

C 23

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2024/School/480

Dated: 29/05/2024

FIRE SAFETY CERTIFICATE

Certified that the Building MC Primary School, Located at Dwarka Sector - 3, Phase - 3, New Delhi, having Two Blocks comprised of **Ground + 01 Upper floor** was issued Fire Safety Certificate by this department vide Letter no. F6/DFS/MS/School/2021/165 Dated 01/03/2021. The premise was re inspected by the officer concerned of this department on 22/05/2024 in the presence of Ms. Ved Dabas (Principal). All the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance with DOE 3298-3398 dated 1-3-2011 issued by the Director of Education and that the building/ premises is fit for occupancy class B "Educational" (Except Auditorium) with effect from 29/05/2024.... for a period of three years, subject to compliance of the condition given below.

Issued on 29/05/2024.... at New Delhi by.

(Atul Garg)
Director
Delhi Fire Service

Copy to: -

1. The Principal, MC Primary School, Dwarka Sector - 3, Phase - 3, New Delhi.
2. Directorate of Education Old Secretariat Delhi - 110054.


Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used strictly as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. www.dfs.delhigovt.nic.in.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

N/13
INSPECTION REPORT

1. Name & address of the building: MC Primary School, Located at Dwarka Sector - 3, Phase - 3, New Delhi
2. Type of Occupancy : Educational Two Blocks(Ground + 01 Upper Floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2021/165 Dated 01/03/2021
5. Fire Safety directives Letter No. : DOE 3298-3398 dated 01-03-2011
6. Date of inspection : 22/05/2024
7. Name of the Inspecting Officer :Udai vir singh, ADO (DWK)
8. Name and designation of Officer
from the building side :Ms. Ved Dabas (Principal)
9. Year of Construction : 2004,2010
10. Applicant's letter No. :Email dated 08/05/2024

| S No | Minimum standards on fire prevention and fire safety U/R 33 | Cr.No.3298-3398 dated 1-3-11 | Provided at site | Remarks MR/NMR |
|------|---|---|---|----------------|
| 1. | Access of building | | | |
| | • Road width | 06 mtr | 10 mtr | MR |
| | • Gate width | 4.5 mtr | 05 mtr | MR |
| | • Width of internal road | NA | NA | NA |
| 2. | Number, width, Type & Arrangements of exits | | | |
| | a. Number of staircases | | | |
| | • Upper floors | 02 Nos. | 04 Nos. | MR ✓ |
| | • Basements | NA | NA | NA |
| | b. Width of staircases | | | |
| | • Upper floors | 1.5 mtr if less than 1.5 mtr additional staircase of 0.75 mtr is required | Old block 1.59 , 1.25 & New block 1.35 & 1.36 mtr | MR |
| | • Basements | | | |
| | c. Protection of exits | NA | NA | NA |
| | • Fire check door | | | |
| | • Pressurization | NA | NA | NA |
| | d. No of continuous staircase to terrace | NA | NA | NA |
| | e. Width Of Corridor | Required | 212cm | MR |
| | f. Door Size | 01 mtr | 01 mtr | MR |
| 3. | Compartmentation | | | |
| | • Fire check door | NA | NA | NA |
| | • Sealing of electrical shafts | NA | NA | NA |
| | • Fire Rating of shaft door | NA | NA | NA |
| | • Water Curtain | NA | NA | NA |
| | • Fire Dampers | NA | NA | NA |



N/14

| | | | | |
|-----|---|--|--|--|
| 4. | Smoke managements System | | | |
| | <ul style="list-style-type: none"> Basements Upper floors | NA 12 a/c per hour | NA Natural ventilation | NA MR |
| 5. | Fire Extinguishers | | | |
| | <ul style="list-style-type: none"> Total numbers Types IS marking | 02ABC & CO ₂ For every 300 sq. mtrs ISI marked | 11Nos. ABC & CO ₂ ISI marked | MR MR MR |
| 6. | First – Aid Hose Reels | | | |
| | <ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter | NA NA NA | NA NA NA | NA NA NA |
| 7. | Automatic fire detection and alarming system | | | |
| | <ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location | NA NA NA NA NA | NA NA NA NA NA | NA NA NA NA NA |
| 8. | MOEFA | NA | NA | NA |
| 9. | Public Address System | NA | NA | NA |
| 10. | Automatic Sprinkler System | | | |
| | <ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling | NA NA NA | NA NA NA | NA NA NA |
| 11. | Internal Hydrants: | | | |
| | <ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box | NA NA NA | NA NA NA | NA NA NA |
| 12. | Yard Hydrants | | | |
| | <ul style="list-style-type: none"> Total number of hydrants Hose Box | NA NA | NA NA | NA NA |
| 13. | Pumping Arrangements | | | |
| | <ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Staring/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump | NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA | NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA | NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA |

[Handwritten signature]

| | | | | |
|-----|--|----|--|----|
| 14. | Captive water Storage for fire fighting: | | | |
| | • Under ground tank capacity | NA | NA | NA |
| | ➤ Draw off connection | NA | NA | NA |
| | ➤ Fire service inlet | NA | NA | NA |
| | ➤ Access to tank | NA | NA | NA |
| | • Overhead Tank capacity | NA | NA | NA |
| 15 | Exit Signage | NA | NA | NA |
| 16. | Provision of Lifts | | | |
| | ➤ Pressurization of Lift Shaft | NA | NA | NA |
| | ➤ Pressurization of lift lobby | NA | NA | NA |
| | ➤ Communication in lift Car | NA | NA | NA |
| | ➤ Fireman's Grounding Switch | NA | NA | NA |
| | ➤ Lift Signage | NA | NA | NA |
| 17. | Standby power supply | NA | NA | NA |
| 18. | Refuge Area | | | |
| | ➤ Total area | NA | NA | NA |
| | ➤ Location | NA | NA | NA |
| 19. | Fire control room | | | NA |
| | ➤ Detector system panel | NA | NA | NA |
| | ➤ Flow Switch Panel | NA | NA | NA |
| | ➤ PA System Panel | NA | NA | NA |
| | ➤ Battery backup | NA | NA | NA |
| | ➤ Building Floor Plans | NA | NA | NA |
| 20. | Special Fire Protection Systems for Protection of special Risks, if any; | NA | ABC fire extinguisher provided near electric panel | MR |

The fire protection systems provided in the building were test checked and found functional at the time of inspection.
 In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter F6/DFS/MS/School/2021/165 Dated 01/03/2021 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

[Signature]
 Signature of the Inspecting Officer
 Name *Uday V K Singh*
 Designation *ASD/DWR*

[Signature]
[Signature]
 CFO (S2)
[Signature]
 21/05/2021
[Signature]
 21/05/21

[Signature]
[Signature]