



No. F6/DFS/MS/EH/NDZ/2024/ 174

Dated: 07/06/2024

FIRE SAFETY CERTIFICATE

Certified that the M/s Miraj Cinema A Unit of Moon Shine Entertainment Limited (Chand Cinema) Restaurant ruining on 3rd floor located at Chand Cinema Part 2, Trilok Puri, Delhi – 110091, building comprised of three basement, Ground plus four upper floors only, owned/occupied Miraj Cinema A Unit of Moon Shine Entertainment Limited have complied with the Fire Prevention and Fire Safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 30/05/2024 in the presence of Mr. Vikas Tyagi (Manager) and found that the building/premises is fit for occupancy class “Assembly Building” (Group D) Eating House (Restaurant at running third floor only) and valid up to 31/03/2027 in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 printed below.

Issued 07/06/2024 at New Delhi by.


(ATUL GARG)
DIRECTOR
D/C DELHI FIRE SERVICE

Copy to:-

1. The Manager, Moon Shine Entertainment Limited (Chand Cinema) located at Trilok Puri, Delhi - 110091.
2. M/s Miraj Cinema A Unit of Moon Shine Entertainment Limited (Chand Cinema) located at Chand Cinema Part 2, Trilok Puri, Delhi – 110091

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. Basement shall be used as per NBC/UBBL.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & address of the building	Miraj Cinema A Unit of Moon Shine Entertainment Limited (Chand Cinema) located at Chand Cinema Part 2, Trilok Puri, Delhi - 110091.		
2	Building is comprised of	03 Basement, Ground + 04 upper floors only. Restaurant ruining on 3 rd floor.		
3	Type of occupancy	Eating House (Restaurant)		
4	Type of case	Nil (FSC also issued to the Chand Cinema vide letter No. F6/DFS/MS/Cinema/NDZ/2024/242 dated 19/04/2024.		
5	Details of previous FSC	Nil		
6	Fire safety directives letter no.	F6/DFS/MS/BP/2019/113 dated 15.03.2019		
7	Date of inspection	30.05.2024		
8	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)		
9	Name of the designation of officer from the building side	Mr. Vikas Tyagi (Manager)		
10	Year of construction	2020		
11	Applicant's letter no.	MHA ID no. 202452007874 dated 20/05/2024		
S.No	Minimum standard of fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1	Access to Building:			
	A	Road width	30 mtrs.	30 mtrs. MR
	B	Gate width	6.0 mtrs.	6.0 mtrs. MR
	C	Width of internal road	9.0 mtrs.	9.0 mtrs. MR
2	Number, Width, Type and Arrangement of Exits:			
	A	Number of staircases		
		a	Upper floor	02 nos. 03 nos. MR
		b	Basement	03 nos. 03 nos. + 01 no. ramp MR
	B	Width of staircases		
		a	Upper floor	2.0 mtrs. 2.0 mtrs. MR
		b	Basement	2.0 mtrs. 2.0 mtrs. (Ramp 7.30 mtrs.) MR
	C	Protection of exits		
		a	Fire check door	Required Provided MR
		b	Pressurization	Required Provided MR
	D	No. of continuous staircases to terrace		
			02 nos.	04 nos. MR
	E	Width of corridor		
			Required	Provided MR
	F	Door size		
			Required	Provided MR
3	Compartmentation:			
	A	Fire check door		
			Required	Provided MR
	B	Sealing of electrical shafts		
			Required	Sealed MR
	C	Fire rating of shaft door (02 hrs)		
			Required	Provided MR
	D	Water curtain		
			Required	Provided MR
	E	Fire dampers		
			Required	Provided MR
4	Smoke Management System:			
	A	Basement		
			30 a/c per hrs	Provided MR
	B	Upper floor		
			12 a/c per hrs	Provided MR

Chand Cinema located at Trilok Puri, Delhi - 110091.

N/2

5. Fire Extinguisher:		Provided In the Cinema		
A	Total numbers	40 nos.	52 nos.	MR
B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
C	ISI marking	ISI Marked	ISI Marked	MR
6 First-Aid-Hose Reel:		Provided In the Cinema		
A	Total numbers of	All Basements - 03nos Ground floor -04 nos. First & third each floors - 11 nos. Second & fourth each floor- 03 nos. Terrace - 03 nos.	Provided	MR
B	Length of hose reel hose	30 mtrs.	Provided	MR
C	Nozzle diameter	05 mm	Provided	MR
7 Automatic Fire Detection and Alarming System:				
A	Type of detectors	Smoke & Heat	Provided	MR
B	Location of main panel	Ground floor entry gate no. 01	Provided	MR
C	Location of repeater panel	In main building control room	Provided	MR
D	Alternate source of power	Batter & DG Set	Provided	MR
E	Hooters location	Staircase	Provided	MR
8	MOEFA:	Required	Provided	MR
9	Public Address System:	Required	Provided	MR
10 Automatic Sprinkler System:		Provided In the Cinema		
A	Basement	Required	Provided	MR
B	Upper floor	Required	Provided	MR
C	Sprinkler above false ceiling	Required	Provided	MR
11 Internal Hydrants:				
A	Size of riser/down-comer	150 mm	Provided	MR
B	No. of hydrants per floor	Required	Provided	MR
C	Hose box	Required	Provided	MR
12 Yard Hydrants:				
A	Total number of hydrants	05 nos.	05 nos.	MR
B	Hose box	05 nos.	05 nos.	MR
13 Pumping Arrangements:		Provided In the Cinema		
1 Ground level				
A	Discharge of main pump	2850 LPM	2850 LPM	MR
B	Head of main pump	120 M	120 M	MR
C	Number of main pumps	02 nos.	02 nos.	MR
D	Jockey pump out put	180 LPM	180 LPM	MR
E	Jockey pump head	120 M	120 M	MR
F	Standby pump out put	2850 LPM	2850 LPM	MR
G	Standby pump head	120 M	120 M	MR
H	Water Curtain Pump	900 LPM	900 LPM	MR
I	Auto starting /manual stopping	Auto	Provided	MR
J	Pump house access	Required	Provided	MR
2 Terrace Level				
A	Discharge of pump	N/A	N/A	N/A
B	Head of the pump	N/A	N/A	N/A
C	Power supply	N/A	N/A	N/A
D	Auto starting of pump	N/A	N/A	N/A


W

8/

14	Captive Water Storage for Fire Fighting:			
A	Underground tank capacity	2,00,000 Liters	2,00,000 Liters	N/A
B	Draw-off connection	Required	Provided	MR
C	Fire service inlet	Required	Provided	MR
D	Access to tank	Required	Provided	MR
E	Overhead tank capacity	20,000 liters	20,000 liters. ✓	MR
15	Exit Signage:	Required	Provided	MR
16	Provision of Lifts: Provided In the Cinema			
A	Pressurization of lift shaft	Required	Provided	MR
B	Pressurization of lift lobby	Required	Provided	MR
C	Communication in lift car	Required	Provided	MR
D	Firemen's grounding switch	Required	Provided	MR
E	Lift signage	Required	Provided	MR
17	Standby Power Supply:	Required	Provided	MR
18	Refuge Area:			
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
19	Fire Control Room: Provided In the Cinema			
A	Detector system panel	Required	Provided	MR
B	Flow switch panel	Required	Provided	MR
C	PA system panel	Required	Provided	MR
D	Battery backup	Required	Provided	MR
E	Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	Required for HT/LT Panels	Provided in all HT & LT Panels	MR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards of fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.


31/5/2024

Signature of the Inspecting Officer
Name: - Yashwant Singh Meena
Designation: - ADO (L.N)

~~DY. CFO/NDZ~~
~~C.F/O~~
~~Director~~
~~21/6/24~~
~~21/6/24~~
~~21/6/24~~

Sir. F. T Letter is setup for sign. Please
Director
21/6/24