

No. F6/DFS/MS/Petrol/2024/WZ/347

Dated:- 06/06/2024

FIRE SAFETY CERTIFICATE

Certified that the Petroleum Oil Storage Tank Terminals (Hindustan Petroleum Corporation Ltd.), Located at Rohtak Road, Tikri Kalan (Delhi Terminal), New Delhi-110041, owned/occupied by H.P.C.L, was issued Fire Safety Certificate by this department Vide Letter No. F6/DFS/MS/Petrol/2021/WZ/258 Dated 31/05/2021. The said premise was re-inspected by the officer concerned of this department on 20/05/2024 in the presence of Sh. Ajay Kumar (Chief Manager Installation) and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules, 2010 and provision of OISD 117 (Revised) and that the premises/building is fit for occupancy class "Hazardous Building" Group - J with effect from 06/06/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 06/06/2024..... at New Delhi by.

(Atul Garg)
Director
Tel. No. 011-23414000

Copy to: -

1. Sh. Ajay Kumar, Chief Manager Installation, Hindustan Petroleum Corporation Ltd., Delhi Terminal, Tikri Kalan, New Delhi-110041.

Conditions for the validity of Fire Safety Certificate:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.