



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

C/66

75
आजादी का
अमृत महोत्सव

No. F6/DFS/MS/WZ/School/2024/WZ/ 500

Dated:- 05/06/2024

FIRE SAFETY CERTIFICATE

Certified that the Prudence School {A Unit of The Great India Educational Society (Regd.)} Located at Plot No. 2, Meera Bagh, A-block, Near Meera Bhawan, Paschim Vihar, New Delhi, comprised of Basement + Stilt + Upper Ground + 02 Upper Floors, was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/2021/WZ/374 dated 10/02/2021. The said premise was re-inspected by the officer concerned of this department on 22/05/2024 in the presence of Dr. Harish Sabharwal (President) and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules, 2010 and that the school building is fit for occupancy class "Educational Building" Group B" with effect from 05/06/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010 printed below.

Issued on 05/06/2024 at New Delhi by

(Atul Garg)
Director

Tel No. 011-23414000

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054.
2. The Principal, The Great India Educational Society, Plot No. 2, Meera Bagh, A-Block, Near Meera Bhawan, Paschim Vihar, New Delhi.

Following fire safety directives must be adhered to:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name and address of the building: **Prudence School {A Unit of The Great India Education Society (Regd.)}** located at Plot No. 2, Meera Bagh, A-block, Near Meera Bhawan, Paschim Vihar, New Delhi-110087
2. Type of Occupancy : Educational, (B+Stilt+GF+ 02 Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2021/WZ/374 Dated 10/05/2021
5. Fire Safety directives Letter No. : F6/DFS/MS/BP/2016/318 dated 07/12/2016
6. Date of inspection : 22/05/2024
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer
from the building side : Dr. Harish Sabharwal (President)
9. Year of Construction : 2016
10. Applicant's letter No. : email dated 11/05/2024

S No	Minimum standards on fire prevention and fire safety U/R 33	Directive letter dated 07/12/2016/as per FSC dated 10/05/2021	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02 nos.	Provided	MR
	• Basements	02 nos.	Provided	MR
	b. Width of staircases			
	• Upper floors	1.5 m x 1 & 1.35 m x 1	1.60 m x 2	MR
	• Basements	1.5 m x 1 & 1.35 m x 1	1.60 m x 2	MR
	c. Protection of exits			
	• Fire check door	Required in basement	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	01	Provided	MR
	e. Width Of Corridor	1.5 m	1.90 m	MR
	f. Door Size	1 m	1.25 m	MR
3.	Compartmentation		NA	
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	Required	Provided	MR
	• Upper floors	NA	NA	NA

5.	Fire Extinguishers		16 nos.	MR
	• Total numbers	12 nos.	16 nos.	MR
	• Types	ABC & CO ₂	Provided	MR
	• ISI marking	ISI Marked	Provided	MR
6.	First – Aid Hose Reels		02 nos.	MR
	• Total numbers on each floor	01 no.	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			NA
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	Provided	NA
9.	Public Address System	NA	N/A	NA
10.	Automatic Sprinkler System			
	• Basements	Required in Basement & Slit floor	Provided	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	100 mm	NA
	• Number of hydrants per floor	NA	01	NA
	• Hose Box	NA	01	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level	2280 lpm	Provided	MR
	• Discharge of main pump	70 m	Provided	MR
	➤ Head of main pump	01	Provided	MR
	➤ Number of main pumps	180 lpm	Provided	MR
	➤ Jockey pump out put	40 m	Provided	MR
	➤ Jockey pump head	2280 lpm	Provided	MR
	➤ Standby Pump out put	70 m	Provided	MR
	➤ Standby Pump Head	Required	Provided	MR
	➤ Auto Staring/Manual stopping	Required	Provided	MR
	➤ Pump House Access			
	• Terrace level	900 lpm	Provided	MR
	➤ Discharge of pump	40 m	Provided	MR
	➤ Head of the pump	Required	Provided	MR
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump			
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	1,00,000 ltrs.	Provided	MR
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	15,000 ltrs.	20,000 ltrs	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts	Two lifts are provided in basement to upper floors		
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR

		Required	Provided	MR
17.	Standby power supply			
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

Fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety requirements under the rules, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/2021/WZ/374 Dated 10/05/2021 is recommended under Rule 37 of the Delhi Fire Service Rules, 2010 under the DFS Act 2007.

Accordingly DFA is put up for approval please.

[Signature]
20/05/24
Aman Kumar Lathar
ADO (JWP)

~~DCFO (w2)~~

~~*[Signature]*~~
3/6/2024

~~CFO~~ *[Signature]*
3/6/2024

~~Director~~ *[Signature]*
3/6/24

AOO/OP

Sir, F.S. letter is added for your signature M.

~~Director~~ *[Signature]*
4/06/24
[Signature]

[Signature]
04/06/24
AOO (JWP)

252
3/6/2024