

C-60

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/GH/NDZ/2024/ 191

Dated: 28/05/2024

FIRE SAFETY CERTIFICATE

Certified that the **Radha Krishna Guest House** located at **8913/2, Multani Dhand, Pahar Ganj, New Delhi** comprised of Ground floor (Reception), 1st floor (05 guest rooms), 2nd floor (05 guest rooms) and 3rd floor (05 guest rooms), total 15 guest rooms owned/occupied by Radha Krishna Guest House was earlier granted FSC by this department vide letter No.F6/DFS/MS/GH/NDZ/2021/257 dated 27/07/21. Now, The premise was re-inspected by the officer concerned of this department on **16/05/24** in the presence of Sh. Vikas and found that the said guest house building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Residential, Sub Division-A-1 Ground floor (Reception), 1st floor to 3rd floor (05 guest rooms at each floor) total 15 guest rooms up to third floor** and valid up to 31.03.2027 from the date of issue in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 28/05/2024 New Delhi by.


(Atal Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Commissioner, North MCD, Civic Centre, New Delhi: to ensure not to use any floor above third floor.
2. The Addl. Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi. Online id no. 2024043006498 dated 30/04/24.
3. The Manage, Radha Krishna Guest House 8913/2, Multani Dhand, Pahar Ganj, New Delhi.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
9. Any flammable material for interior decoration is prohibited.

INSPECTION REPORT

- | | |
|--|---|
| 1. Name & address of the building | Radha Krishna Guest House at 8913/2, Multani Dhanda, Pahar Ganj, New Delhi |
| 2. Type of occupancy:- | Residential, Sub Division-A-1
Gr. + 03 Upper floors (total 15 Guest rooms)
Ground (Reception), 1 st floor (05 guest rooms),
2 nd floor (05 guest rooms) and 3 rd floor (05 guest rooms) |
| 3. Type of case:- | Renewal |
| 4. Details of previous FSC:- | No. F6/DFS/MS/GH/NDZ/2021/257 dated 27/07/21. |
| 5. Fire safety directives No.- | N/A |
| 6. Date of inspection:- | 16/05/24. |
| 7. Name of the inspecting officer:- | Sh. Ravinder Singh (ADO/CC) |
| 8. Name & designation of officer
From the building side:- | Sh. Vikas
2008 |
| 9. Year of construction:- | Online id no. 2024043006498 dated 30/04/24. |
| 10. Applicant's letter No:- | Old Case |

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	N/A	04 mtr. ✓	N/A
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	01 Nos.	01 Nos. ✓	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	0.80 mtr.	1.25 mtr. ✓	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01	01 ✓	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1.0 mtr.	1.0 mtr. ✓	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 ACPH	N/A	N/A
	2) Upper floors	12 a/c per hour	Natural/exhaust	MR
5.	Fire Extinguishers			
	1) Total numbers	10 Nos.	10 Nos. ✓	MR
	2) Types	ABC & CO2	ABC & CO2	MR

1/23

	3) ISI marking	Required	Provided	✓	MR
6.	First-Aid Hose Reel				
	1) Total number of each floor	01	01	✓	MR
	2) Length of hose reel hose	30 m	30 m	✓	MR
	3) Nozzle diameter	05 mm	05 mm	✓	MR
7.	Automatic Fire Detection & Alarming System				
	1) Type of detectors Co Type	Required	Provided	✓	MR
	2) Location of main panel	Ground floor	Provided	✓	MR
	3) Location of repeater panel	N/A	N/A		N/A
	4) Alternate source of power	Required	Provided		MR
	5) Hooter's Location	Each floor	Provided		MR
8.	MOEFA	N/A	N/A		N/A
9.	Public Address System	Required	Provided	✓	MR
10.	Automatic Sprinkler System				
	1) Basement	N/A	N/A		N/A
	2) Upper floors	N/A	N/A		N/A
	3) Sprinkler above false ceiling	N/A	N/A		N/A
11.	Internal Hydrants				
	1) Size of riser/down-comer	N/A	N/A		N/A
	2) Number of hydrants per floor	N/A	N/A		N/A
	3) Hose box	N/A	N/A		N/A
12.	Yard Hydrants				
	1) Total number of hydrants	N/A	N/A		N/A
	2) Hose box	N/A	N/A		N/A
13.	Pumping Arrangement				
	1) Ground level	N/A	N/A		N/A
	a) Discharge of main pump	N/A	N/A		N/A
	b) Head of main pump	N/A	N/A		N/A
	c) Number of main pump	N/A	N/A		N/A
	d) Jockey pump output	N/A	N/A		N/A
	e) Jockey pump head	N/A	N/A		N/A
	f) Stand by pump output	N/A	N/A		N/A
	g) Stand by pump head	N/A	N/A		N/A
	h) Auto starting/Manual stopping	N/A	N/A		N/A
	2) Terrace level				
	a) Discharge of pump	450 LPM	450 LPM	✓	MR
	b) Head of pump	30 mtr.	30 mtr.	✓	MR
	c) Power supply	Required	Provided		MR
	d) Auto starting of pump	Required	Provided		MR
14.	Captive Water Storage for Fire Fighting				
	1) Under ground tank capacity	N/A	N/A		N/A
	a) Draw-off connection	N/A	N/A		N/A
	b) Fire service inlet	N/A	N/A		N/A


2/24

	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	2500 ltr.	2500 ltr. /	MR
15.	Exit Signage.	Required	Provided /	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided /	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. No.F6/DFS/MS/GH/NDZ/2021/257 dated 27/07/21 renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended up to third floor only.

Signature of the Inspecting Officer




Name: - Ravinder Singh
Designation: - ADO (CC)

DO (CD)


22/5/24

Dy. C.A. (RD2)


22/05/24

C.F.O.

21/5/2024

Director

22/5/24

