

239

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
 [Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/School/2024/ 504

Dated: 05/06/2024

FIRE SAFETY CERTIFICATE

Certified that the Building at Shiksha Bharti Educational Society, Senior School Building Located at Sector-8, Dwarka, New Delhi-110075, comprised of Basement + Ground + 4 Upper Floor was issued FSC vide Letter No. F6/DFS/MS/School/2021/376 Dated 10/05/2021. The premises was re inspected by the officers concerned of this department on 24/05/2024 in the presence of Mr. S.C Rawat (Manager) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class-B "Educational building" with effect from 05/06/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 05/06/2024 at New Delhi by.


 (Anul Garg)
 Director
 Delhi Fire Service.

Copy to:

1. The Principal, Shiksha Bharti Educational Society, Senior School Building Located at Sector-8, Dwarka, New Delhi-110075.
2. Directorate of Education Old Secretariat Delhi - 110054.

Following fire safety directives must be adhered to:-

- 1 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 2 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 3 The trained staff should be available round the clock.
- 4 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 5 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 6 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
- 7 Basement shall be used strictly as per building bye laws.
- 8 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: Shiksha Bharti Educational Society, Senior School Building Located at Sector-8, Dwarka, New Delhi-110075
2. Type of Occupancy : Educational (Basement + Ground+ 4 Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2021/376 Dated 10/05/2021
5. Fire Safety directives Letter No. : F6/DFS/MS/BP/2013/323 Dated 29/10/13
6. Date of inspection : 24-05-2024
7. Name of the Inspecting Officer : Udai vir singh, ADO (DWK)
8. Name and designation of Officer
from the building side : Mr. S.C Rawat (Manager)
9. Year of Construction : 2018
10. Applicant's letter No. : Email Dated 03/05/2024


Total Area = 7125 sqm.
Class rooms = 70
No. of students = 2217

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/2	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	09 mtr	30 m	MR
	• Gate width	4.5 mtr	06 m	MR
	• Width of internal road	06 mtr	Old case	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	4 Nos.+1 Ramp	4 Nos.+1 Ramp	MR (Old case)
	• Basements	3 Nos.+2 Ramp	3 Nos.+2 Ramp	MR (Old case)
	b. Width of staircases			
	• Upper floors	1.5 m	4x150cm Provided	MR (Old case)
	• Basements	1.5 m	3x150cm Provided	MR (Old case)
	c. Protection of exits			
	• Fire check door	Required	Provided at basement	MR
	• Pressurization	NA	Open to air	NA
	d. No of continuous staircase to terrace	03 Nos.	Provided	MR
	e. Width Of Corridor	1.5m	Provided	MR (Old case)
	f. Door Size	1-1.50 mtr	Provided	MR (Old case)
3.	Compartmentation			
	• Fire check door	Required	Provided at basement	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	02 Hrs	Provided	MR
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	30 a/c charge	Provided	MR
	• Upper floors	12 a/c charge	Natural ventilation	MR

(Handwritten Signature)

N/26

5.	Fire Extinguishers			
	• Total numbers	30 nos.	32 Nos. Provided	MR
	• Types	ABC & CO ₂	ABC & CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR
6.	First - Aid Hose Reels			
	• Total numbers on each floor	03 Nos.	Provided	MR
	• Length of hose reel hose	30	Provided	MR
	• Nozzle diameter	05 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	03 Nos.	03 Nos.	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	1620 lpm	Provided	MR
	➤ Head of main pump	40 m	Provided	MR
	➤ Number of main pumps	01	Provided	MR
	➤ Jockey pump out put	NA	Provided	NA
	➤ Jockey pump head	NA	Provided	NA
	➤ Standby Pump out put	1620 lpm	Provided	MR
	➤ Standby Pump Head	40 m	Provided	MR
	➤ Auto starting/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	NA	450LPM	NA
	➤ Head of the pump	NA	40m	NA
	➤ Power supply	NA	Provided	NA
	➤ Auto starting of pump	NA	Provided	NA



14.	Captive water Storage for fire fighting:	Required	50000 ltr	MR
	• Under ground tank capacity	NA	NA	MR
	➤ Draw off connection	NA	NA	MR
	➤ Fire service inlet	NA	NA	MR
	➤ Access to tank	NA	NA	MR
	• Overhead Tank capacity	25000 ltrs	25000 ltr	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	DG set 120 KVA	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	CO2 Fire extinguisher provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter F6/DFS/MS/School/2021/376 Dated 10/05/2021 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended. If approved FSC may be issued.

Signature of the Inspecting Officer
 Name Uday Kumar Singh
 Designation ADO/DWT

[Signature] 28/5/24

[Signature] 28/5/24

[Signature] 28/5/24

[Signature] 29/5/24

[Signature]