

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No. F.6/DFS/MS/EH/2024/SZ/170

Dated 31/05/2024

FIRE SAFETY CERTIFICATE

Certified that the Eating House in the Name & Style of **M/s Locale** located at **Shop No 17, Community Centre, Saket, New Delhi 110017** comprised of Basement Ground plus Three Upper Floors but (**Restt. running on Second & Third Floor only**) owned/occupied by A Unit of **Foursome Foods Pvt Ltd** was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/EH/2021/SZ/229 dated 14/09/2021. The restaurant premise was re-inspected by the officer concerned of this department on 24/05/2024 in the presence of Sh. Gurvinder Singh and found that the said premise have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy **Class D "Assembly Building"** Restaurant at 2nd & 3rd floor only and **validity upto 31/03/2027** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 31/05/2024 at New Delhi by


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Joint C.P (Lic/Branch) First Floor, PS Defence Colony, New Delhi -110049.
(Ref. MHA Portal ID 2024051007323 dated 13/05/2024)

Conditions for the validity of Fire Safety Certificate: -

1. This FSC is Valid for 2nd & 3rd Floor only.
2. All the means of escape/entry/exit shall be kept free from any obstruction.
3. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire fighting system.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

INSPECTION REPORT

1	Name & Address of the Building	M/s Locale (A Unit of Foursome Foods Pvt Ltd.) Shop No 17, Community Centre, Saket New Delhi 110017		
2	Type of Occupancy	Assembly 'Group-D' (Restaurant at Second and Third Floor only)		
3	Building comprised of	Basement, Ground Plus Three Upper Floor		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/EH/SZ/2021/229 dated 14/09/2021		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	24.05.2024		
8	Name of the Inspecting Officers	DO (South) & ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Gurvinder Singh		
10	Year of construction/ date of conversion	1999		
11	Applicant letter No.	MHA Portal Id 2024051007323 dated 13-05-2024		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	As per old NOC	Provided at Site	Remarks
1	Access to Building.			
	• Road width	9 m	24 m Provided	MR
	• Gate width	Required	1.5 mtr restaurant gate provided	MR
	• Width of internal road	NA	NA	-NA-
2	Number, width, type & arrangement of exits			
	a. Number of Staircase			
	• Upper floors	01 Nos	01 Nos	MR (old case)
	• Basement floor	01 Nos	01 Nos	MR (old case)
	b. Width of Staircase			
	• Upper floors	1.25m	1.19 mtr	MR (Old Case)
	• Basement floor	1.25m	1.19 mtr	MR (Old Case)
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	-NA-	NA	-NA-
	d. No. of continuous staircase to terrace	Required	01 No Provided	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1.5 mtr	1.5 mtr	MR
3	Compartmentation.			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4	Smoke Management system.			
	• Basement	30 ACPH	N/A	N/A
	• Upper floors	12 ACPH	Exhaust Fan	M/A
5	Fire Extinguishers.			
	• Total numbers	12 Nos	Provided	MR
	• Types	ABC / CO2	ABC-06& Co2-06	MR
	• ISI Marking	ISI marked	Provided	MR
6	First Aid Hose Reels.			
	• Total numbers on each floor.	One	Provided	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR
7	Automatic fire detection & alarming system.			
	• Type of detectors	N/A	N/A	N/A

	<ul style="list-style-type: none"> Location of Main Panel Location of Repeater Panel Alternate source of power Hooper's location 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System	Required	Provided	MR
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	N/A	N/A	N/A
		Required	Provided	MR
		N/A	N/A	N/A
11	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box. 	100mm	Provided	MR
		01	Provided	MR
		01	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
13	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby Pump head. Auto Starting / Manual Stopping. Pump House Access 	N/A	-NA-	-NA-
		N/A	-NA-	-NA-
		N/A	-NA-	-NA-
		N/A	-NA-	-NA-
		N/A	-NA-	-NA-
		N/A	-NA-	-NA-
		N/A	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Terrace Level 			
	<ul style="list-style-type: none"> Discharge of pump. Head of pump. Power supply. Auto starting of pump. 	450 LPM & 180 LPM	Provided	MR
		40 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive water storage for Fire Fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. <ul style="list-style-type: none"> Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. 	N/A	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		5,000 ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	N/A	-NA-	-NA-
		N/A	-NA-	-NA-
		Required	Provided	MR
		Required	Provided	MR
		N/A	-NA-	-NA-
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area			

	<ul style="list-style-type: none"> Total area Location 	-NA-	-NA-	-NA-
19	Fire Control Room.	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Detector System Panel. Flow Switch Panel. PA system Panel. Battery backup Building floor plan 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
20	Special Fire Protection System for the Protection of special Risk, if any :	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Further, the party has complied all the observation / Shortcoming already issued & communicated by this department vide letter of even no 165 dated 06/05/2024.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/EH/SZ/2021/229 dated 14/09/2021, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

[Handwritten Signature]

Signature of the Inspection Officer
Name: Sh. Manoj Kumar Sharma
Design: DC (South)

[Handwritten Signature]
28/5/24

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

CFO (HQ)

[Handwritten Signature]
28 5/2024
Director
[Handwritten Signature]
28/5/24
ADDO/BCP

As approved, F.T. letter is sent for your signature !!

[Handwritten Signature]
28/5

[Handwritten Signature]
28/5/24
[Handwritten Signature]

Uploaded
03/06/24