



FIRE SAFETY CERTIFICATE

Certified that the **Shri R.B. Public School** located at **E - 135, Dilshad Garden, Delhi - 110095**, comprised of **ground plus two upper floors**, owned/occupied by **Shri R.B. Public School**, was issued Fire Safety Certificate vide letter No. F6/DFS/MS/School/2019/NDZ/545 dated 15/03/2019. The School building was re-inspected by the officer concerned of this department on dated 30.05.2024 in the presence of Mr. Deepak Sharma (Manager) of the school and found that the school have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and observed that the school building is fit for occupancy class **Group B "Educational Building"** with effect from 07/06/2024 for a period of **three years**, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on 07/06/2024 at New Delhi by.


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Dy. Director of Education, B-Block, Plot No. 419, Yamuna Vihar, North-East, Delhi - 110053.
2. The Principal, Shri R.B. Public School located at E - 135, Dilshad Garden, Delhi - 110095.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & address of the building	Shri R.B. Public School located at E - 135, Dilshad Garden, Delhi - 110095.
2	Building is comprised of	Ground plus two upper floors.
3	Type of occupancy	Educational Building
4	Type of case	Renewal
5	Details of previous FSC	F6/DFS/MS/School/2019/NDZ/545 dated 15/03/2019.
6	Fire safety directives letter no.	NBC Part-IV.
7	Date of inspection	30/05/2024.
8	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)
9	Name of the designation of officer from the building side	Mr. Deepak Sharma (Manager)
10	Year of construction	2011
11	Applicant's letter no.	Outdoor dairy no. 2004 dated 24/05/2024

S.No	Minimum standard of fire prevention and fire safety U/R 33	NBC Part - IV Requirement	Provided at site	Remarks MR/NMR
1	Access to Building:			
A	Road width	6.0 mtrs.	6.0 mtrs. ✓	MR
B	Gate width	N/A	N/A	N/A
C	Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits:			
A	Number of staircases			
a	Upper floor	01 no.	02 nos. ✓	MR
c	Basement	N/A	N/A	N/A
B	Width of staircases			
a	Upper floor	1.50 mtrs	1.10 mtrs. & 1.50 mtrs. ✓	MR
b	Basement	N/A	N/A	N/A
C	Protection of exits			
a	Fire check door	N/A	N/A	N/A
b	Pressurization	N/A	N/A	N/A
D	No. of continuous staircases to terrace	01 no.	01 no. ✓	MR
E	Width of corridor	1.50 mtrs.	2.0 mtrs. ✓	MR
F	Door size	1.0 mtr.	1.0 mtr.	MR
3	Compartmentation:			
A	Fire check door	NA	NA	NA
B	Sealing of electrical shafts	N/A	N/A	N/A
C	Fire rating of shaft door	N/A	N/A	N/A
D	Water curtain	N/A	N/A	N/A
E	Fire dampers	N/A	N/A	N/A
4	Smoke Management System:			
A	Basement	N/A	N/A	N/A
B	Upper floor	N/A	N/A	N/A

(3)

2/17

Shri R.B. Public School located at E-135, Dilshad Garden, Delhi-110095

5.	Fire Extinguisher:				
	A	Total numbers	06 nos.	08 nos. ✓	MR
	B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
	C	ISI marking	ISI marked	ISI marked	MR
6	First-Aid-Hose Reel:				
	A	Total numbers of each floor	01 no.	01 no. ✓	MR
	B	Length of hose reel hose	30 mtrs	30 mtrs	MR
	C	Nozzle diameter	05 mm	05 mm	MR
7	Automatic Fire Detection and Alarming System:				
	A	Type of detectors	N/A	N/A	N/A
	B	Location of main panel	N/A	N/A	N/A
	C	Location of repeater panel	N/A	N/A	N/A
	D	Alternate source of power	N/A	N/A	N/A
	E	Hooters	N/A	N/A	N/A
8	MOEFA:		N/A	N/A	N/A
9	Public Address System:		N/A	N/A	N/A
10	Automatic Sprinkler System:				
	A	Basement	N/A	N/A	N/A
	B	Upper floor	N/A	N/A	N/A
	C	Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants:				
	A	Size of riser/down-comer	N/A	N/A	N/A
	B	Number of hydrants per floor	N/A	N/A	N/A
	C	Hose box	N/A	N/A	N/A
12	Yard Hydrants:				
	A	Total number of hydrants	N/A	N/A	N/A
	B	Hose box	N/A	N/A	N/A
13	Pumping Arrangements:				
1	Ground level				
	A	Discharge of main pump	N/A	N/A	N/A
	B	Head of main pump	N/A	N/A	N/A
	C	Number of main pumps	N/A	N/A	N/A
	D	Jockey pump out put	N/A	N/A	N/A
	E	Jockey pump head	N/A	N/A	N/A
	F	Standby pump out put	N/A	N/A	N/A
	G	Standby pump head	N/A	N/A	N/A
	H	Auto starting /manual stopping	N/A	N/A	N/A
	I	Pump house access	N/A	N/A	N/A
2	Terrace Level				
	A	Discharge of pump	450 LPM	450 LPM ✓	MR
	B	Head of the pump	40 m	40 m ✓	MR
	C	Power supply	Required	Provided	MR
	D	Auto starting of pump	Required	Provided	MR

W

62


N/18
Shri R.B. Public School located at E-135, Dilshad Garden, Delhi-110095.

14	Captive Water Storage for Fire Fighting:			
	A	Underground tank capacity	N/A	N/A
	B	Draw-off connection	N/A	N/A
	C	Fire service inlet	N/A	N/A
	D	Access to tank	N/A	N/A
	E	Overhead tank capacity	10,000 liters	10,000 liters
15	Exit Signage:		Required	Provided
16	Provision of Lifts:			
	A	Pressurization of lift shaft	N/A	N/A
	B	Pressurization of lift lobby	N/A	N/A
	C	Communication in lift car	N/A	N/A
	D	Firemen's grounding switch	N/A	N/A
	E	Lift signage	N/A	N/A
17	Standby Power Supply:		N/A	N/A
18	Refuge Area:			
	A	Total area	N/A	N/A
	B	Location	N/A	N/A
19	Fire Control Room:			
	A	Detector system panel	N/A	N/A
	B	Flow switch panel	N/A	N/A
	C	PA system panel	N/A	N/A
	D	Battery backup	N/A	N/A
	E	Building floor plans	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:		N/A	N/A

The fire protection system was randomly checked and tested and was found functional at the time of inspection. The earlier shortcomings issued vide letter no. F6/DFS/MS/School/NDZ/2024/247 dated 16.05.2024 by this department have been rectified by the management.

Keeping in view of above deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules. The NOC / FSC was issued vide letter no. F6/DFS/MS/School/2019/NDZ/545 dated 15/03/2019 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

No file is pending with me before disposal of this case.



Signature of the Inspecting Officer

Name: - Yashwant Singh Meena

Designation: - ADO (L.N)

DY.CFO/NDZ

Handwritten notes and signatures:
 C.F.O. *Mugh*
 4/6/2024
 Director *[Signature]*
 2/06/24
[Signature]

Handwritten signature: Anil LN

Handwritten initials: P.T.D.