

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001**

No. F.6/DFS/MS/EH/2024/SZ/167

Dated: 30/05/2024

**FIRE SAFETY CERTIFICATE**

Certified that the Eating House in the name & style of **M/s SideCar** located at **M-29, First & Second Floor, Greater Kailash New Delhi 110048** in the building comprised of Basement, Ground plus Two upper floors owned/occupied by A Unit of Barkeepers LLP was issued fire safety certificate by this department vide letter no F6/DFS/MS/EH/2021/SZ/282 dated 08/10/2021. The restaurant premise was re-inspected by the officer concerned of this department on 24/05/2024 in the presence of Mr. Gaurav Jain and found that the said premise have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy **Class D "Assembly Building"** (Restaurant) and **validity upto 31/03/2027** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 30/05/2024 at New Delhi by

  
(ATUL KARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to: -

1. The Addl. Commissioner of Police (Lic/Brach), 1<sup>st</sup> Floor, P.S. Defence Colony, New Delhi-110049 (Ref. MHA Portal ID 2024051607684 dated 16/05/2024)

**Conditions for the validity of Fire Safety Certificate: -**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire-fighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

**INSPECTION REPORT**

1. Name & address of the building: M/s Sidecar restaurant (Unit of Barkeepers LLP) M-29, GK-II Delhi.
2. Type of Occupancy : Restt. running at 1<sup>st</sup> & 2<sup>nd</sup> Floor only
3. Type of Case : Renewal
4. Comprised of : Basement + GF + 1<sup>st</sup> + 2<sup>nd</sup> Floor
5. Detail of Previous FSC : F6/DFS/MS/EH/2021/SZ/282 dated 08/10/2021
6. Fire Safety directives letter No : Approval of FPW at N/1
7. Date of inspection : 24/05/2024
8. Name of Inspecting Officer : DO (South) & ADO (BCP)
9. Name and designation of officers from the building side : Mr. Gaorav Jain
10. Year of Construction : 1970
11. Applicant's letter No. : MHA Portal ID 2024051607684 dated 16/05/2024

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Directive at N/3 & 2005 circular Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	Required -NA- -NA-	6m -NA- -NA-	MR -NA- -NA-
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	02 Nos	Provided	MR
	• Basements	-NA-	-NA-	-NA-
	b. Width of staircases			
	• Upper Floor	1.5 m & 1.2 m	Provided	MR
	• Basements	-NA-	-NA-	-NA-
	c. Protection of exits			
	• Fire check door	-NA-	-NA-	-NA-
	• Pressurization	-NA-	-NA-	-NA-
	d. No. of continuous staircases to terrace	Required	01 No	MR
	e. Width of Corridor	-NA-	-NA-	-NA-
	f. Door Size	02 Exit	2 m & 1.25 m	MR
3.	<b>Compartmentation</b>			
	• Fire check door	-NA-	-NA-	-NA-
	• Sealing of electrical shafts	-NA-	-NA-	-NA-
	• Fire Rating of shaft door	-NA-	-NA-	-NA-
	• Water Curtain	-NA-	-NA-	-NA-
	• Fire Dampers	-NA-	-NA-	-NA-
4.	<b>Smoke Management System</b>			
	• Basements	-NA-	-NA-	-NA-
	• Upper floors	12 ACPH	Provided in kitchen	MR
5.	<b>Fire Extinguishers</b>			
	• Total numbers	8 No's	8 No's	MR
	• Types	ABC/ W. CO2/CO <sub>2</sub>	4/4/-	MR
	• IS marking	Required	Provided	MR
6.	<b>First-Aid Hose Reels</b>			
	• Total numbers on each floor	One	1 <sup>st</sup> & 2 <sup>nd</sup> floor	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7.	<b>Automatic fire detection and alarming system</b>			
	• Type of detectors	-NA-	-NA-	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-

	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	-NA-	-NA-	-NA-
8.	<b>MOEFA</b>	Required	Provided	MR
9.	<b>Public Address System</b>	-NA-	-NA-	-NA-
10.	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Ground &amp; Upper Floors</li> <li>Sprinkler above false ceiling</li> </ul>	-NA-	-NA-	-NA-
		Required	Provided	MR
		-NA-	-NA-	-NA-
11.	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	Required	100mm	MR
		One	Provided	MR
		One	Provided	MR
12.	<b>Yard Hydrants</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
13.	<b>Pumping Arrangements</b>			
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/Manual Stopping</li> </ul> </li> <li>Terrace level <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		450 & 225 LPM	Provided	MR
		40m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity <ul style="list-style-type: none"> <li>Draw-off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> </ul> </li> <li>Overhead Tank capacity</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
15.	<b>Exit Signage.</b>	5,000 Lts.	10,000 ltr	MR
16.	<b>Provision of Lifts.</b>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> <li>Pressurization of Lift lobby</li> <li>Communication In lift Car</li> <li>Fireman's Grounding Switch</li> <li>Lift Signage</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
17.	<b>Standby power supply</b>	Required	Provided	MR
18.	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>Total Area</li> <li>Location</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
19.	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>Detector System Panel</li> <li>Flow Switch Panel</li> <li>PA System Panel</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-

आजादी का अमूल्य मรด

2124

<ul style="list-style-type: none"> <li>Battery backup</li> <li>Building Floor Plans</li> </ul>	-NA-	-NA-	-NA-
	-NA-	-NA-	-NA-
<b>Special Fire Protection System for Protection of special Risks, if any:</b>			-NA-

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/EH/2021/SZ/282 dated 08/10/2021, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

*[Signature]*  
Signature of the Inspection Officer  
Name: Sh. Manoj Kumar Sharma  
Design: DO (South)

*[Signature]*  
Signature of the Inspecting Officer  
Name: Sh. Rajesh Kumar  
Design: ADO (BCP)

CFO (HQ)

*[Signature]*  
28/5/2021  
Director  
*[Signature]*  
20/5/21

*[Signature]*  
ADO/BCP

As approved, F.T. letter is put up for your signature pl

*[Signature]*  
29/5

*[Signature]*  
Director  
21/5/21  
*[Signature]*

Uploaded  
30/05/21  
*[Signature]*