



No. F6/DFS/MS/School/NDZ/2024/ 517

Dated: 07/06/2024

**FIRE SAFETY CERTIFICATE**

Certified that the Sun Rise Public School located at A-Block, Gali No. 02, Khasra No.126 , 127, Kaushalpuri, Chauhan Patti, Delhi-110090, comprised building of ground plus two upper floors only, owned/occupied Sun Rise Public School have complied with the Fire Prevention and Fire Safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 29/05/2024 in the presence of Mr. Vijay Prakash Tiwari (Manager) & Mr. Satish Dubey (Principal) and that the building /premises is fit for occupancy class "Educational Building" (Group - B) with effect from 07/06/2024 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 07/06/2024 at New Delhi by.

(ATUL GARG)  
DIRECTOR  
o/c DELHI FIRE SERVICE

**Copy to: -**

1. The Dy. Director of Education, B- Block, Yamuna Vihar, Delhi - 110053.
2. The Principal, Sun Rise Public School located at A-Block, Gali No. 02, Khasra No.126 , 127, Kaushalpuri, Chauhan Patti, Delhi-110090.

**Conditions for the validity of Fire Safety Certificate**

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

## INSPECTION REPORT

1	Name & address of the building	Sun Rise Public School located at A-Block, Gali No. 02, Khasra No.126, 127, Kaushalpuri, Chauhan Patti, Delhi-110090.		
2	Building is comprised of	Ground plus two upper floors only		
3	Type of occupancy	Educational Building		
4	Type of case	New Case		
5	Details of previous FSC	New		
6	Fire safety directives letter no.	NBC Part-IV		
7	Date of inspection	29/05/2024		
8	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)		
9	Name of the designation of officer from the building side	Mr. Vijay Prakash Tiwari (Manager) & Mr. Satish Dubey (Principal)		
10	Year of construction	2023		
11	Applicant's letter no.	Outdoor dairy no.1505 dated 08/05/2024		
S.N o	Minimum standard of fire prevention and fire safety U/R 33	NBC Part-IV Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to Building:</b>			
A	Road width	6.0 meters.	6.0 meters.	MR
B	Gate width	4.50 meters.	4.50 meters.	MR
C	Width of internal road	N/A	N/A	N/A
2	<b>Number, Width, Type and Arrangement of Exits:</b>			
A	Number of staircases			
a	Upper floor	02 no.	02 nos.	MR
b	Basement	N/A	N/A	N/A
B	Width of staircases			
a	Upper floor	1.50 meters	1.80 meters each	MR
b	Basement	N/A	N/A	N/A
C	Protection of exits			
a	Fire check door	N/A	N/A	N/A
b	Pressurization	N/A	N/A	N/A
D	No. of continuous staircases to terrace	01 no.	02 no.	MR
E	Width of corridor	1.50 meters.	1.50 meters.	MR
F	Door size class room	1.20 meters.	1.20 meters.	MR
G	Number of Door class room	02 nos.	02 nos.	MR
3	<b>Compartmentation:</b>			
A	Fire check door	N/A	N/A	N/A
B	Sealing of electrical shafts	N/A	N/A	N/A
C	Fire rating of shaft door	N/A	N/A	N/A
D	Water curtain	N/A	N/A	N/A
E	Fire dampers	N/A	N/A	N/A
4	<b>Smoke Management System:</b>			
A	Basement	N/A	N/A	N/A
B	Upper floor	N/A	N/A	N/A

Sun Rise Public School located at A-Block, Gall No. 02, Khasra No.126 , 127, Kaushalpur,  
Chauhan Patti, Delhi-110090

<b>5.</b>	<b>Fire Extinguisher:</b>			
A	Total numbers	08 nos.	12 nos.	MR
B	Types	CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC	MR
C	ISI marking	ISI Marked	ISI Marked	MR
<b>6.</b>	<b>First-Aid-Hose Reel:</b>			
A	Total numbers of each floor	01 no.	01 no.	MR
B	Length of hose reel hose	30 meters	30 meters	MR
C	Nozzle diameter	05 mm	05 mm	MR
<b>7.</b>	<b>Automatic Fire Detection and Alarming System:</b>			
A	Type of detectors	N/A	N/A	N/A
B	Location of main panel	N/A	N/A	N/A
C	Location of repeater panel	N/A	N/A	N/A
D	Alternate source of power	N/A	N/A	N/A
E	Hooters	N/A	N/A	N/A
<b>8.</b>	<b>MOEFA:</b>	N/A	N/A	N/A
<b>9.</b>	<b>Public Address System:</b>	N/A	N/A	N/A
<b>10.</b>	<b>Automatic Sprinkler System:</b>			
A	Basement	N/A	N/A	N/A
B	Upper floor	N/A	N/A	N/A
C	Sprinkler above false ceiling	N/A	N/A	N/A
<b>11.</b>	<b>Internal Hydrants:</b>			
A	Size of riser/down-comer	N/A	N/A	N/A
B	Number of hydrants per floor	N/A	N/A	N/A
C	Hose box	N/A	N/A	N/A
<b>12.</b>	<b>Yard Hydrants:</b>			
A	Total number of hydrants	N/A	N/A	N/A
B	Hose box	N/A	N/A	N/A
<b>13.</b>	<b>Pumping Arrangements:</b>			
<b>1</b>	<b>Ground level</b>			
A	Discharge of main pump	N/A	N/A	N/A
B	Head of main pump	N/A	N/A	N/A
C	Number of main pumps	N/A	N/A	N/A
D	Jockey pump out put	N/A	N/A	N/A
E	Jockey pump head	N/A	N/A	N/A
F	Standby pump out put	N/A	N/A	N/A
G	Standby pump head	N/A	N/A	N/A
H	Auto starting /manual stopping	N/A	N/A	N/A
I	Pump house access	N/A	N/A	N/A
<b>2</b>	<b>Terrace Level</b>			
A	Discharge of pump	450 LPM	450 LPM	MR
B	Head of the pump	40 meters.	40 meters.	MR
C	Power supply	Required	Required	MR
D	Auto starting of pump	Required	Required	MR

Sun Rise Public School located at A-Block, Gall No. 02, Khasra No.126 , 127, Kaushalpuri, Chauhan Patti, Delhi-110090.

<b>14 Captive Water Storage for Fire Fighting:</b>				
A	Underground tank capacity	N/A	N/A	N/A
B	Draw-off connection	N/A	N/A	N/A
C	Fire service inlet	N/A	N/A	N/A
D	Access to tank	Required	Provided	MR
E	Overhead tank capacity	10,000 liters	10,000 liters	MR
<b>15 Exit Signage:</b>		Required	provided	MR
<b>16 Provision of Lifts:</b>				
A	Pressurization of lift shaft	N/A	N/A	N/A
B	Pressurization of lift lobby	N/A	N/A	N/A
C	Communication in lift car	N/A	N/A	N/A
D	Firemen's grounding switch	N/A	N/A	N/A
E	Lift signage	N/A	N/A	N/A
<b>17 Standby Power Supply:</b>		N/A	N/A	N/A
<b>18 Refuge Area:</b>				
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
<b>19 Fire Control Room:</b>				
A	Detector system panel	N/A	N/A	N/A
B	Flow switch panel	N/A	N/A	N/A
C	PA system panel	N/A	N/A	N/A
D	Battery backup	N/A	N/A	N/A
E	Building floor plans	N/A	N/A	N/A
<b>20 Special Fire Protection systems for protection of special Risks, if any:</b>		N/A	N/A	N/A

The fire protection system was randomly checked and tested and was found functional at the time of inspection.


Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the Rules, it is recommended to grant Fire Safety Certificate under Rules 37 of Delhi Fire Service Rules 2010.  
No file is pending with me before disposal of this case.


  
31/5/2024

Signature of the Inspecting Officer  
Name Yashwant Singh Meena  
Designation ADO (L.N)

DY. CFO/NDZ

  
C.F/O.  
03/06/24

  
4/6/2024

  
06/06/24



Sir,  
A.I. letter is setup for sign. Please  
Director

  
5/6/2024