



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/EH/2024/SZ/168

Dated: 31/05/2024

**FIRE SAFETY CERTIFICATE**

Certified that **The Golden Dragon Restaurant** (A unit of Universal Foods Pvt. Ltd) at 1<sup>st</sup> Floor, DDA Market, Panchsheel Park, New Delhi-110016, running at First Floor of the building comprised of Ground plus one upper floor, was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/EH/SZ/2021/231 dated 14/09/2021. The said premise was re-inspected by the officer concerned of this department on 27/05/2024 in the presence of Mr. Pawan Sachdeva (Manager) and observed that said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the said premise is fit for occupancy class "**Assembly Group D**" (Restaurant) with effect from the date of issuance upto **31/03/2027** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 31/05/2024 at New Delhi by

  
(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to: -

1. The Joint Commissioner of Police, Licensing Branch, First Floor, Police Station Defence Colony, New Delhi-110049 (w.r.t. MHA ID No. **2024050707035** dated **09/05/2024**)
2. Mr. Pawan Verma M/s The Golden Dragon (A unit of Universal Foods Pvt. Ltd) at First Floor, DDA Market, Panchsheel Park, New Delhi-110016

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire-fighting system.
4. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N-16

## INSPECTION REPORT

1.	Name & address of the building	The Golden Dragon Restaurant (A unit of Universal Foods Pvt. Ltd) at 1 <sup>st</sup> Floor, DDA Market, Panchsheel Park, New Delhi-110016		
2.	Type of Occupancy	Assembly Group 'D'		
3.	Building Comprised of	Ground plus one upper floor only but the Restaurant is running at First Floor only		
4.	Type of Case	Renewal		
5.	Details of previous NOC	F.6/DFS/MS/EH/SZ/2021/231 Dt. 14/09/2021		
6.	Fire Safety directives letter No,	Nil		
7.	Date of inspection	27/05/2024		
8.	Name of Inspecting Officer	Santosh Kumar (ADO/SJ)		
9.	Name and designation of Officer from building side	Mr. Pawan Sachdeva (Manager)		
10.	Year of Construction	2006		
11.	Applicant letter No.	Online MHA ID No. 2024050707035 dated 09/05/2024		
S. No	Minimum standards on fire prevention and fire safety U/R 33	Old FSC Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Required	9 mtr	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	Required	1 + 1 ramp	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	Required	0.72m & 1.25m ramp	MR (Old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	2 Exits	1.15m & 1.20m	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Managements System			
	• Basements	NA	NA	NA
	• Upper floors/Restt. Area	Required	Exhaust fan provided	MR
5.	Fire Extinguishers			
	• Total numbers	04 No's	Provided	MR
	• Types	ABC / CO <sub>2</sub>	ABC & CO <sub>2</sub>	MR
	• ISI marking	Required	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	One	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR

9/27

w

N-17

7.	Automatic fire detection and alarming system			
	• Type of detector	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9	Public Address System	NA	NA	NA
10	Automatic Sprinkler System			
	• Basement	NA	NA	NA
	• Upper Floors/Restt. Area	Required	Provided in Restt.	MR
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down- comer	Required	100 mm	MR
	• Number of hydrants per floor	Required	One	MR
	• Hose Box	Required	One	MR
12	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 & 180 LPM	Provided	MR
	➤ Head of the pump	40m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14	Captive water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	2,500 Ltrs	5,000 Ltrs	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA

SA

3

N-18

19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any	NA	NA	NA

The fire protection systems provided in the building/premises were checked, tested at random and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the fire safety certificate issued vide letter No. F.6/DFS/MS/EH/SZ/2021/231 dated 14/09/2021, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

*S. Kumar*  
29/05/24

Signature of the Inspecting Officer  
Name: Santosh Kumar  
Designation: ADO (SJ)

DO (SD)

*msl*  
29/5/24

*CPD*  
28/5/2024

*Director*  
~~29/5/24~~

*ADY/SJ*

Sir, A.T. letter is put up for your sig. pl.

*Director*  
~~29/5/24~~

*S. Kumar*  
29/05/24

*Uploaded*  
31/05/24

*Q*