




No. F6/DFS/MS/School/NDZ/2024/ 488

Dated: 03/06/2024

FIRE SAFETY CERTIFICATE

Certified that the **Vijay Jyoti Co-Edu. Middle School** located at **New Usman Pur, Vijay Colony, Delhi - 110053**, comprised of **ground plus one upper floor** owned/occupied by **Vijay Jyoti Co-Edu. Middle School**, was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/2010/963 dated 30/03/2010. The School building was re-inspected by the officer concerned of this department on 27/05/2024 in presence of Mrs. Dinesh Rani (Manager) and found that school have deemed complied with the fire prevention and fire safety requirements in accordance with Circular letter No. 262-362 dated 17/01/2005 issued by Director of Education and the building premises is fit for occupancy of class **Group B "Educational Building"** with effect from 03/06/2024 for a period of **three years**, in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on 03/06/2024 at New Delhi by.


(ATUL GARG)
DIRECTOR
o/c DELHI FIRE SERVICE

Copy to:-

1. The Dy. Director of Education, B - Block, Yamuna Vihar, Delhi-110053.
2. The Principal, Vijay Jyoti Co-Edu. Middle School located at New Usman Pur, Vijay Colony, Delhi - 110053.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

N/S

INSPECTION REPORT				
1	Name & address of the building		Vijay Jyoti Co-Edu. Middle School located at New Usman Pur, Vijay Colony, Delhi - 110053.	
2	Building is comprised of		Ground plus one upper floor	
3	Type of occupancy		Educational Building	
4	Type of case		Renewal	
5	Details of previous FSC		F6/DFS/MS/2010/963 dated 30/03/20210.	
6	Fire safety directives letter no.		Circular Letter No.262-362 dated 17/01/2005	
7	Date of inspection		27/05/2024	
8	Name of the inspecting officers		Yashwant Singh Meena ADO (L.N)	
9	Name of the designation of officer from the building side		Mrs. Dinesh Rani (Manager)	
10	Year of construction		1999	
11	Applicant's letter no.		Email dated 24/05/2024	
S.No	Minimum standard of fire prevention and fire safety U/R 33	Circular Requirement	Provided at site	Remarks MR/NMR
1	Access to Building:			
	A	Road width	6.0 mtrs.	6.0 mtrs. MR
	B	Gate width	N/A	N/A
	C	Width of internal road	N/A	N/A
2	Number, Width, Type and Arrangement of Exits:			
	A	Number of staircases		
		a	Upper floor	01 nos. 02 nos. MR
		b	Basement	N/A N/A N/A
	B	Width of staircases		
		a	Upper floor	1.50 mtrs 1.44 mtrs & 0.70 mtrs MR (old case)
		b	Basement	N/A N/A N/A
	C	Protection of exits		
		a	Fire check door	N/A N/A N/A
		b	Pressurization	N/A N/A N/A
	D	No. of continuous staircases to terrace		01 no. 01 no. MR
	E	Width of corridor		1.50 mtrs. 1.50 mtrs MR
	F	Door size		1.0 mtr. 1.0 mtr MR
3	Compartmentation:			
	A	Fire check door		N/A N/A N/A
	B	Sealing of electrical shafts		N/A N/A N/A
	C	Fire rating of shaft door		N/A N/A N/A
	D	Water curtain		N/A N/A N/A
	E	Fire dampers		N/A N/A N/A
4	Smoke Management System:			
	A	Basement		N/A N/A N/A
	B	Upper floor		N/A N/A N/A

(W)

5	Fire Extinguisher:				
	A	Total numbers	10 nos.	12 nos.	MR
	B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
	C	ISI marking	ISI marked	ISI marked	MR
6	First-Aid-Hose Reel:				
	A	Total numbers of each floor	01 no	01 no	MR
	B	Length of hose reel hose	30 mtr	30 mtr	MR
	C	Nozzle diameter	05 mm	05 mm	MR
7	Automatic Fire Detection and Alarming System:				
	A	Type of detectors	N/A	N/A	N/A
	B	Location of main panel	N/A	N/A	N/A
	C	Location of repeater panel	N/A	N/A	N/A
	D	Alternate source of power	N/A	N/A	N/A
	E	Hooters	N/A	N/A	N/A
8	MOEFA:		N/A	N/A	N/A
9	Public Address System:		N/A	N/A	N/A
10	Automatic Sprinkler System:				
	A	Basement	N/A	N/A	N/A
	B	Upper floor	N/A	N/A	N/A
	C	Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants:				
	A	Size of riser/down-comer	N/A	N/A	N/A
	B	Number of hydrants per floor	N/A	N/A	N/A
	C	Hose box	N/A	N/A	N/A
12	Yard Hydrants:				
	A	Total number of hydrants	N/A	N/A	N/A
	B	Hose box	N/A	N/A	N/A
13	Pumping Arrangements:				
1	Ground level				
	A	Discharge of main pump	N/A	N/A	N/A
	B	Head of main pump	N/A	N/A	N/A
	C	Number of main pumps	N/A	N/A	N/A
	D	Jockey pump out put	N/A	N/A	N/A
	E	Jockey pump head	N/A	N/A	N/A
	F	Standby pump out put	N/A	N/A	N/A
	G	Standby pump head	N/A	N/A	N/A
	H	Auto starting /manual stopping	N/A	N/A	N/A
	I	Pump house access	N/A	N/A	N/A
2	Terrace Level				
	A	Discharge of pump	220 LPM	220 LPM	MR
	B	Head of the pump	40 m	40 m	MR
	C	Power supply	Required	Provided	MR
	D	Auto starting of pump	Required	Provided	MR

W


90 /

14	Captive Water Storage for Fire Fighting:			
A	Underground tank capacity	N/A	N/A	N/A
B	Draw-off connection	N/A	N/A	N/A
C	Fire service inlet	N/A	N/A	N/A
D	Access to tank	N/A	N/A	N/A
E	Overhead tank capacity	2500 liters	5000 liters	MR
15	Exit Signage:			
		N/A	N/A	N/A
16	Provision of Lifts:			
A	Pressurization of lift shaft	N/A	N/A	N/A
B	Pressurization of lift lobby	N/A	N/A	N/A
C	Communication in lift car	N/A	N/A	N/A
D	Firemen's grounding switch	N/A	N/A	N/A
E	Lift signage	N/A	N/A	N/A
17	Standby Power Supply:			
		N/A	N/A	N/A
18	Refuge Area:			
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
19	Fire Control Room:			
A	Detector system panel	N/A	N/A	N/A
B	Flow switch panel	N/A	N/A	N/A
C	PA system panel	N/A	N/A	N/A
D	Battery backup	N/A	N/A	N/A
E	Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:			
		N/A	N/A	N/A

The fire protection systems provided in the school building were tested, checked at random and found functional at the time of inspection.

Keeping in view of the compliance of minimum standards of fire prevention and fire safety measures required as per Circular No. 262-362 dated 17/01/2005, under the rules the FSC issued vide letter no. F6/DFS/MS/2010/963 dated 30/03/2010, renewal under Rule 35 of the Delhi Fire Service Rules 2010, is recommended to be renewed.

No file is pending with me before disposal of this case.


 Signature of the Inspecting Officer
 Name: - Yashwant Singh Meena
 Designation: - ADO (L.N)

DY.CFO (NDZ)

C.F.O.

Director

King
28/05/24

Kugh
28/05/2024

29/5/24

And/En
P.T.O