



No. F6/DFS/MS/CNG/NDZ/2024/ 369

Dated: 15/06/2024

FIRE SAFETY CERTIFICATE

Certified that the **CNG Dispensing Station** located at Loni Road, Delhi – 110032, Comprised of **ground floor only**, owned/occupied by **Indraprastha Gas Limited** was issued FSC vide letter no. F6/DFS/MS/ F6/DFS/MS/CNG/2021/NDZ/349 dated 23/07/2021. The CNG station was re-inspected by the officer concerned of this department on 07/06/2024 in the presence of Mr. Sunchit Sehrawat (Manager Fire & Safety) and found that the CNG station have deemed fit for occupancy “**CNG Filling Station**” (Group – J) for ground floor with effect from 15/06/2024 for a period of **three years**, subject to conditions, printed overleaf.

Issued on 15/06/2024 at New Delhi by.


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The General Manager (Fire & Safety), IGL Bhawan, Plot No. 04, Community Center, R.K. Puram Sector - 09, New Delhi - 110022.

Conditions for the validity of Fire Safety Certificate

1. No trade susceptible to cause to CNG by generating head, mechanical/ electrical spark should be allowed within the licensed premises.
2. Overhead electrical cable and loose/naked wiring shall not be allowed across the licensed premises. The electrical equipment, electrical gadgets and fitting in the premises shall conform to hazardous area classification for the at purpose and be of a type approved by the CCE.
3. In premises “NO Smoking” signs board both Hindi and English shall be displayed in such a manner as to be easily readable by all people.
4. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
5. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
6. Noting contravention of the explosive Act. 1884 and rules their under 1983, and static mobile pressure vessels (Unfired) Rules 1981 as modified from time to time.
7. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. May be got verified from the concerned authorities..
8. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction/ unauthorized use of land if any.
9. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
10. The owner/occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [Sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

1. Name & address of the building : CNG Filling Station at Loni Road
Delhi by IGL
2. Building is comprised of : Ground floor
3. Type of Occupancy : CNG Storage & Dispensing Unit
4. Type of Case : Renewal
5. Details of Previous NOC letter : F6/DFS/MS/2018/1321 dt-05/06/2018
6. Fire Safety directive letter No. : OISD-179
7. Date of Inspection : 19/06/2021
8. Name of the Inspecting officers : ADO Mehmood
9. Name and designation of Officer from the building side : Mr. Kaustubh Panwar (Area Manager)
10. Year of Construction : 2003
11. Applicant's Letter No. : E-mail Dt. 07/06/2021

S.No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	As per Directives	Provided at Site	Remarks MR/NMR
01	Access to Building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	12 mtr. 4.5 mtr. N/A	15 mtr. 06 mtr. N/A	MR MR N/A
02	Number, width, Type and Arrangement of Exits			
	<ul style="list-style-type: none"> • Number of staircases • Width of staircases 	N/A N/A	N/A N/A	N/A N/A
03	Compartmentation	Required	Provided	MR
04	Smoke Management System.	Required	Provided	MR
05	Fire extinguishers			
	<ul style="list-style-type: none"> • DCP type 10 kg. • DCP type 75 kg. • CO2 type 4.5 kg • IS marking 	08 nos. 01 nos. 04 nos. ISI marked	08 nos. 01 nos. 04 nos. ISI marked	MR MR MR MR
06	First-Aid-Hose Reels			
	Total numbers on each floor	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Length of hose reels hose • Nozzle diameter 	N/A N/A	N/A N/A	N/A N/A
07	Automatic Fire Detection and Alarming System.			
	<ul style="list-style-type: none"> • Type of detectors • Location of main panel • Alternate source of power • Hooper's location 	Gas Required Required Required	Provided Provided Provided Provided	MR MR MR MR
08	MOEFA	N/A	N/A	N/A
09	Public Address System	N/A	N/A	N/A
10	Automatic Sprinkler System	N/A	N/A	N/A
11	Internal Hydrants	N/A	N/A	N/A
12	Yard Hydrants	N/A	N/A	N/A

13	Pumping Arrangements			
	• Terrace Level	N/A	N/A	N/A
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting.	N/A	N/A	N/A
15	Exit Signage / No Smoking Signage	Required	Provided	MR
16	Provision of Lifts.	N/A	N/A	N/A
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area	N/A	N/A	N/A
19	Fire Control Room	N/A	N/A	N/A
20	Special Fire Protection System			
	• CO2, DCP local application	Required	Provided	MR
	• Hand held explosive meter	02 nos.	Provided	MR

The fire protection system provided in the CNG station were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety as per OISD-179, It is recommended to renewal of Fire Safety Certificate.

Mehmood
22/7/21
Signature of the Inspection Officer
Name: - Mehmood
Designation- A.D.O (TP)

DY.CFO (NDZ)

Mehmood
21/7/21

ADDO(TP)

A R+ letter put up for signature

Mehmood
19/7/21

Mehmood
19/7/21

Mehmood
16/7/2021
ADDO(TP)



MSCell

M/10

INSPECTION REPORT

1	Name & address of the building	CNG Dispensing Station located at Loni Road, Delhi By IGL		
2	Building is comprised of	Ground floor		
3	Type of occupancy	CNG Storage & Dispensing Unit		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/CNG/2021/NDZ/349 dated 23/07/2021		
6	Fire safety directives letter no.	OISD-179		
7	Date of inspection	07/06/2024		
8	Name of the inspecting officers	Yashwant Singh Meena ADO/Laxmi Nagar)		
9	Name of the designation of officer from the building side	Mr. Sunchit Sehrawat (Manager Fire & Safety)		
10	Year of construction	2003		
11	Applicant's letter no.	Outdoor dairy no. 2248 dated 31/05/2024		
S.No	Minimum standard of fire prevention and fire safety U/R 33	As per Directives	Provided at site	Remarks MR/NMR
1	Access to Building:			
A	Road width	12 meters.	15 meters. ✓	MR
B	Gate width	4.5 meters.	6.0 meters. ✓	MR
C	Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits:			
A	Number of staircases	N/A	N/A	N/A
B	Width of staircases	N/A	N/A	N/A
3	Compartmentation:	Required	Provided	MR
4	Smoke Management System:	Required	Provided	MR
5.	Fire Extinguisher:			
A	DCP Type 10 kg	08 nos.	08 nos. ✓	MR
B	DCP Type 75 kg	01 no.	01 no.	MR
C	CO ₂ Type 4.50 kg	04 nos.	04 nos.	MR
D	ISI marking	ISI Marked	ISI Marked	MR
6	First-Aid-Hose Reel:			
A	Total numbers of each floor	N/A	N/A	N/A
B	Length of hose reel hose	N/A	N/A	N/A
C	Nozzle diameter	N/A	N/A	N/A
7	Automatic Fire Detection and Alarming System:			
A	Type of detectors	Gas	Provided ✓	MR
B	Location of main panel	Required	Provided ✓	MR
D	Alternate source of power	Required	Provided ✓	MR
E	Hooters	Required	Provided ✓	MR
8	MOEFA:	N/A	N/A	N/A
9	Public Address System:	N/A	N/A	N/A
10	Automatic Sprinkler System:	N/A	N/A	N/A
11	Internal Hydrants:	N/A	N/A	N/A
12	Yard Hydrants:	N/A	N/A	N/A
13	Pumping Arrangements:			
A	Terrace Level	N/A	N/A	N/A
B	Discharge of pump	N/A	N/A	N/A
C	Head of the pump	N/A	N/A	N/A
D	Power supply	N/A	N/A	N/A
E	Auto starting of pump	N/A	N/A	N/A