



No. F6/DFS/MS/CNG/NDZ/2024/ 367

Dated: 15/06/2024

FIRE SAFETY CERTIFICATE

Certified that the CNG Station at Site no. 1, Pocket- C, IFC, Gazipur on NH-24, Delhi, Comprised of ground plus one upper floor only, owned/occupied by Indraprastha Gas Limited was granted FSC by this department vide letter no. F6/DFS/MS/CNG//2021/337 dated 20/07/2021. The premises was re-inspected by the officer concerned of this department on 07/06/2024 in the presence of Mr. Sunchit Sehrawat (Manager Fire & Safety) and found that the CNG station have deemed complied with the fire prevention and fire safety requirements in accordance with the earlier directive issued vide letter no. F.5/(3A)/DFS/2005/526 dated 03/11/2005 and found that the premises is fit for occupancy class **Hazardous Group J** with effect from 15/06/2024 for period of **three years** in accordance with Rule 36 unless under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010 printed bellow.

Issued on 15/06/2024 at New Delhi by.


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to :-

1. The General Manager, M/s Indraprastha Gas Ltd. IGL Bhawan, Plot No. 04, Community Center, R.K. Puram Sector - 09, New Delhi - 110022.

Conditions for the validity of Fire Safety Certificate

1. No trade susceptible to cause to CNG by generating head, mechanical/ electrical spark should be allowed within the licensed premises.
2. Overhead electrical cable and loose/naked wiring shall not be allowed across the licensed premises. The electrical equipment, electrical gadgets and fitting in the premises shall conform to hazardous area classification for the at purpose and be of a type approved by the CCE.
3. In premises "NO Smoking" signs board both Hindi and English shall be displayed in such a manner as to be easily readable by all people.
4. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
5. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
6. Noting contravention of the explosive Act. 1884 and rules their under 1983, and static mobile pressure vessels (Unfired) Rules 1981 as modified from time to time.
7. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. May be got verified from the concerned authorities..
8. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction/ unauthorized use of land if any.
9. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
10. The owner/occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [Sub rule(1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	CNG Station at Site no. 1, Pockey- C, IFC, Gazipur on NH-24, Delhi.			
2	Building is comprised of	Ground + 01 Upper floor.			
3	Type of occupancy	Hazardous Group - J			
4	Type of case	Renewal			
5	Details of previous FSC	F6/DFS/MS/CNG//2021/337 dated 20/07/2021			
6	Fire safety directives letter no.	Nil			
7	Date of inspection	07.06.2024			
8	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)			
9	Name of the designation of officer from the building side	Mr. Sunchit Sehrawat (Manager Fire & Safety)			
10	Year of construction	2007			
11	Applicant's letter no.	Outdoor dairy no. 2249 dated 31/05/2024			
S.No	Minimum standard of fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR	
1	Access to Building:				
	A	Road width	12 meters.	30 meters.	MR
	B	Gate width	N/A	N/A	N/A
	C	Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits:				
	A	Number of staircases			
	a	Upper floor	01 no.	01 no.	MR
	b	Basement	N/A	N/A	N/A
	B	Width of staircases			
	a	Upper floor	1.25 meters.	1.25 meters	MR
	b	Basement	N/A	N/A	N/A
	C	Protection of exits			
	a	Fire check door	N/A	N/A	N/A
	b	Pressurization	N/A	N/A	N/A
	D	No. of continuous staircases to terrace	N/A	N/A	N/A
	E	Width of corridor	N/A	N/A	N/A
	F	Door size	N/A	N/A	N/A
3	Compartmentation:				
	A	Fire check door	NA	NA	NA
	B	Sealing of electrical shafts	N/A	N/A	N/A
	C	Fire rating of shaft door	N/A	N/A	N/A
	D	Water curtain	N/A	N/A	N/A
	E	Fire dampers	N/A	N/A	N/A
4	Smoke Management System:				
	A	Basement	N/A	N/A	N/A
	B	Upper floor	Required	Provided	MR

W

5.	Fire Extinguisher:				
	A	Total numbers	20 nos.	20 nos.	MR
	B	Types	DCP Type 10 kg DCP Type 75 kg CO ₂ Type 4.50 kg	DCP Type 10 kg DCP Type 75 kg CO ₂ Type 4.50 kg	MR
	C	ISI marking	ISI Marked	Provided /	MR
6	First-Aid-Hose Reel:				
	A	Total numbers of each floor	N/A	N/A	N/A
	B	Length of hose reel hose	N/A	N/A	N/A
	C	Nozzle diameter	N/A	N/A	N/A
7	Automatic Fire Detection and Alarming System:				
	A	Type of detectors	Gas	Provided	MR
	B	Location of main panel	At. Gr. floor	Provided	MR
	C	Location of repeater panel	N/A	N/A	N/A
	D	Alternate source of power	Required	Provided	MR
	E	Hooters	At. Gr. floor	Provided	MR
8	MOEFA:		N/A	N/A	N/A
9	Public Address System:		N/A	N/A	N/A
10	Automatic Sprinkler System:				
	A	Basement	N/A	N/A	N/A
	B	Upper floor	N/A	N/A	N/A
	C	Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants:				
	A	Size of riser/down-comer	N/A	N/A	N/A
	B	Number of hydrants per floor	N/A	N/A	N/A
	C	Hose box	N/A	N/A	N/A
12	Yard Hydrants:				
	A	Total number of hydrants	N/A	N/A	N/A
	B	Hose box	N/A	N/A	N/A
13	Pumping Arrangements:				
1	Ground level				
	A	Discharge of main pump	N/A	N/A	N/A
	B	Head of main pump	N/A	N/A	N/A
	C	Number of main pumps	N/A	N/A	N/A
	D	Jockey pump out put	N/A	N/A	N/A
	E	Jockey pump head	N/A	N/A	N/A
	F	Standby pump out put	N/A	N/A	N/A
	G	Standby pump head	N/A	N/A	N/A
	H	Auto starting /manual stopping	N/A	N/A	N/A
	I	Pump house access	N/A	N/A	N/A
2	Terrace Level				
	A	Discharge of pump	N/A	N/A	N/A
	B	Head of the pump	N/A	N/A	N/A
	C	Power supply	N/A	N/A	N/A
	D	Auto starting of pump	N/A	N/A	N/A

N/22

14	Captive Water Storage for Fire Fighting:			
A	Underground tank capacity	N/A	N/A	N/A
B	Draw-off connection	N/A	N/A	N/A
C	Fire service inlet	N/A	N/A	N/A
D	Access to tank	N/A	N/A	N/A
E	Overhead tank capacity	N/A	N/A	N/A
15	Exit Signage:	Required	Provided	MR
16	Provision of Lifts:			
A	Pressurization of lift shaft	N/A	N/A	N/A
B	Pressurization of lift lobby	N/A	N/A	N/A
C	Communication in lift car	N/A	N/A	N/A
D	Firemen's grounding switch	N/A	N/A	N/A
E	Lift signage	N/A	N/A	N/A
17	Standby Power Supply:	Required	Provided	MR
18	Refuge Area:			
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
19	Fire Control Room:			
A	Detector system panel	N/A	N/A	N/A
B	Flow switch panel	N/A	N/A	N/A
C	PA system panel	N/A	N/A	N/A
D	Battery backup	N/A	N/A	N/A
E	Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any: Co2, DCP local application and hand held explosive meter.	N/A	N/A	N/A

• IGL given an undertaking that 1st floor area approx 51.3 Sq. meter shall be used as storage, hence case can be considered for FSC. *Already accepted at N/19, [Signature]*
 The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules of the FSC issued vide letter no. F6/DFS/MS/CNG//2021/337 dated 20/07/2021, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended to be renewed.

No file is pending with me before disposal of this case.

[Signature]
10/6/2024

Signature Inspecting Officer
 Name: - Yashwant Singh Meena
 Designation: - ADO (Laxmi Nagar)

DY.CFONDZ

C.F.O.

[Signature]
10/06/24

[Signature]
11/6/2024
Director

Sir, F.7 letter is put up for sign. Please

[Signature]
10/6/24

[Signature]
12/6/2024