



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/EH/2024/SZ/ 178

Dated: 11 / 06 / 2024

**FIRE SAFETY CERTIFICATE**

Certified that M/s **Daryaganj** (A Unit of Matchless Restt. Pvt. Ltd), Shop No-R1, Lower Ground Floor, Worldmark-1, Aerocity, IGI Airport, New Delhi-110037, comprised of Three Basements, Ground, Mezzanine & 06 Upper Floors, but the restaurant running at lower ground floor only was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/EH/2021/SZ/308 dated 27/10/2021. The premise was re-inspected by the officer concerned of this department on 04/06/2024 in the presence of Mr. Vijay (Restt. Manager) and observed that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the said premise is fit for occupancy class "**Group-D Assembly**" for a period up to **31/03/2027** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 11/06/2024 at New Delhi by

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to: -

1. The Joint Commissioner of Police, Licensing Unit, First Floor, Police Station Defence Colony, New Delhi-110049 (w.r.t. MHA ID No. 2024052908373 dated 29/05/2024)
2. Authorized Signatory M/s **Daryaganj** (A Unit of Matchless Restt. Pvt. Ltd), Shop No-R1, Lower Ground Floor, Worldmark-1, Aerocity NH-8, IGI Airport, New Delhi-110037

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire-fighting system.
4. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
5. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

### INSPECTION REPORT

1	Name & Address of the Building	M/s <b>Daryaganj</b> (A Unit of Matchless Restt. Pvt. Ltd), Shop No-R1, Lower Ground Floor, Worldmark-1, Aerocity, IGI Airport, New Delhi-110037		
2	Type of Occupancy	Assembly 'Group-D' (Restt. at LG Floor)		
3	Building comprised of	Three Basements, Ground, Mezzanine & 06 Upper Floors.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/EH/2021/SZ/308 dt. 27/10/2021		
6	Fire Safety Directives Letter No	F.6/DFS/MS/BP/2017/Hotel/368 dated 21/02/2017 (Bldg.)		
7	Date of Inspection	04/06/2024		
8	Name of the Inspecting Officers	Santosh Kumar (ADO/SJ)		
9	Name & Designation of Officers from the building side	Mr. Vijay (Restt. Manager)		
10	Year of construction	2014		
11	Applicant letter No.	MHA ID No. <b>2024052908373</b> dated <b>29/05/2024</b>		
<b>S. No.</b>	<b>Minimum standards on Fire Prevention and Fire Safety U/R 33</b>	<b>Old FSC Requirements</b>	<b>Provided at Site</b>	<b>Remarks MR/NMR</b>
<b>1</b>	<b>Access to Building</b> FSC No <b>F.6/DFS/MS/Mixed/2024/SZ/HTL/12</b> dated <b>12/03/2024</b>			
	• Road width	Restt within Worldmark-I	As above	MR
	• Gate width	Aerocity	As above	-NA-
	• Width of internal road		As above	-NA-
<b>2</b>	<b>Number, width, type &amp; arrangement of exits</b>	Provided & Maintained by Building Mgmt.		
	<b>a. Number of Staircase</b>			
	• Upper floors	-NA-	As above	-NA-
	• Basement floor/Lower GF	02 Nos	As above	MR
	<b>b. Width of Staircase</b>	Provided & Maintained by Building Mgmt.		
	• Upper floors	N/A	As above	-NA-
	• Basement floor	2m/1.35m	As above	MR
	<b>c. Protection of exits</b>	Provided & Maintained by Building Mgmt.		
	• Fire check door	Required	As above	MR
	• Pressurization	Required	As above	MR
	<b>d. No. of continuous staircase to terrace</b>	Required	As above	MR
	<b>e. Width of corridor</b>	-NA-	-NA-	-NA-
	<b>f. Door size</b>	2m/1.35m	2m & 1.35m	MR
<b>3</b>	<b>Compartmentation.</b>	Provided & Maintained by Building Mgmt.		
	• Fire check door.	Required		MR
	• Sealing of electrical shafts.	Required	As above	MR
	• Fire rating of shaft door.	Required	As above	MR
	• Water curtain	Required	As above	MR
	• Fire dampers.	-NA-	As above	-NA-
<b>4</b>	<b>Smoke Management system.</b>	Provided & Maintained by Building Mgmt.		
	• Basement/Restt. Area	Required	Smoke venting provided	MR
	• Upper floors	-NA-	-NA-	-NA-
<b>5</b>	<b>Fire Extinguishers.</b>			
	• Total numbers	06 Nos	Provided	MR
	• Types	ABC / CO2	ABC & CO2	MR
	• ISI Marking	ISI marked	Provided	MR
<b>6</b>	<b>First Aid Hose Reels.</b>	Provided & Maintained by Building Mgmt.		
	• Total numbers on each floor.	One	As above	MR
	• Length of hose-reel hose.	30m	As above	MR
	• Nozzle Diameter	5mm	As above	MR


<b>7</b>	<b>Automatic fire detection &amp; alarming system. (Provided &amp; Maintained by Building Mgmt.)</b>			
	• Type of detectors	Required	Smoke & Heat	MR
	• Location of Main Panel	Required	Mezzanine floor	MR
	• Location of Repeater Panel	Required	FCR at GF	MR
	• Alternate source of power	Required	Provided	MR
	• Hooter's location	Required	All area	MR
<b>8</b>	<b>MOEFA</b>	Required	Provided	MR
<b>9</b>	<b>Public Address System</b>	-NA-	As above	-NA-
<b>10</b>	<b>Automatic Sprinkler System</b>	Provided & Maintained by Building Mgmt.		
	• Basement/Restt. Area	Required	As above	MR
	• Upper floors	-NA-	As above	-NA-
	• Sprinkler above false ceiling	-NA-	As above	-NA-
<b>11</b>	<b>Internal Hydrants.</b>	Provided & Maintained by Building Mgmt.		
	• Size of Riser/Down-comer	-NA-	As above	-NA-
	• Number of Hydrant per floor	-NA-	As above	-NA-
	• Hose box.	-NA-	As above	-NA-
<b>12</b>	<b>Yard Hydrants.</b>	Provided & Maintained by Building Mgmt.		
	• Total number of hydrants.	-NA-	As above	-NA-
	• Hose box.	-NA-	As above	-NA-
<b>13</b>	<b>Pumping arrangements.</b>			
	• <b>Ground Level</b>	Provided & Maintained by Building Mgmt.		
	➤ Discharge of main pump.	-NA-	2280 LPM	-NA-
	➤ Head of main pump.	-NA-	105m	-NA-
	➤ Number of main pumps.	-NA-	Two	-NA-
	➤ Jockey Pump output.	-NA-	2 x 180 LPM	-NA-
	➤ Jockey Pump head.	-NA-	105m	-NA-
	➤ Standby Pump output.	-NA-	2280 LPM	-NA-
	➤ Standby Pump head.	-NA-	105m	-NA-
	➤ Auto Starting / Manual Stopping.	-NA-	Provided	-NA-
	➤ Pump House Access	-NA-	Provided	-NA-
	• <b>Terrace Level</b>	Provided & Maintained by Building Mgmt.		
	➤ Discharge of pump.	450 LPM	900 LPM	MR
	➤ Head of pump.	40 mtr	Provided	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
<b>14</b>	<b>Captive water storage for Fire Fighting. (Provided &amp; Maintained by Building Mgmt.)</b>			
	• Underground tank capacity.	-NA-	1,50,000 Ltr	-NA-
	➤ Draw-off connection.	-NA-	Provided	-NA-
	➤ Fire Service Inlet.	-NA-	Provided	-NA-
	➤ Access to tank.	-NA-	Provided	-NA-
	• Overhead tank capacity.	10,000 Ltr	20,000 Ltr	MR
<b>15</b>	<b>Exit Signage.</b>	Required	Provided	MR
<b>16</b>	<b>Provision of Lifts.</b>	Provided & Maintained by Building Mgmt.		
	• Pressurization of lift shaft.	-NA-	As above	-NA-
	• Pressurization of lift lobby.	-NA-	As above	-NA-
	• Communication in lift car.	-NA-	As above	-NA-
	• Fireman's switch.	-NA-	As above	-NA-
	• Lift signage.	-NA-	As above	-NA-
<b>17</b>	<b>Standby Power Supply</b>	Required	Provided	MR
<b>18</b>	<b>Refuge Area</b>	Provided & Maintained by Building Mgmt.		
	• Total area	-NA-	As above	-NA-
	• Location	-NA-	As above	-NA-

19	Fire Control Room.	Provided & Maintained by Building Mgmt.		
	• Detector System Panel.	-NA-	As above	-NA-
	• Flow Switch Panel.	-NA-	As above	-NA-
	• PA system Panel.	-NA-	As above	-NA-
	• Battery backup	-NA-	As above	-NA-
	• Building floor plan	-NA-	As above	-NA-
20	Special Fire Protection System for the Protection of special Risk, if any:	-NA-	As above	N/A

The fire protection systems provided in the building/premises were checked, tested at random and found functional at the time of inspection. The main building has been issued FSC by this department vide letter No. F.6/DFS/MS/Mixed/2024/SZ/HTL/12 dated 12/03/2024.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the fire safety certificate issued vide letter No. F.6/DFS/MS/EH/2021/SZ/308 dated 27/10/2021, renewal under rule 37 of Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

  
 Signature of the Inspecting Officer  
 Name: Santosh Kumar  
 Designation: ADO (SJ)

DO (SD)

*mu*  
6/6/24

*cto*  
7/6/2024

*Director*

*Any(S)*

*Str, FT/letter is put up for your sig. pl*

*Director*  
11/06/24

*Suman*  
11/06/24

*Uploaded*

*11/06/24*