



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2024/Indl./ 360

Dated: 13/06/2024

FIRE SAFETY CERTIFICATE

Certified that the **Marc Sanitation Private Limited** located at **Plot No. A-2, SMA, G.T.K. Road, Industrial Area, Jahangirpuri, Delhi-110033** comprised of **Basement, Ground & First floor** owned/occupied by **Marc Sanitation Private Limited** issued Fire Safety Certificate by this department vide this office letter no. **F6/DFS/MS/BP/95/1270 dated 21.08.1995**. The premise was inspection by the officer concerned of this department on **31.05.2024** in presence of **Sh. Arvind Aggarwal (Owner)** and observed that all the fire prevention and fire safety arrangements as provided found in good working condition, premises have deemed complied with the requirements under Rule 33 of the Delhi Fire Service Rules, 2010 and building premises is fit for occupancy class "**G-2 Industrial building**" with effect from....**13/06/2024**.. for a period of **three years**, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...**13/06/2024**... at New Delhi by


(A. K. Garg)
Director
Ph:-011-23414000

Copy to :-

1. M/s Marc Sanitation Private Limited located at Plot No. A-2, SMA, G.T.K. Road, Industrial Area, Jahangirpuri, Delhi-110033.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doit fire/FIRE/Home/Forms>.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : Marc Bathing Luxury at Plot No.A-2, SMA, G.T.K. Road, Indl. Area, Delhi-110033.
2. Type of Occupancy : Industrial Building
3. Composition of building : Basement, Ground & first floor only
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/BP/95/1270 dated: 21.08.1995
6. Fire Safety directives letter No : Nil
7. Date of inspection : 31.05.2024
8. Name of the Inspecting Officers : ADO(RN)
9. Name and designation of officers from the building side : Sh. Arvind Aggarwal (Owner)
10. Year of Construction : Nil
11. Applicant's letter No. : Letter No. DTD.23/05/2024 & DFS Dairy No.8059 dated: 27.05.2024

Minimum Standards on fire prevention and fire safety U/R 33		BBI-1983 Requirements	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	6m 05m NA	10m 05m NA	MR MR NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	02 02	02 06	MR MR
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	1.20m 1.20m	1.40m & 90cm (iron) 1.40m	MR (bieng old case) MR
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	Required NA	Provided NA	MR NA
	d. No. of continuous staircases to terrace	01	01	MR
	e. Width of Corridor	1.20 m	1.20m	MR
	f. Door Size	1.20 m	1.20m	MR
3	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basements Upper floors 	Required Required	Exhuast fan Natural Ventilation	MR MR
5	Fire Extinguishers			

	<ul style="list-style-type: none"> Total numbers Types ISI marking 	20no's	20no's	MR
		ABC/CO2	ABC-16/CO2-04	MR
		ISI Marked	Provided	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor 	01	Provided	MR
	<ul style="list-style-type: none"> Length of hose reel hose 	30m	Provided	MR
	<ul style="list-style-type: none"> Nozzle diameter 	5mm	Provided	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	Smoke/ Heat	Provided	MR
	<ul style="list-style-type: none"> Location of Main Panel 	Ground floor	Provided	MR
	<ul style="list-style-type: none"> Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Alternate source of power 	Required	Provided	MR
	<ul style="list-style-type: none"> Hooters' Location 	Every floor	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement 	Required	Provided	MR
	<ul style="list-style-type: none"> Upper Floor 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	100mm	Provided	MR
	<ul style="list-style-type: none"> Number of hydrants per floor 	01	Provided	MR
	<ul style="list-style-type: none"> Hose Box 	01	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	N/A	Provided	N/A
	<ul style="list-style-type: none"> Hose Box 	N/A	Provided	N/A
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head 	2280LPM	Provided	MR
		60m	60m	MR
		01	01	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
		2280LPM (Diesel Operative)	Provided	MR
		60m	60m	MR

Q

	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the pump	40m	40m	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	1,00,000ltr	Provided	MR
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	12,500 LTR	15,000 LTR	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts. One open goods lift is provided.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A