



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2024/School/ 530

Dated: 14/06/2024

FIRE SAFETY CERTIFICATE

Certified that the **M.C Primary Co-ed School** located at **Gopal Nagar, Kewal Park, Azadpur, Delhi-110033** comprised of **Ground floor only** owned/occupied by **M.C Primary Co-ed School** was granted FSC by this department vide letter **no.F6/DFS/MS/School/2021/364** Dated: **10.05.2021**. The premises was inspected by the officer concerned of this department on **06.06.2024** in presence of **Smt. Shikha Gupta (Incharge)** and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class Group B Educational with effect from **14/06/2024** for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on**14/06/2024**..... at New Delhi by

(Atul Garg)
 Director

Ph:-011-23414000

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Incharge, M.C Primary Co-ed School, Gopal Nagar, Delhi-110033.

Conditions for the validity of Fire Safety Certificate:

- 1 All the means of escape/entry/exit shall be kept free from any obstruction.
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
- 3 All the staff members must know the correct method of operation of firefighting system.
- 4 The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in./wps/wcm/connect/doit fire/FIRE/Home/Forms>.
- 5 This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
- 6 "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

M/15

INSPECTION REPORT

1. Name & address of the building : M.C Primary Co-ed School, Gopal Nagar, Delhi-110033.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Composition of building : Ground floor only
5. Details of previous NOC : F6/DFS/MS/School/2021/364 Dated: 10.05.2021
6. Fire Safety directives letter No : Director of Education Circular dated 01.03.2011
7. Date of inspection : 06.06.2024
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers from the building side : Smt. Shikha Gupta (Incharge)
10. Year of Construction : 2000
11. Applicant's letter No. : Online E-Mail ID dated: 04.06.2024

Plot Area- 490 m2 Covered Area: 342 m2 No of class rooms -06 nos. No of students---145nos.

	Minimum Standards on fire prevention and fire safety U/R 33	Director of education circular dated 01.03.2011	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06m	08m	MR
	• Gate width	4.5m	2.50m each	MR(bieng old case)
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
d. No. of continuous staircases to terrace	NA	NA	NA	
e. Width of Corridor	NA	NA	MR	
f. Door Size	1 m	1m	MR	
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	Fire Extinguishers			
	• Total numbers	02nos	02nos	MR
	• Types	ABC/Co2	ABC-02	MR

46

		ISI Marked	Provided	MR	
	<ul style="list-style-type: none"> ISI marking 				
6	First-Aid Hose Reels.				
	<ul style="list-style-type: none"> Total numbers on each floor 	NA	NA	NA	
	<ul style="list-style-type: none"> Length of hose reel hose 	NA	NA	NA	
	<ul style="list-style-type: none"> Nozzle diameter 	NA	NA	NA	
7	Automatic fire detection and alarming system.				
	<ul style="list-style-type: none"> Type of detectors 	NA	NA	NA	
	<ul style="list-style-type: none"> Location of Main Panel 	NA	NA	NA	
	<ul style="list-style-type: none"> Location of Repeater Panel 	NA	NA	NA	
	<ul style="list-style-type: none"> Alternate source of power 	NA	NA	NA	
	<ul style="list-style-type: none"> Hooters' Location 	NA	NA	NA	
8	MOEFA	NA	NA	NA	
9	Public Address System.				
10	Automatic Sprinkler System.				
	<ul style="list-style-type: none"> Basement 	NA	NA	NA	
	<ul style="list-style-type: none"> Upper Floor 	NA	NA	NA	
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	NA	NA	NA	
11	Internal Hydrants				
	<ul style="list-style-type: none"> Size of riser/down-comer 	NA	NA	NA	
	<ul style="list-style-type: none"> Number of hydrants per floor 	NA	NA	NA	
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA	
12	Yard Hydrants.				
	<ul style="list-style-type: none"> Total number of hydrants 	NA	NA	NA	
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA	
13	Pumping Arrangements.				
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access 	N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		NA	NA	NA	
		NA	NA	NA	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
	<ul style="list-style-type: none"> Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	NA	NA	NA	
		NA	NA	NA	
		NA	NA	NA	
		NA	NA	NA	
	14	Captive Water Storage for fire fighting.			
		<ul style="list-style-type: none"> Underground tank capacity 	NA	NA	NA
<ul style="list-style-type: none"> Draw-off connection 		NA	NA	NA	
<ul style="list-style-type: none"> Fire service inlet 		NA	NA	NA	
<ul style="list-style-type: none"> Access to tank 		NA	NA	NA	

N/17

	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage.	NA	NA	NA
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011, it is recommended to renewal of fire safety certificate issued vide this department letter of even no. F6/DFS/MS/School/2021/364 Dated: 10.05.2021.

8/sycto/wz
D- 6/6/2024

Dy. Chief Fire Officer (WZ)

[Handwritten signatures and dates]
 6/6
 cfo
 7/6/2024
 Director
 11/06/24

Signature of the Inspecting Officer
 Name:- C.L. Meena
 Designation:- Asst. Div. Officer (RN)

[Handwritten signature]
 05/06/2024

[Handwritten signature]
 AM/RN

cont... PT