

c/26

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE

[Refer sub - rule (1) of rule 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/SZ/2024/C.C. | 27

Dated: 13 /06/2024

FIRE SAFETY CERTIFICATE

Certified that the building of Coaching center Located at, 1st & 2nd floor Plot No. 49, Sector-12B, Dwarka, New Delhi – 110075. in the building comprised of Basement (Storage) Ground (Bank/shops) first Floor (Coaching centre Office) Second floor (class room) & 3rd floor (Hall) have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and verified by the team of officers concerned of this department on 29/05/2024 & 12/06/2024 in the presence of Mr. Naurang Singh (Owner) and found that the said building is fit for occupancy class “**Educational Coaching Centre**” Group B Sub Division B – 1 (For Coaching running at 1st & 2nd floors only) with effect from 13/06/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...13/06/2024... at New Delhi.


(Atul Garg)
Director
Delhi Fire Service.
o/c

Copy to:

1. The Owner/Occupier, Coaching center Located at 1st & 2nd floor Plot No. 49, Sector-12B, Dwarka, New Delhi – 110075.
2. The Executive Engineer (Bldg.) HQ, Municipal Corporation of Delhi, 9th floor, Minto Road New Delhi – 110002.

Following fire safety directives must be adhered to:-

1. All the exits passage leading to stairs shall be kept clear and free from lock & keys.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. www.dfs.delhigovt.nic.in.
8. Basement shall be used strictly as per building bye laws.
9. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

N/7

INSPECTION REPORT

1. Name & address of the building: Coaching center Located at 1st & 2nd floor Plot No. 49, Sector-12B, Dwarka, New Delhi – 110075.
2. Type of Occupancy : Educational , (Coaching centre running at 1st & 2nd floor in a building comprised of Basement + Ground +03 UFs & two rooms at terrace now sealed)
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : Nil
6. Date of inspection : 29-05-2024
7. Name of the Inspecting Officer :DO/SW & ADO (DWK)
8. Name and designation of Officer
from the building side : Mr. Naurang Singh
9. Year of Construction : 2018
10. Applicant's letter No. : Email, dated 13/05/2024

S No	Minimum standards on fire prevention and fire safety U/R 33	As per NBC	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06mtrs	Provided	MR
	• Gate width	6 mtrs	On Road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases	02 Nos.	Provided	MR
	• Upper floors	2	Provided	MR
	• Basements			
	b. Width of staircases	1.5m	Provided	MR
	• Upper floors	1.5m	Provided	MR
	• Basements			
	c. Protection of exits			
	• Fire check door	Required in basement	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Required	01 Provided	MR
	e. Width Of Corridor	1.5 m	Provided	MR
	f. Door Size	01 mtr	Provided	MR
3.	Compartmentation			
	• Fire check door	Required in basement	Provided	MR
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA

(Handwritten signature)

W/19

14.	Captive water storage for fire fighting:			
	• Underground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	15,000 L	Provided	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	DG Set	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.


Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under Rule 35 of the Delhi Fire Service Rules 2010. If approved, the FSC may be issued.



Sign of Inspecting Officer
Name: Sh. Vedpal
Designation: DO/SW



Sign of Inspecting Officer
Name: Uday vir Singh
Designation: ADO/DWK

CFO (S2) 
31/5/2024

Director 
3/13/24