

c/10

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/SZ/School/2024/ 520

Dated: 12/06/2024

FIRE SAFETY CERTIFICATE

Certified that the building of Hamilton International School, Located at Plot No. 653, Gali No – 04, Shahabad Mohamadpur , New Delhi, comprised of Ground + 01 Upper Floor owned/ occupied by **Hamilton International School** have complied with the fire prevention and fire safety requirements in accordance with DOE Circular 3298-3398 Dated 01/03/2011 and verified by the officer concerned of this department on 10/06/2024 in the presence of Mrs. Renu Sharma (Director) and found that the building is fit for occupancy class B “Educational building” with effect from 12/06/2024 for a period of three year.

Issued on 12/06/2024 at New Delhi by.

(Atul Garg)
Director
Delhi Fire Service
12/06/24

Copy to:

1. The Principal Hamilton International School, Located at Plot No 653, Gali No – 04, Shahabad Mohamadpur , New Delhi.
2. Directorate of Education Old Secretariat Delhi – 110054.

Following fire safety directives must be adhered to:-

- 1 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 2 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 3 The trained staff should be available round the clock.
- 4 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 5 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 6 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form ‘J’ [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. www.dfs.delhigovt.nic.in.
- 7 Basement shall be used strictly as per building bye laws.
- 8 The owner/occupier shall submit a declaration every year in the form ‘K’ provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: Hamilton International School, Located at Plot No 653, Gali No – 04, Shahabad Mohamadpur, New Delhi.
2. Type of Occupancy : Educational Ground + 1 Upper Floor
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives L. No. : DOE Circular 3298 -3398 Dated 01/03/2011
6. Date of inspection : 10/06/2024
7. Name of the Inspecting Officer : Udai vir Singh ADO (DWK)
8. Name and designation of Officer from the building side : Ms. Renu Sharma (Director)
9. Year of Construction : 2010
10. Applicant's letter No. : Nil dated 12-12-2022

Total Area = 16029 sqm.
Covered Area = 3282 sqft
Class rooms = 11
No. of students = 220

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE Circular no-01/03/2011	Provided at site	Remarks MR/NMR									
1.	Access of building			MR									
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td>Accessible</td> <td>Accessible (06 mtr)</td> <td></td> </tr> <tr> <td>6 mtr</td> <td>Directly accessible from road</td> <td>MR</td> </tr> <tr> <td>NA</td> <td>NA</td> <td>NA</td> </tr> </table>	Accessible	Accessible (06 mtr)		6 mtr	Directly accessible from road	MR	NA	NA	NA		
Accessible	Accessible (06 mtr)												
6 mtr	Directly accessible from road	MR											
NA	NA	NA											
2.	Number, width, Type & Arrangements of exits												
	a. Number of staircases			MR									
	<ul style="list-style-type: none"> • Upper floors • Basements 	02 Nos.	02 Nos.	NA									
	b. Width of staircases												
	<ul style="list-style-type: none"> • Upper floors • Basements 	1.5 mtr & 0.75 mtr	1.5m & 1m	MR									
	c. Protection of exits												
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	NA	NA	NA									
	d. No of continuous staircase to terrace												
	<ul style="list-style-type: none"> • Width Of Corridor 	01	Provided	MR									
	f. Door Size												
		1 mtr	01 mtr	MR									
3.	Compartmentation												
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA	NA	NA									
		NA	NA	NA									
		NA	NA	NA									
		NA	NA	NA									
		NA	NA	NA									




4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural Ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	02 nos. each floor	04 Nos.	MR
	• Types	ABC & CO ₂	ABC	MR
	• IS marking	ISI marked	ISI marked	MR
6.	First - Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	> Head of main pump	NA	NA	NA
	> Number of main pumps	NA	NA	NA




	<ul style="list-style-type: none"> ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	<ul style="list-style-type: none"> ➤ Total area ➤ Location 	NA	NA	NA
		NA	NA	NA
19.	Fire control room			
	<ul style="list-style-type: none"> ➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Battery backup 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA


