



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75  
अजादी का  
अमृत महोत्सव

No. F6/DFS/MS/WZ/School/2024/WZ/552

Dated:- 19/06/2024

**FIRE SAFETY CERTIFICATE**

Certified that the **Bhatnagar International Summit** Located at **A-1, Paschim Vihar, Delhi- 110063**, comprised of **Basement + Ground + 01 Upper Floor**, was issued Fire Safety Certificate by this department vide letter no. **F6/DFS/MS/School/2011/808 dated 05/05/2011**. The said premise was re-inspected by the officer concerned of this department on 11/06/2024 in the presence of Sh. Sanju Kumar (Caretaker) and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises/building is fit for occupancy class **"Educational Building" Group B**" with effect from 19/06/2024 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010 printed below.

Issued on 19/06/2024 at New Delhi by

(Atul Garg)  
Director

Tel No. 011-23414000

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054.
2. The Principal, Bhatnagar International Summit Located at A-1, Paschim Vihar, Delhi- 110063.

**Following fire safety directives must be adhered to:-**

1. Management has been submitted an undertaking basement is used only extracurricular activities and dance class and temporary rooms on the terrace are not used for school purpose. If used for any school purposes the FSC should be treated as null and void.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
6. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
7. All comments / directions of licensing Department shall always be permitted and followed.
8. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
9. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

## INSPECTION REPORT

1. Name and address of the building: **Bhatnagar Internation Summit** Located at A-1 , Paschim Vihar, Delhi-110063
2. Type of Occupancy : Educational, Basement + Ground + 01 Upper Floor & (some tin shed rooms on terrace).
3. Type of Case : Renewal
4. Details of previous NOC : **F6/DFS/MS/School/2011/808 dated 05/05/2011**
5. Fire Safety directives Letter No. : /NBC Part-IV
6. Date of inspection : 11/06/2024
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer  
from the building side : Sh. Sanju Kumar (Caretaker)
9. Year of Construction : 1992
10. Applicant's letter No. : BS13/24-25 dated 03.05.2024

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Part-IV Requirements/as per FSC dated 05/05/2011	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02	01 & 01 (Iron made)	MR
	• Basements	02	02	MR
	b. Width of staircases			
	• Upper floors	1.5 m	1).1.40& 2).1.5m(Iron staircase)	MR (Old case)
	• Basements	1.5 m	1.40 m each	MR (Old Case)
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	01	01	MR
	e. Width Of Corridor	1.5 m	1.4 m	MR (Old Case)
	f. Door Size	1. m	1. m	MR )
3.	Compartmentation		NA	
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	Required	Exhaust Fans Provided	MR
	• Upper floors	NA	NA	NA

2119

5.	Fire Extinguishers				MR
	• Total numbers	6 nos.	8 nos.		MR
	• Types	ABC & CO <sub>2</sub>	Provided		MR
	• IS marking	ISI marked	Provided		
6.	First – Aid Hose Reels				MR
	• Total numbers on each floor	01	Provided		MR
	• Length of hose reel hose	30 m	Provided		MR
	• Nozzle diameter	5 mm	Provided		
7.	Automatic fire detection and alarming system				NA
	• Type of detectors	NA	NA		NA
	• Location of Main Panel	NA	NA		NA
	• Location of Repeater Panel	NA	NA		NA
	• Alternate source of power	NA	NA		NA
	• Hooters' Location	NA	NA		NA
8.	MOEFA	NA	NA		MR
9.	Public Address System	Required	Provided		
10.	Automatic Sprinkler System				MR
	• Basements	Required	Provided		NA
	• Upper Floor	NA	NA		NA
	• Sprinkler above false ceiling	NA	NA		NA
11.	Internal Hydrants:				MR
	• Size of riser/down- comer	100 mm	100 mm		MR
	• Number of hydrants per floor	01	01		MR
	• Hose Box	01	01		MR
12.	Yard Hydrants				NA
	• Total number of hydrants	NA	NA		NA
	• Hose Box	NA	NA		NA
13.	Pumping Arrangements:				
	• Ground Level	NA	NA		NA
	• Discharge of main pump	NA	NA		NA
	➤ Head of main pump	NA	NA		NA
	➤ Number of main pumps	NA	NA		NA
	➤ Jockey pump out put	NA	NA		NA
	➤ Jockey pump head	NA	NA		NA
	➤ Standby Pump out put	NA	NA		NA
	➤ Standby Pump Head	NA	NA		NA
	➤ Auto Staring/Manual stopping	NA	NA		NA
	➤ Pump House Access	NA	NA		NA
	• Terrace level				
	➤ Discharge of pump	900 lpm	Provided		MR
		40 m	Provided		MR
	➤ Head of the pump	Required	Provided		MR
	➤ Power supply	Required	Provided		MR
	➤ Auto starting of pump				
14.	Captive water Storage for fire fighting:				
	• Under ground tank capacity	NA	NA		NA
	➤ Draw off connection	NA	NA		NA
	➤ Fire service inlet	NA	NA		NA
	➤ Access to tank	NA	NA		NA
	• Overhead Tank capacity	15,000 ltrs.	Provided		MR
15.	Exit Signage	Required	Provided		MR
16.	Provision of Lifts				
	➤ Pressurization of Lift Shaft	NA	NA		NA
	➤ Pressurization of lift lobby	NA	NA		NA

	<ul style="list-style-type: none"> <li>➤ Communication in lift Car</li> <li>➤ Fireman's Grounding Switch</li> <li>➤ Lift Signage</li> </ul>	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Total area</li> <li>➤ Location</li> </ul>	NA	NA	NA
19.	Fire control room	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Detector system panel</li> <li>➤ Flow Switch Panel</li> <li>➤ PA System Panel</li> <li>➤ Battery backup</li> <li>➤ Building Floor Plans</li> </ul>	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

Note:- Management has been submitted an undertaking basement is used only extracurricular activities and dance class and temporary rooms on the terrace are not used for school purpose. If used for any school purposes the FSC should be treated as null and void.

This department already issued shortcomings vide letter No. F6/DFS/MS/2019/5020 dated 20.08.2019 have been rectified.

Fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety requirements under the rules, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/2011/808 dated 05/05/2011 is recommended under Rule 37 of the Delhi Fire Service Rules, 2010 under the DFS Act 2007.

Accordingly DFA is put up for approval & signature please.

DEFO (WZ) on m/R  
PCO (EDS)  
C/PD

ADP  
12/06/24

ADP  
12/06/24  
 Aman Kumar Lathar  
 ADO (JWP)

FT PLS

13/06/2024  
~~Director~~  
~~12/06/24~~  
~~Director~~  
~~12/06/24~~

ADP/JWP  
 Sir, F.T. letter is added for your signature for

ADP  
12/06/24