

c/86

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/EH/NDZ/2024/ 182

Dated : 14/06/2024

**FIRE SAFETY CERTIFICATE**

Certified that the M/s Ludo Bar And Lounge, located at Shop No. 45, Block 80, at Ground floor, Punchkuain Road, Pahar Ganj New Delhi in a building comprised of basement, Ground plus two upper floors but Restaurant running at Ground floor only. The FSC was earlier granted by this department vide letter No. F6/DFS/MS/EH/NDZ/184 dated 21/12/20 in the name & style M/s ABCD restaurant ( a unit of 2RS). Now, the premises was inspected by officers concerned of this department on 05/06/24 in the presence of Mr. Ripu and found that the said restaurant premises has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010 and that the said restaurant premises is fit for occupancy class Assembly Building (Group D) -restaurant at ground floor only, and valid up to 31.03.2027 from the date of issue in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued .....14/06/2024.....New Delhi by.

  
(Atul Garg)  
DIRECTOR  
Delhi Fire Service

**Copy to:-**

1. The Commissioner, MCD, Civic Centre, New Delhi.
2. The Joint Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi ID No.2024052708179 dated 27.05.2024.
3. The Manager, M/s Ludo Bar And Lounge Shop No. 45, Block No 80, Ground floor, Punchkuain Road Pahar Ganj, New Delhi.

**Condition for the validity of fire safety certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. **This FSC is valid for restaurant at ground floor only**
2. Any loss of life or property due to nonfunctional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
9. Any flammable material for interior decoration is strictly prohibited.

1. Name & address of the building M/s Ludo Bar And Lounge Shop  
No. 45, Block-80, comprises of B+GF+2  
upper floor Punchkuian Road, Pahar Ganj,  
New Delhi
2. Type of occupancy:-  
Assembly Building Group-D  
Restaurant running at ground floor only
3. Type of case:-  
New Cases
4. Details of previous FSC:-  
F6/DFS/MS/EH/NDZ/184 dated 21/12/20.
5. Fire safety directives No.-  
N/A
6. Date of inspection:-  
05/06/24.
7. Name of the inspecting officer:-  
Sh. Rajinder Atwal (DO/CD) &  
Sh. Ravinder Singh (ADO/CC)
8. Name & designation of officer  
From the building side:-  
Sh. ~~Raj Kumar Ripu~~
9. Year of construction:-  
1960
10. Applicant's letter No:-  
ID No.2024052708179 dated 27.05.2024.

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirements as per UBBL-2016 & NBC part-4	Provided at site	Remarks MR/NMR
<b>1. Access to Building</b>				
	1) Road width	06 mtr.	09 mtr. /	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
<b>2. Number, Width Type &amp; Arrangement of Exits</b>				
<b>A. Number of staircases</b>				
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
<b>B. Width of staircase</b>				
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
<b>C. Protection of exits</b>				
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
<b>D. No. of continuous staircase to terrace</b>				
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	02 mtr.&1.5 mtr	02 mtr.&1.5 mtr /	MR
<b>3. Compartmentation</b>				
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
<b>4. Smoke Management System</b>				
	1) Basements	12 ACPH	N/A	N/A
	2) Upper floors	12 a/c per hour	Natural	MR
<b>5. Fire Extinguishers</b>				
	1) Total numbers	04 Nos.	04 Nos. /	MR
	2) Types	ABC & CO2	ABC & CO2	MR

	3) ISI marking	Required	Provided	MR
<b>6.</b>	<b>First-Aid Hose Reel</b>			
	1) Total number at ground floor	01	Provided	MR
	2) Length of hose reel hose	30 mtr.	Provided	MR
	3) Nozzle diameter	05 mm	Provided	MR
<b>7.</b>	<b>Automatic Fire Detection &amp; Alarming System</b>			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
<b>8.</b>	<b>MOEFA</b>	Required	Provided	MR
<b>9.</b>	<b>Public Address System</b>	N/A	N/A	N/A
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	Provided	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
<b>11.</b>	<b>Internal Hydrants</b>			
	1) Size of riser/down-comer	100mm	Provided	MR
	2) Number of hydrants per floor	01	Provided	MR
	3) Hose box	01	Provided	MR
<b>12.</b>	<b>Yard Hydrants</b>			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
<b>13.</b>	<b>Pumping Arrangement</b>			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	Provided	MR
	b) Head of pump	40 mtr.	Provided	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
<b>14.</b>	<b>Captive Water Storage for Fire Fighting</b>			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A

N/18

	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	20,000 ltr.	Provided ✓	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	Provided	MR
17	Stand by Power Supply	Required	Provided	MR
18	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20	Special Fire Protection System for Protection of special Risk, if any:.			N/A

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if agreed, we may renew the FSC issued vide letter no. F6/DFS/MS/EH/NDZ/184 dated 21/12/20, under rule 35(6) of the Delhi Fire Service Rules 2010. Accordingly, DFA is put up for kind perusal and signature please.

Signature of the Inspecting Officer

*Rajinder Atwal*  
7/6/24

Name:- Rajinder Atwal  
Designation:-DO(CD)

Signature of the Inspecting Officer

*Sh. Ravinder Singh*  
7/6/24

Name:- Sh. Ravinder Singh  
Designation:- ADO (CC)

*Dy. C.F.O. (over)*  
*Rajinder*  
10/06/24

*C.F.O. Singh*  
11/6/24

*Director*  
11/06/24

As per order, DFA put up for kind perusal

*Director*  
11/06/24

*Sh. Ravinder Singh*  
13/6/24