



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**



094

No. F6/DFS/MS/School/WZ/2024/ 553

Dated:- 19/06/2024

**FIRE SAFETY CERTIFICATE**

Certified that the Margshree School located at Najafgarh Road, Nangloi, New Delhi-110041, having two blocks, first block is comprised of **Ground plus Two Upper Floors and second block is comprised of Ground Floor only**, was granted fire safety certificate vide letter No. F.6/DFS/MS/School/2021/WZ/373 dated 10.05.2021. The school building was re-inspected by officer concern of this department on 13.06.2024 in the presence of Sh. Prakash, Caretaker, and found that said school building have deemed complied with the fire prevention and fire safety requirements in accordance with **D.O.E Circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01.03.2011** and that the building/premises is fit for occupancy class **“Educational Building” Group- B** with effect from 19/06/2024 for a period of **three years**, subject to compliance of the conditions, mentioned below.

Issued on 19/06/2024 at New Delhi by.


  
(Atul Garg)  
Director  
Tel No. 011-23414000

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054
2. The Principal, Margshree School, Najafgarh Road, Nangloi, New Delhi-110041.

**Following fire safety directives must be adhered to:-**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

  
18/06/24

**INSPECTION REPORT**

1. Name & address of the building : Margshree School located at H-243, Kunwar Singh Nagar, Nangloi, New Delhi- 110041.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2021/WZ/373 dated 10/05/2021
5. Fire Safety directives letter No : Directorate of Education Cir. No. F6/Estate/CC/Fire/Safety/2011/3298-3398 dt. 01.03.2011
6. Date of inspection : 13.06.2024
7. Name of the Inspecting Officers : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of officers  
from the building side : Sh. Prakash, Caretaker
9. Year of Construction : 2006
10. Applicant's letter No. : MS/FSC/2024 dated 04.06.2024

Margshree School is having two blocks, first block is comprised of ground plus two upper floors and second floor is comprised of ground floor only.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per DoE cir. dt. 01.03.2011	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	06 mts	Provided	MR
	• Gate width	4.5 mts	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	-----	-----	-----
	• Upper Floors	02	02	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases	-----	-----	-----
	• Upper Floors	1.5 mts or less & 0.75 mt.	2 x 1.5 mts	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits	-----	-----	-----
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	01	01	MR
	g. Width of Corridor	1.5 mts	1.5 mts	MR
	h. Door Size	1.0 mt	Provided	MR
3	<b>Compartmentation.</b>			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	<b>Smoke Management System.</b>			
	• Basements	N/A	N/A	N/A
	• Upper floors	Required	Natural ventilation	MR



5 Fire Extinguishers			
<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	18 nos.	Provided	MR
	ABC, CO <sub>2</sub> type	Provided	MR
	ISI marked	Provided	MR
6 First-Aid Hose Reels.			
<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	01	Provided	MR
	30 mts	Provided	MR
	5 mm	Provided	MR
7 Automatic fire detection and alarming system			
<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	N/A	N/A	N/A
	N/A	N/A	N/A
	N/A	N/A	N/A
	N/A	N/A	N/A
	N/A	N/A	N/A
8 MOEFA	N/A	N/A	N/A
9 Public Address System.	N/A	N/A	N/A
10 Automatic Sprinkler System			
<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	N/A	N/A	N/A
	N/A	N/A	N/A
	N/A	N/A	N/A
11 Internal Hydrants			
<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	100 mm	100 mm	MR
	01	01	MR
	01	01	MR
12 Yard Hydrants.			
<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	N/A	N/A	N/A
	N/A	N/A	N/A
13 Pumping Arrangements			
<ul style="list-style-type: none"> <li>Ground Level                             <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/ Manual stopping</li> <li>Pump House Access</li> </ul> </li> <li>Terrace level                             <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>	---	----	-----
	N/A	N/A	N/A
	N/A	N/A	N/A
	N/A	N/A	N/A
	N/A	N/A	N/A
	N/A	N/A	N/A
	N/A	N/A	N/A
	N/A	N/A	N/A
	N/A	N/A	N/A
	N/A	N/A	N/A
	----	-----	-----
	450 LPM	Provided	MR
	40 mts	Provided	MR
	Required	Provided	MR
Required	Provided	MR	
14 Captive Water Storage for fire fighting			
<ul style="list-style-type: none"> <li>Underground tank capacity</li> <li>Draw-off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> <li>Overhead Tank capacity</li> </ul>	N/A	N/A	N/A
	N/A	N/A	N/A
	N/A	N/A	N/A
	Required	Provided	MR
	5000 lts	Provided	MR
15 Exit Signage.	Required	Provided	MR

Provision of Lifts.		Not Applicable		
•	Pressurization of Lift Shaft	N/A	N/A	N/A
	Pressurization of Lift lobby	N/A	N/A	N/A
	Communication In lift Car	N/A	N/A	N/A
	Fireman's Grounding Switch	N/A	N/A	N/A
	Lift Signage	N/A	N/A	N/A
17	<b>Standby power supply</b>	N/A	N/A	N/A
18	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
•	Detector System Panel	N/A	N/A	N/A
	Flow Switch Panel	N/A	N/A	N/A
	PA System Panel	N/A	N/A	N/A
	Batter backup	N/A	N/A	N/A
	Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required 02 ABC type fire extinguishers near elect. panel	Provided	MR

The fire protection systems provided in the building were randomly test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the directorate of education circular No. F6/Estate/CC/Fire/Safety/2011/3298-3398 dated 01.03.2011, Fire Safety Certificate issued vide letter No. F.6/DFS/MS/School/2021/WZ/373 dated 10.05.2021, renewal under Rule 37 of the Delhi Fire Service Rules 2010, is recommended.

Accordingly, DFA is put up for approval & signature please.

*Q11th 11*  
*14/06/24*

Signature of the Inspecting Officer  
(Aman Kumar Lathar)  
Asst. Divisional Officer (JWP)

DCFO (West Zone) *on m/r*  
DCFO (F/W)  
*K. J. J. J.*  
*14/6/24*

CFO *14/6/2024*  
Director *14/6/24*

Director *14/6/24*

*AOD/JWP*  
*Sir, F.T. letter is added for your signature pl.*  
*Q11th 11*  
*14/06/24*