

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/2024/ School/ 557

Dated: 20/06/2024

**FIRE SAFETY CERTIFICATE**

Certified that the NavShakti Vidya Mandir Girls Senior Secondary School located at Arakashan Road, Pahar Ganj New Delhi comprises of Ground + 03 Upper floor owned/occupied by Govt. Girls Ser. Sec. School. The premises was inspected by the officer concerned of this department on 10/06/24 in the presence of the Smt. Veena and found that school have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and the premises is fit for occupancy of class Group B "Educational Building" Sub-Div. B-I with effect from .....20/06/2024 for a period of three years subject to compliance of the conditions mentioned below:

Issued on .....20/06/2024... at New Delhi by.

(Atul Garg)  
DIRECTOR  
Delhi Fire Service

Copy to:-

1. Director of Education, Govt. of NCT, Delhi.
2. The Principal, NavShakti Vidya Mandir Girls Senior Secondary School.

**Conditions for the validity of fire safety certificate**

1. All the means of escape shall be kept free of all types of obstruction all the time.
2. All the fire safety arrangements provided there in shall be maintained in good working condition at all time.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. The compliance with regards to electrical installation, structural stability, set back area , occupancy and any deviation in construction etc. shall be verified from authority concerned.
5. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry.
8. Any flammable material for interior decoration shall strictly prohibited.

NIT  
**INSPECTION REPORT**

1. Name & address of the building:- NavShakti Vidya Mandir Girls Senior Secondary School, located at Arakashan Road, Pahar Ganj, New Delhi.
2. Type of occupancy:- Educational Group B-I, Gr.+03 Upper Floor
3. Type of case:- Fresh
4. Details of previous NOC:- fresh
5. Fire safety directives No.- N/A
6. Date of inspection:- 10/06/24.
7. Name of the inspecting officer:- Sh. Ravinder Singh (ADO/CC)
8. Name & designation of officer From the building side:- Smt. Veena
9. Year of construction:- 1951
10. Applicant's letter No:- letter no. NVM/2024/29 dated 29.05.24.

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement as per circular of Dir. of education 2011	Provided at site	Remarks MR/NMR
1.	<b>Access to Building</b>			
	1) Road width	06 mtr.	06 mtr.	MR
	2) Gate width	NA	NA	NA
	3) Width of internal road	NA	NA	NA
2.	<b>Number, Width Type &amp; Arrangement of Exits</b>			
	<b>A. Number of staircases</b>			
	1. Upper floors	02 ( of any width )	gr. to Ist -03 nos & Ist to IIIrd - 02 nos	MR
	2. Basements	N/A	N/A	N/A
	<b>B. Width of staircase</b>			
	1. Upper floors	.80m ,1.0 mtr	02 nos. of 1.0 mtr.& 01 of .8m	MR
	2. Basements	N/A	N/A	N/A
	<b>C. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01	01	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	N/A	N/A	N/A
3.	<b>Compartmentation</b>			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	<b>Smoke Management System</b>			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	12 ACPH	Natural	MR
5.	<b>Fire Extinguishers</b>			
	1) Total numbers	08 Nos.	08 Nos.	MR
	2) Types	ABC & CO2	ABC, CO2 & W.CO2	MR

2/8


	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	02	02	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100mm	provided	MR
	2) Number of hydrants per floor	02 nos	02 nos	MR
	3) Hose box	02 nos	provided	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	2x450 LPM /	MR
	b) Head of pump	30 mtr.	30 mtr. /	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Underground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	Required	Provided /	MR
	d) Over head tank capacity	10,000 ltr.	10,000 ltr.	MR
15.	Exit Signage.	Required	Provided	MR

16.	Provision of Lifts.			
	a) Pressurization of lift	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A


The fire protection system provided in the school building were tested, checked at random and found functional at the time of inspection. Further, additional staircase of 1.5 meter was asked in earlier shortcomings issued on dated 14.03.13, whereas 02 staircase of any width is required and same are provided as per director of education circular - 2011. Accordingly, if agreed, we may accept the same.

In view of the substantial compliance of the minimum standards of fire prevention and fire safety measures as required as per circular of Director of education-2011, if approved, we may issue the FSC to said school premises. Accordingly, DFA is prepared and put up for kind perusal and sig. please.


Signature of the Inspecting Officer


  
 Name :- Ravinder Singh  
 Designation :- ADO (CC)



  
 13/6/24  
 Dy. C.S. (no. 2)

  
 13/06/24

CFIO.  
  
 14/6/2024

  
 15/6/24

As copy sent for perusal and signature  
  
 15/6/24