

c 52

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/2024/School/WZ/ 550

Dated: 19/06/2024

**FIRE SAFETY CERTIFICATE**

Certified that the **Heera Lal Public School, Bhagya Vihar, Jain Colony, Madan Pur Dabas, Delhi-110081**, comprised of **02 Blocks, Ground & Ground + 03 upper floors** has already been issued FSC by this department vide letter No. **F.6/DFS/MS/School/WZ/2021/321** dated **13.04.2021**. The premises was re-inspected by the officer concerned of this department on **03.06.2024** in the presence of **Mr. Ramesh Chand (Manager)** and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Group B Educational** with effect from 19/06/2024 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 19/06/2024 at New Delhi by

  
(Atul Garg)  
**DIRECTOR**  
Ph; 011-23414000

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sect. Delhi - 54.
2. The Principal, Heera Lal Public School, Bhagya Vihar, Jain Colony, Madan Pur Dabas, Delhi-110081.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

[http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/) [http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)

N/14

**INSPECTION REPORT**

1. Name & address of the building	Heera Lal Public School, Bhagya Vihar, Jain Colony, Madan Puri Dabas, Delhi-110081.
2. Type of Occupancy	Educational
3. Type of Case	Renewal (Ground & Ground + 03 upper floors)
4. Details of Previous NOC	F.6/DFS/MS//School/WZ/2021/321 dated 13.04.2021.
5. Fire Safety directives letter No	NBC Part-IV.
6. Date of inspection	03.06.2024.
7. Name of Inspecting Officer	Sh. Ajay Kumar Sharma (ADO Rohini)
8. Name and designation of officers From the building side	Mr. Ramesh Chand (Manager)
9. Year of Construction	2003 & 2018
10. Applicant's letter No.	OD No.1988 dated 22.05.2024.

S. No	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>		Accessible	MR
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	4.5m	MR
	• Width of internal road	-NA-	-NA-	-NA-
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	<b>a. Number of staircases</b>			MR
	• Upper Floors	02nos.	02nos.	MR
	• Basements	-NA-	-NA-	-NA-
	<b>b. Width of staircases</b>			MR
	• Upper Floor	1.5m	1.5m & 1.07m	MR
	• Basements	-NA-	-NA-	-NA-
	<b>c. Protection of exits</b>			-NA-
	• Fire check door	-NA-	-NA-	-NA-
	• Pressurization	-NA-	-NA-	-NA-
	<b>d. No. of continuous staircases to terrace</b>	01nos.	01nos.	MR
	<b>e. Width of Corridor</b>	-NA-	-NA-	-NA-
	<b>f. Door Size</b>	1.0m	Provided	MR
3.	<b>Compartmentation</b>			-NA-
	a) Fire check door	-NA-	-NA-	-NA-
	b) Sealing of electrical shafts	-NA-	-NA-	-NA-
	c) Fire Rating of shaft door	-NA-	-NA-	-NA-
	d) Water Curtain	-NA-	-NA-	-NA-
	e) Fire Dampers	-NA-	-NA-	-NA-
4.	<b>Smoke Management System</b>			-NA-
	a) Basements	30 /c per hour	-NA-	-NA-
	b) Upper floors	12 a/c per hour	Natural ventilated	MR
5.	<b>Fire Extinguishers</b>			MR
	a) Total numbers	10nos.	12nos.	MR
	b) Types	ABC/CO2	ABC-12nos.	MR
	c) IS marking	ISI marked	Yes	MR
6.	<b>First-Aid Hose Reels</b>			MR
	a) Total numbers on each floor	03nos.	04nos.	MR
	b) Length of hose reel hose	30mm	Provided	MR
	c) Nozzle diameter	5m	Provided	MR
7.	<b>Automatic fire detection and alarming system</b>			

Ajay

	a) Type of detectors	-NA-	-NA-	-NA-
	b) Location of Main Panel	-NA-	-NA-	-NA-
	c) Location of Repeater Panel	-NA-	-NA-	-NA-
	d) Alternate source of power	-NA-	-NA-	-NA-
	e) Hooters' Location	-NA-	-NA-	-NA-
8.	<b>MOEFA</b>	-NA-	-NA-	-NA-
9.	<b>Public Address System</b>	-NA-	-NA-	-NA-
10.	<b>Automatic Sprinkler System</b>			
	a) Basement	-NA-	-NA-	-NA-
	b) Ground & Upper Floors	-NA-	-NA-	-NA-
	c) Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	<b>Internal Hydrants</b>			
	a) Size of riser/down-comer	-NA-	-NA-	-NA-
	b) Number of hydrants per floor	-NA-	-NA-	-NA-
	c) Hose Box	-NA-	-NA-	-NA-
12.	<b>Yard Hydrants</b>			
	a) Total number of hydrants	-NA-	-NA-	-NA-
	b) Hose Box	-NA-	-NA-	-NA-
13.	<b>Pumping Arrangements</b>			
	• Ground Level			
	➤ Discharge of main Pump	-NA-	-NA-	-NA-
	➤ Head of Main pump	-NA-	-NA-	-NA-
	➤ Number of main pumps	-NA-	-NA-	-NA-
	➤ Jockey Pump out put	-NA-	-NA-	-NA-
	➤ Jockey pump head	-NA-	-NA-	-NA-
	➤ Standby Pump out put	-NA-	-NA-	-NA-
	➤ Standby Pump Head	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping	-NA-	-NA-	-NA-
	➤ Pump House Access	-NA-	-NA-	-NA-
	Terrace level			
	➤ Discharge of pump	450lpm	45lpm	MR
	➤ Head of the pump	40m	40m	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	<b>Captive Water Storage for fire fighting</b>			
	• Underground tank capacity	-NA-	-NA-	-NA-
	➤ Draw-off connection	-NA-	-NA-	-NA-
	➤ Fire service inlet	-NA-	-NA-	-NA-
	➤ Access to tank	-NA-	-NA-	-NA-
	• Overhead Tank capacity	10,000ltr	10,000ltr	MR
			Provided	MR
15.	<b>Exit Signage.</b>	Required		
16.	<b>Provision of Lifts.</b>			
	a) Pressurization of Lift Shaft	-NA-	-NA-	-NA-
	b) Pressurization of Lift lobby	-NA-	-NA-	-NA-
	c) Communication In lift Car	-NA-	-NA-	-NA-
	d) Fireman's Grounding Switch	-NA-	-NA-	-NA-
	e) Lift Signage	-NA-	-NA-	-NA-
17.	<b>Standby power supply</b>	-NA-	-NA-	-NA-

By

-NA-  
-NA-  
-NA-  
-NA-

Refuge Area.

	a) Total Area			
	b) Location	-NA-	-NA-	-NA-
19.	<b>Fire Control Room</b>	-NA-	-NA-	-NA-
	a) Detector System Panel	-NA-	-NA-	-NA-
	b) Flow Switch Panel	-NA-	-NA-	-NA-
	c) PA System Panel	-NA-	-NA-	-NA-
	d) Battery backup	-NA-	-NA-	-NA-
	e) Building Floor Plans	-NA-	-NA-	-NA-
20.	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	-NA-	-NA-	-NA-

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in NBC Part-4, and removal of shortcomings issued vide letter no. 214 dated 02.05.2024, the FSC issued vide letter no. F.6/DFS/MS//School/WZ/2021/321 dated 13.04.2021, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

*[Handwritten Signature]*  
4/6/24

Signature of the Inspecting Officer  
Name           Ajay Kumar Sharma  
Designation   ADO(Rohini)

Hall is located in which floor as mentioned in undertaking. Mentioned in fsc also.

Dy. CFO (WZ)

*[Handwritten Signature]*  
6/6

~~ADO (Rohini)~~

DCFO/...1024  
Dated...6/6/2024

MP Hall is a temporary stand alone block and is not a part of fsc. Again put up for kind perusal and approval please.

*[Handwritten Signature]*  
19/6/24

Dy. CFO (WZ) - on MR

Dy. CFO / FSG