



No. F6/DFS/MS/School/NDZ/2024/ 561

Dated: 20/06/2024

FIRE SAFETY CERTIFICATE

Certified that the **Kendriya Vidyalaya** located at **A.G.C.R. Colony, Delhi - 110092**, comprised of **ground plus three upper floors**, owned / occupied by **Kendriya Vidyalaya**, was issued FSC vide letter No. F6/DFS/MS/School/2021/NDZ/651 dated 25/08/2021. The School building have complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and re-inspected by the officer concerned of this department on 12/06/2024 in presence of Mrs. Prachi Dixit (Principal) of the school and that the school building is fit for occupancy class "**Educational Building**" (**Group-B**) with effect from 20/06/2024 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 20/06/2024 at New Delhi by.

(ATUL GARG)
DIRECTOR

0/0
DELHI FIRE SERVICE

Copy to:-

1. The Principal, Kendriya Vidyalaya located at A.G.C.R. Colony, Delhi - 110092.
2. The Astt. Commissioner, Kendriya Vidyalaya Sangathan, JNU Campus, New Mehrauli Road, Delhi.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

N/10

INSPECTION REPORT

01.	Name & address of the building	Kendriya Vidyalaya located at A.G.C.R. Colony, Delhi - 110092.		
02.	Building is comprised of	Ground plus three upper floors		
03.	Type of occupancy	Educational		
04.	Type of case	Renewal		
05.	Details of previous FSC	F6/DFS/MS/School/2021/NDZ/651 dated 25/08/2021		
06.	Fire safety directives letter no.	NBC Part - IV		
07.	Date of inspection	12/06/2024		
08.	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)		
09.	Name of the designation of officer from the building side	Mrs. Prachi Dixit (Principal)		
10.	Year of construction	2004		
11.	Applicant's letter no.	Email dated 05/06/2024		
S.No	Minimum standard of fire prevention and fire safety U/R 33	NBC Part-IV Requirement	Provided at site	Remarks MR/NMR
01.	Access to Building:			
	A	Road width	6.0 mtrs.	6.0 mtrs. ✓ MR
	B	Gate width	4.5 mtrs	4.5 mtrs ✓ MR
	C	Width of internal road	N/A	N/A
02.	Number, Width, Type and Arrangement of Exits:			
	A	Number of staircases		
	a	Upper floor	02 nos.	02 nos. ✓ MR
	C	Basement	N/A	N/A
	B	Width of staircases		
	a	Upper floor	1.50 mtrs.	1.50 mtrs each ✓ MR
	C	Basement	N/A	N/A
	C	Protection of exits		
	a	Fire check door	N/A	N/A
	b	Pressurization	N/A	N/A
	D	No. of continuous staircases to terrace	02 nos.	02 nos. ✓ MR
	E	Width of corridor	1.50 mtrs.	1.50 mtrs ✓ MR
	F	Door size	1.0 mtr	1.0 mtr. ✓ MR
03.	Compartmentation:			
	A	Fire check door	N/A	N/A
	B	Sealing of electrical shafts	N/A	N/A
	C	Fire rating of shaft door	N/A	N/A
	D	Water curtain	N/A	N/A
	E	Fire dampers	N/A	N/A
04.	Smoke Management System:			
	A	Basement	N/A	N/A
	B	Upper floor	N/A	N/A

(u)

05.	Fire Extinguisher:			
	A	Total numbers	15 nos.	15 nos. / MR
	B	Types	ABC/CO ₂	ABC/CO ₂ / MR
	C	ISI marking	ISI Marked	ISI Marked / MR
06.	First-Aid-Hose Reel:			
	A	Total numbers of each floor	01 no.	01 no. / MR
	B	Length of hose reel hose	30 mtrs.	30 mtrs. / MR
	C	Nozzle diameter	05 mm	05 mm / MR
07.	Automatic Fire Detection and Alarming System:			
	A	Type of detectors	N/A	N/A / N/A
	B	Location of main panel	N/A	N/A / N/A
	C	Location of repeater panel	N/A	N/A / N/A
	D	Alternate source of power	N/A	N/A / N/A
	E	Hooters	N/A	N/A / N/A
08.	MOEFA:			N/A / N/A
09	Public Address System:			N/A / N/A
10.	Automatic Sprinkler System:			
	A	Basement	N/A	N/A / N/A
	B	Upper floor	N/A	N/A / N/A
	C	Sprinkler above false ceiling	N/A	N/A / N/A
11.	Internal Hydrants:			
	A	Size of riser/down-comer	100 mm	100 mm / MR
	B	Number of hydrants per floor	04 nos	04 nos / MR
	C	Hose box	04 nos	04 nos / MR
12.	Yard Hydrants:			
	A	Total number of hydrants	N/A	N/A / N/A
	B	Hose box	N/A	N/A / N/A
13.	Pumping Arrangements:			
1	Ground level			
	A	Discharge of main pump	N/A	N/A / N/A
	B	Head of main pump	N/A	N/A / N/A
	C	Number of main pumps	N/A	N/A / N/A
	D	Jockey pump out put	N/A	N/A / N/A
	E	Jockey pump head	N/A	N/A / N/A
	F	Standby pump out put	N/A	N/A / N/A
	G	Standby pump head	N/A	N/A / N/A
	H	Auto starting /manual stopping	N/A	N/A / N/A
	I	Pump house access	N/A	N/A / N/A
2	Terrace Level			
	A	Discharge of pump	2 X 450 LPM	2 X 450 LPM / MR
	B	Head of the pump	40 m	40 m / MR
	C	Power supply	Required	Provided / MR
	D	Auto starting of pump	Required	Provided / MR

(u)

e

N/12

Kendriya Vidyalaya located at A.G.C.R. Colony, Delhi - 110092.

14.	Captive Water Storage for Fire Fighting:			
A	Underground tank capacity	N/A	N/A	N/A
B	Draw-off connection	N/A	N/A	N/A
C	Fire service inlet	N/A	N/A	N/A
D	Access to tank	N/A	N/A	N/A
E	Overhead tank capacity	10,000 liters.	Provided ✓	MR
15.	Exit Signage:	Required	Provided	MR
16.	Provision of Lifts:			
A	Pressurization of lift shaft	N/A	N/A	N/A
B	Pressurization of lift lobby	N/A	N/A	N/A
C	Communication in lift car	N/A	N/A	N/A
D	Firemen's grounding switch	N/A	N/A	N/A
E	Lift signage	N/A	N/A	N/A
17.	Standby Power Supply:	NA	N/A	N/A
18.	Refuge Area:			
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
19.	Fire Control Room:			
A	Detector system panel	N/A	N/A	N/A
B	Flow switch panel	N/A	N/A	N/A
C	PA system panel	N/A	N/A	N/A
D	Battery backup	N/A	N/A	N/A
E	Building floor plans	N/A	N/A	N/A
20.	Special Fire Protection systems for protection of special Risks, if any:	NA	N/A	N/A

The fire protection system was randomly checked and tested and was found functional at the time of inspection.

Keeping In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules of Directorate of Education the FSC issued vide letter no. F6/DFS/MS/School/2021/NDZ/651 dated 25/08/2021, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended to be renewed.

No file is pending with me before disposal of this case.


13/6/2024

Signature of the Inspecting Officer
Name: - Yashwant Singh Meena
Designation: - ADO (L.N)

~~DY. CFO/NDZ~~

C.F.O.

~~Director~~
19/06/24

~~Ang L N~~