

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE

NEW DELHI- 110001

No. F6/DFS/MS/School/SZ/2024/ 546

Dated: 19/06/2024

FIRE SAFETY CERTIFICATE

Certified that the **Kerala Educational Society (Kerala School)**, M-Block, Vikas Puri, New Delhi-110018, Comprised of ground plus two upper floors, owned/occupied by Kerala Educational Society was issued FSC vide letter no. F.6/DFS/MS/School/SZ/2021/307 dated 05.04.2021. The school building was re- inspected by the officers concerned of this department on dated 01/04/2021 in the presence of Sh. Rajeev Gopal (Admin) and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building (except multipurpose hall) is fit for occupancy Group B '**Educational Building**' with effect from19/06/2024 for a period of three years, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on.....19/06/2024.....at New Delhi by.


(Atul Garg)
 Director
 Delhi Fire Service

Copy to:-

1. The Secretary, Kerala Educational Society (Kerala School), M-Block, Vikas Puri, New Delhi-110018.
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-54.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Multipurpose hall not in use for school activity
8. Basement shall be used as per the building bye laws.
9. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
10. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

- N/2r
1. Name & address of the building : Kerala Educational Society (Kerala School), M-Block, Vikas Puri, New Delhi-110018.
2. Building is comprised of : **Ground plus two upper floor**
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/School/SZ/2021/307 dated 05.04.2021
6. Fire Safety direction letter No : NBC 2005
7. Date of Inspection : 07.06.2024
8. Name of the Inspecting Officers: : Vedpal Chhikar, DO (SW) & R.K. YADAV, ADO (JKP)
9. Name of the designation of Officer from the building side : Sh. Rajeev Gopal (Admin)
10. Year of Construction : 2004-05
11. Applicant's letter No : Nil, dated 05.04.2024

S.No	Minimum Standards on fire prevention and fire safety requirements U/R 33	Requirements	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	06 m	06 m	MR
	Gate width	4.5 m	05 m	MR
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits			
a. Number of Staircases	Upper Floor	05 nos.	05 nos.	MR
	Basement	N.A.	N.A.	N.A.
B. Width of Staircases	Upper Floor	1.5 m	1.30 m each	MR, old accepted
	Basement	N.A.	N.A.	N.A.
c. Protection of exits	Fire check door	N.A.	N.A.	N.A.
	Pressurization	N.A.	N.A.	N.A.
e. No. of continuous staircases to terrace		02 no.	04 no.	MR
g. Width of Corridor		1.5 m	1.7 & 1.9 m	MR
h. Door Size		1 m	1.20 m	MR
3	Compartmentation.			
	Fire check door	N.A.	N.A.	N.A.
	Sealing of electrical shafts	N.A.	N.A.	N.A.
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	N.A.	N.A.	N.A.
	Upper floor	Required	Natural ventilation Provided	MR

N78

5.	Fire Extinguisher			
	Total numbers types IS marking	15 Nos.	40 Nos.	MR
		CO ₂ & ABC	CO ₂ & ABC	MR
		ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor Length of hose reel hose Nozzle diameter	02 no.	03 no.	MR
		30 m	30 m	MR
		5 mm	5 mm	MR
7	Automatic fire detection and alarming system.			
	Type of detectors Location of main panel Location of repeater panel Alternate source of power Hooters	N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
8	MOEFA	N.A.	Provided	MR
9	Public address System.	N.A.	N.A.	N.A.
10	Automatic Sprinkler System.			
	Basement upper floor sprinkler above false ceiling	N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer Number of hydrants per floor Hose Box	N.A.	100 mm	MR
		N.A.	3 no.	MR
		N.A.	3 no.	MR
12	Yard Hydrants.			
	Total number of hydrants Hose Box	N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level ➤ Discharge of main Pump ➤ Head of Main Pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby pump out put ➤ Standby pump Head ➤ Auto Starting /Manual stopping ➤ Pump House Access • Terrace Level ➤ Discharge of pump ➤ Head of the Pump ➤ Power supply ➤ Auto Starting of pump 	N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		450 LPM.	450 LPM & 180 LPM	MR
	40 M	40 M	MR	
	Required	Provided	MR	
	Required	Provided	MR	


14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity	N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		10,000 Liters	10,000 Liters	MR
15	Exit Signage.	Required	Provided	MR


N/S




16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
17	Standby power supply	N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:	N.A.	N.A.	N.A.

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety required as per rules. The FSC was issued vide letter No. F.6/DFS/MS/School/SZ/2021/307 dated 05.04.2021, renewal under the Rule 37 of the Delhi Fire Service Rules, 2010 is recommended.


 Signature of the Inspecting Officer
 Name : R.K.Yadav
 Designation :- ADO (JKP)


 Signature of the Inspecting Officer
 Name : Vedpal Chhikara
 Designation: - DO (SW)

CFO (SZ)

 11/6/2021
Director

 11/6/21
ADO (INSUR)



 12/6/21