

620

FORM 'H'
 FORM FOR ISSUING FIRE SAFETY CERTIFICATE
 [Refer sub - rule (1) of rule 35]
 GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
 HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
 NEW DELHI

No. F6/DFS/MS/SZ/2024/ 547

Dated: 19/06/2024

FIRE SAFETY CERTIFICATE

Certified that the building of M.C Primary School Located at Old Rajinder Nagar, New Delhi - 110060, comprised of Ground + 01 Upper floor was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/SZ/2019/2103 dated 01/11/19. The premise was re inspected by the officer concerned of this department on 09/06/2024 in the presence of Mr. Hansraj Meena (Teacher). All the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance with DOE 3298-3398 dated 1-3-2011 issued by the Director of Education and that the building/ premises is fit for occupancy class B "Educational" with effect from 19/06/2024. for a period of three years, subject to compliance of the condition given below.

Issued on ... 19/06/2024. at New Delhi by.


 (Atul Garg)
 Director
 Delhi Fire Service
 S/c


Copy to: -

1. The Principal, M.C Primary School Located at Old Rajinder Nagar, New Delhi - 110060.
2. Directorate of Education Old Secretariat Delhi - 110054.

Following fire safety directives must be adhered to:-

- 1) All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 2) Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 3) The trained staff should be available round the clock.
- 4) Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 5) The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 6) Basement shall be used strictly as per building bye laws.
- 7) The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. www.dfs.delhigovt.nic.in.
- 8) The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

N/11

INSPECTION REPORT

1. Name & address of the building: M.C Primary School Located at Old Rajinder Nagar, New Delhi - 110060.
2. Type of Occupancy : Educational (Ground + 01 Upper Floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/SZ/2019/2103 dated 01/11/19
5. Fire Safety directives Letter No. : DOE 3298-3398 dated 01-03-2011
6. Date of inspection : 09/06/2024
7. Name of the Inspecting Officer : ADO (DWK)
8. Name and designation of Officer
from the building side : Mr. Hansraj Meena (Teacher)
9. Year of Construction : Before 2006
10. Applicant's letter No. : Form J dated 13/05/2024

No. of Students=295
No. of class rooms=08
Total area= 2040 sqm
Covered area=620 sqm

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/06, N/07& N/08	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtr	Provided	MR
	• Gate width	Old case	3.70 mtr	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02 Nos.	02 Nos.	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 mtr if less than 1.5 mtr additional staircase of 0.75 mtr is required	1.70m & 1.30m	MR(Being old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1.0 m	1.10 m	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA

N/12

4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	12 a/c per hour	Natural ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	05 Nos.	Provided	MR
	• Types	ABC & CO ₂	ABC & CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR
6.	First - Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	Provided	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level	NA	NA	NA
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA

11/13

14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage	NA	NA	NA
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	01 ABC type fire extinguisher is provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter F6/DFS/MS/School/SZ/2019/2103 dated 01/11/19 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended. If approved, the FSC may be issued.

Signature of the Inspecting Officer
 Name Uday V K Singh
 Designation AD/DW/2

[Signature]
 13/6/24

(FO/S2) [Signature]
 Director [Signature]
 14/6/2024
 11/06/24 [Signature]