



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE NEW DELHI-110001**

No: F.6/DFS/MS/School/WZ/2024/ 568

Dated: 20/06/2024

**FIRE SAFETY CERTIFICATE**

Certified that the M. C. Primary Co - Ed School, located at Ramesh Nagar, No.02, Namdhari Colony, Kirti Nagar, New Delhi-110015, in a building comprised of ground plus two upper floors was issued FSC vide letter No. F6/DFS/MS/WZ/2020/137 dated 30/03/2020. The premises was re-inspected by the officer concerned by this department on 05/06/2024 in the presence of Smt. Sunita (Incharge) and found that the premises/building have deemed complied with fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire service Rules,2010 and found that the building / premises is fit for occupancy class "Educational" (Group -B) with effect from ...20/06/24 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010. Condition mentioned below.

Issued on ...20/06/2024 at New Delhi.

(Atul Gang)  
Director

Copy to: -

1. The Principal M/s M. C. Primary Co - Ed School, located at Ramesh Nagar, No.02, Namdhari Colony, Kirti Nagar, New Delhi-110015.
2. Director of Education, Old Secretariat, New Delhi-110054.

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

18/6/2024

## INSPECTION REPORT

1. Name & address of the building	M. C. Primary Co - Ed School Located at Ramesh Nagar, No.2, Namdhari Colony, Kirti Nagar, New Delhi-110015.
2. Type of Occupancy	Educational (Ground + 02 upper floor)
3. Type of Case	Renewal
4. Details of previous NOC	F6/DFS/MS/WZ/2020/137 dated 30/03/2020
5. Fire Safety directives letter No	DOE Circular No.- 262-362 dated 17/01/2005
6. Date of inspection	05/06/2024
7. Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8. Name and designation of officers from the building side	Smt. Sunita (Incharge)
9. Year of Construction	1997 (As per prev. inspection report dtd.- 26/02/2020)
10. Applicant's letter No.	Letter dated 10/05/2024

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Required as per Rule 35(6) of DFS Rule 2010	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	06 mts	Provided	MR
	• Gate width	Accessible	On Road	MR
	• Width of internal road	N/A	N/A	N/A
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	01	Provided	MR
	• Upper Floors	N/A	N/A	N/A
	• Basements			
	b. Width of staircases	1.50 mts	1 x 117cm & 1 x 150cm	MR (old (2021))
	• Upper Floors	N/A	N/A	N/A
	• Basements			
	c. Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	01	Provided	MR
	e. No. of continuous staircases to terrace	1.5 m	230cm Provided	MR
	f. Width of Corridor	1 mtr	110cm Provided	MR
	g. Door Size			
3	<b>Compartmentation.</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	<b>Fire Extinguishers</b>			
	• Total numbers	08 Nos.	Provided	MR
	• Types	CO <sub>2</sub> , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

8/1

N/13			
6	<b>First-Aid Hose Reels.</b>		
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	01	Provided
		30 m	Provided
		5 mm	Provided
7	<b>Automatic fire detection and alarming system.</b>		
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	NA	NA
		NA	NA
		NA	NA
		NA	NA
		NA	NA
8	<b>MOEFA</b>	NA	NA
9	<b>Public Address System.</b>	NA	NA
10	<b>Automatic Sprinkler System.</b>		
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	NA	NA
		NA	NA
		NA	NA
11	<b>Internal Hydrants</b>		
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	NA	NA
		NA	NA
		NA	NA
12	<b>Yard Hydrants.</b>		
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	NA	NA
		NA	NA
13	<b>Pumping Arrangements.</b>		
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/ Manual stopping</li> <li>Pump House Access</li> </ul> </li> <li>Terrace level <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>	NA	NA
		NA	NA
		NA	NA
		NA	NA
		NA	NA
		NA	NA
		NA	NA
		NA	NA
		NA	NA
		450 lpm	Provided
		40 MH	Provided
		Required	Provided
		Required	Provided
14	<b>Captive Water Storage for fire fighting.</b>		
	<ul style="list-style-type: none"> <li>Underground tank capacity <ul style="list-style-type: none"> <li>Draw-off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> </ul> </li> <li>Overhead Tank capacity</li> </ul>	NA	NA
		NA	NA
		NA	NA
		NA	NA
		10000 ltrs	Provided
15	<b>Exit Signage.</b>	NA	NA

16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	<b>Standby power supply</b>	NA	NA	NA
18	<b>Refuge Area.</b>			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	<b>Fire Control Room</b>			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	<b>Special Fire Protection Systems for Protection of special Risks, if any:</b>	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/WZ/2020/137 dated 30/03/2020 renewal under Rule 35 of the Delhi Fire Service Rules 2010 is recommended.

38/A00/MN  
07/6/2024

Dy CRO (L/2) on m/Rsk

Dy CRO (F/PW)

*[Signature]*  
11/6/24

CFP  
12/6/2024

Director

*[Signature]*  
12/6/24

*[Signature]*

*[Signature]*  
07/6/2024

Signature of the Inspecting Officer  
Name: - Sarabjeet Singh  
Designation: - ADO (MN)

Sir, F.T is put up for your kind personal & sig. please.

*[Signature]*  
18/6/2024