

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS, DELHI FIRE SERVICE NEW DELHI - 110001**

No.F6/DFS/MS/CNG/2024/ 378

Dated: 20.06.2024

**FIRE SAFETY CERTIFICATE**

Certified that the Raizada Motors CNG Operation, at Asaf Ali Road Delhi comprised of Ground floor only. The CNG premises was inspected by the officers concerned of this department on 06/06/24 in the presence of Sh. Kanhaiya Lal Sharma that the CNG premises is fit for occupancy class Hazardous Group J with effect from 20.06.2024...for period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010 printed below.

Issued ..20.06.2024.....at New Delhi by.

  
(Atul Garg)  
DIRECTOR  
Delhi Fire Service

Copy to:-

1. The Commissioner , MCD , Civic Centre , New Delhi.
2. The Joint Commissioner of Police , 1st floor , Police Station , Defence Colony , New Delhi
3. The GM (Fire & Safety), M/s Indraprastha Gas Ltd., IGL Bhawan, Plot No. No. 4, Community Centre, R.K. Puram, Sector-9, New Delhi.
4. Sh. Varun Malik, DMG (CNG Marketing) Raizada Motors CNG Operation, at Asaf Ali Road Delhi.

**Conditions for the validity of fire safety certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. The FSC is valid only for CNG pump house.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. Construction, use of occupancy, height of building, electric installation, set back area etc. shall be checked & verified by the concerned authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.
9. Any flammable material for interior decoration is strictly prohibited.

**INSPECTION REPORT**

1. Name & address of the building **Raizada Motors CNG Operation, Asaf Ali Road Delhi comprised of Ground floor only.**
2. Type of occupancy:- **Hazardous Group J**
3. Type of case:- **Single story building**
4. Details of previous NOC:- **fresh**
5. Fire safety directives No.- **N/A**
6. Date of inspection:- **06/06/24**
7. Name of the inspecting officer:- **Sh. Ravinder Singh (ADO/CC)  
Sh. Rajinder Atwal ( DO/CD)**
8. Name & designation of officer  
From the building side:- **Sh. Kanhaiya Lal Sharma**
9. Year of construction:- **2020**
10. Applicant's letter No:- **letter no. nil dated nil & DFS diary no. 1950 dated 21.05.2024.**

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
<b>1.</b>	<b>Access to Building</b>			
	1) Road width	06 mtr.	30 mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
<b>2.</b>	<b>Number, Width Type &amp; Arrangement of Exits</b>			
	<b>A. Number of staircases</b>			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	<b>B. Width of staircase</b>			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	<b>C. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>D. No. of continuous staircase to terrace</b>	N/A	N/A	N/A
	<b>E. Width of corridor</b>	N/A	N/A	N/A
	<b>F. Door size</b>	N/A	N/A	N/A
<b>3.</b>	<b>Compartmentation</b>			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
<b>4.</b>	<b>Smoke Management System</b>			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
<b>5.</b>	<b>Fire Extinguishers</b>			

n/s

	1) Total numbers	01 DCP trolley 50Kg, 01 water mist cum foam trolley, Co2 flooding system 45 Kg, 02nos DCP- 9 Kg, 2nos Co2 4.5 k.g	01 DCP trolley 50Kg, 01 water mist trolley, Co2 flooding system 45 Kg, 02nos DCP- 9 Kg, 2nos Co2 4.5 Kg.	MR
	2) Types	ABC, CO <sub>2</sub> , DCP flooding system, water Mist cum foam trolley	ABC, CO <sub>2</sub> , DCP flooding system, water Mist cum foam trolley	MR
	3) ISI marking	Required	Provided	MR
<b>6.</b>	<b>First-Aid Hose Reel</b>			
	1) Total number of each floor	N/A	N/A	N/A
	2) Length of hose reel hose	N/A	N/A	N/A
	3) Nozzle diameter	N/A	N/A	N/A
<b>7.</b>	<b>Automatic Fire Detection &amp; Alarming System</b>			
	1) Type of detectors	Flame & Gas	Provided in Compressor Package Area	MR
	2) Location of main panel	G.F.	Gr. Floor	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	N/A	N/A	N/A
<b>8.</b>	<b>MOEFA</b>	Required	Provided	MR
<b>9.</b>	<b>Public Address System</b>	N/A	N/A	N/A
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
<b>11.</b>	<b>Internal Hydrants</b>			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
<b>12.</b>	<b>Yard Hydrants</b>			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
<b>13.</b>	<b>Pumping Arrangement</b>			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of	N/A	N/A	N/A

14.	<b>Captive Water Storage for Fire Fighting</b>			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	N/A	N/A	N/A
15.	<b>Exit Signage</b>	N/A	N/A	N/A
16.	<b>Provision of Lifts.</b>			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	<b>Stand by Power Supply</b>	N/A	N/A	N/A
18.	<b>Refuge Area</b>	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	<b>Fire Control Room</b>	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	<b>Special Fire Protection System for Protection of special Risk, if any:</b> Provided Fire buckets filled with sand. No smoking bars displayed in Hindi & English electrical wiring in metal conduit. MCB, 02 hand held gas detector.			MR ✓

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if approved, we may issue FSC under rule 35 of the Delhi Fire Service Rules 2010. Accordingly, DFA is put up for kind perusal and signature please.

Signature of the Inspecting Officer

*[Signature]*  
12/6/24

Name :- Rajinder Atwal  
Designation :- DO (CD)

Signature of the Inspecting Officer

*[Signature]*  
12/6/24

Name :- Ravinder Singh  
Designation :- ADO (CC)

*[Signature]*  
12/6/24

*[Signature]*  
13/6/24

C.F.O.  
*[Signature]*  
13/6/24

*[Signature]*  
13/6/24

*[Signature]*

As approved FSC put up for kind perusal and signature please

*[Signature]*

*[Signature]*  
12/6/24