



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001



No F 6 / DFS / MS / 2024/ CNG/394

Dated 24/06/2024

FIRE SAFETY CERTIFICATE

Certified that the CNG Filling Station (IGL) located at Kh. No. 33//15, Village Auchandi, Main Auchandi Border- Bawana Road, Delhi- 110039 comprised of Ground floor only owned/ occupied by Indraprastha Gas Limited have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of fire service on 13/06/2024 in the presence of Sh. Ashish Bhardwaj (AE, Fire & Safety, IGL) and that the building/ premise is fit for occupancy (Hazardous) "CNG Filling Station Group 'J' with effect from 24/06/2024 for a period of three years in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on 24/06/2024..... at New Delhi by

(Anil Garg)
Director

Ph. 011-23414000

Old R

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

Copy to :-

1. Chief General Manager (Project), Indraprastha Gas Limited, IGL Bhawan, Plot no-4, Community Centre, R.K. Puram, Sec-09, New Delhi-110022.

INSPECTION REPORT

1. Name & address of the building : CNG Filling Station (IGL) located at Kh. No. 33//15, Village Auchandi, Main Auchandi Border- Bawana Road, Delhi- 110039.
2. Type of Occupancy : CNG Filling station Group 'J'
3. Building Comprised : Ground Floor only.
4. Type of Case : New Case
5. Details of previous NOC : Nil
6. Fire Safety directives letter No : F.6/DFS/MS/CNG/2020/2705 dated- 05/11/2020
7. Date of inspection : 13/06/2024
8. Name of the Inspecting Officers : ADO, R.K.Sinha
9. Name and designation of officers from the building side : Sh. Ashish Bhardwaj (AE, Fire & Safety IGL)
9. Year of Construction : 2024
10. Applicant's letter No. : IGL/CNGPRJ/NOC/30052024 dated 30.05.2024

CNG Dispenser- 03, CNG Compressor-01, CNG Cascade-01

| | Minimum Standards on fire prevention and fire safety U/R 33 | NBC Requirement | Provided at site | Remarks MR/NMR |
|--------------|---|-----------------|------------------|----------------|
| 1 | Access to building | | | |
| | • Road width | 08m | 30m | MR |
| | • Gate width | NA | NA | NA |
| | • Width of internal road | NA | NA | NA |
| 2 | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | | | |
| | • Upper Floors | NA | NA | NA |
| | • Basements | NA | NA | NA |
| | b. Width of staircases | | | |
| | • Upper Floors | NA | NA | NA |
| | • Basements | NA | NA | NA |
| | c. Protection of exits | | | |
| | • Fire check door | NA | NA | NA |
| | • Pressurization | NA | NA | NA |
| | d. No. of continuous staircases to terrace | NA | NA | NA |
| | e. Width of Corridor | NA | NA | NA |
| f. Door Size | NA | NA | NA | |
| 3 | Compartmentation. | | | |
| | • Fire check door | NA | NA | NA |

12

N-7

| | | | | |
|----|---|---|--|----------------------------------|
| | <ul style="list-style-type: none"> Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| 4 | Smoke Management System. | | | |
| | <ul style="list-style-type: none"> Basements Upper floors | NA | NA | NA |
| | | NA | NA | NA |
| 5 | Fire Extinguishers | | | |
| | <ul style="list-style-type: none"> Total numbers Types ISI marking | 12 nos ABC & Co2 Required | Provided 05 trolley- 75 kg. each, 09-DCP, 04-Co2 & (Water mist cum foam trolley-01) Provided | MR MR MR |
| 6 | First-Aid Hose Reels. | | | |
| | <ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter | NA NA NA | NA NA NA | NA NA NA |
| 7 | Automatic fire detection and alarming system. | | | |
| | <ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location | Gas & Flame detector Ground Floor NA Required in Panel Ground Floor Required | Provided Provided NA Provided Provided Provided | MR MR NA MR MR MR |
| 8 | MOEFA | NA | NA | NA |
| 9 | Public Address System. | | | |
| 10 | Automatic Sprinkler System. | | | |
| | <ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling | NA NA NA | NA NA NA | NA NA NA |
| 11 | Internal Hydrants | | | |
| | <ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box | NA NA NA | NA NA NA | NA NA NA |
| 12 | Yard Hydrants. | | | |
| | <ul style="list-style-type: none"> Total number of hydrants | NA | NA | NA |

W

| | | | | |
|----|---|----------|----------|-----|
| | • Hose Box | NA | NA | NA |
| 13 | Pumping Arrangements. | | | |
| | • Ground Level | | | |
| | ➤ Discharge of main Pump | N/A | N/A | N/A |
| | ➤ Head of Main pump | N/A | N/A | N/A |
| | ➤ Number of main pumps | N/A | N/A | N/A |
| | ➤ Jockey Pump out put | N/A | N/A | N/A |
| | ➤ Jockey pump head | N/A | N/A | N/A |
| | ➤ Standby Pump out put | N/A | N/A | N/A |
| | ➤ Standby Pump Head | N/A | N/A | N/A |
| | ➤ Auto Starting/ Manual stopping | N/A | N/A | N/A |
| | ➤ Pump House Access | N/A | N/A | N/A |
| | • Terrace level | | | |
| | ➤ Discharge of pump | | | |
| | ➤ Head of the pump | NA | NA | NA |
| | ➤ Power Supply | NA | NA | NA |
| | ➤ Auto Starting of pump | NA | NA | NA |
| | | NA | NA | NA |
| 14 | Captive Water Storage for fire fighting. | | | |
| | • Underground tank capacity | NA | NA | NA |
| | ➤ Draw-off connection | NA | NA | NA |
| | ➤ Fire service inlet | NA | NA | NA |
| | ➤ Access to tank | NA | NA | NA |
| | • Overhead Tank capacity | NA | NA | NA |
| 15 | Exit Signage. | NA | NA | NA |
| 16 | Provision of Lifts. | | | |
| | • Pressurization of Lift Shaft | N/A | N/A | N/A |
| | • Pressurization of Lift lobby | N/A | N/A | N/A |
| | • Communication In lift Car | NA | NA | NA |
| | • Fireman's Grounding Switch | NA | NA | NA |
| | • Lift Signage | NA | NA | NA |
| 17 | Standby power supply | Required | Provided | MR |
| 18 | Refuge Area. | | | |
| | ➤ Total Area | N/A | N/A | N/A |
| | ➤ Location | N/A | N/A | N/A |
| 19 | Fire Control Room | | | |
| | • Detector System Panel | N/A | N/A | N/A |

bc