

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.**

No. F.6/DFS/MS/CNG/SZ/2024/465

Dated: 26/06/2024

FIRE SAFETY CERTIFICATE

Certified that the **CNG Filling Station** at Khasra No. 54/16, Village- Dichaun Kalan, Najafgarh, South West Delhi, comprised of ground floor only, owned/occupied by **M/s Indraprastha Gas Limited**. The premises was inspected by the officer concerned of this department on 13.06.2024 in the presence of Mr. Rajesh Sharma (Manager) and found that CNG Dispensing Station have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises (**CNG Dispensing Station**) is fit for occupancy Class "J" Hazardous Building w.e.f. 26/06/2024 for a period of **three** years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on.....26/06/2024.....at New Delhi.


(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to:-

1. Sh. Santosh Bhakat, GM, CNG Projects), Indraprastha Gas Limited, IGL Bhawan, Plot No.-4, Community Centre, Sector-9, R.K.Puram, New Delhi-22.
2. The Joint C.P. (Lic.), Police Station, Defence Colony, New Delhi.

Following fire safety directives must be adhered to –

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

2/1 N/S

INSPECTION REPORT

1. Name & address of the building : CNG filling Station at Khasra No. 54/16, Village- Dichaun Kalan, Najafgarh, South West Delhi.
2. Type of Occupancy : Group "J" Hazardous (CNG Facility)
3. Building comprised of : Ground floor only.
4. Type of Case : New
5. Details of Previous NOC : Nil
6. Fire Safety directives letter No : F6/DFS/MS/BP/2019/CNG/3566 dated 14.06.2019
7. Date of inspection : 13.06.2024
8. Name of Inspecting Officer : ADO R.K.Yadav
9. Name and designation of officers
From the building side : Sh. Rajesh Sharma (Manager)
10. Year of Construction : 2018
11. Applicant's letter No. : IGL/CNGPRJ/NOC/30052024 dated 30.05.2024

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NFPA/CCOE/OISD etc. requirements	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	14 m	Provided	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	NA	NA	NA
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	10 Nos.	Provided	MR
	• Types	Required	6 Nos. DCP Type (9 kg), 3 Nos. CO2 Type 4.5 kg, 2 Nos. DCP Type (75 kg) trolley mounted	MR
	• IS marking	ISI	Provided	MR

N/S

h

N/16

6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor 	NA	NA	NA
	<ul style="list-style-type: none"> Length of hose reel hose 	NA	NA	NA
	<ul style="list-style-type: none"> Nozzle diameter 	NA	NA	NA
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Gas and flame detectors 	Required	Provided	MR
	<ul style="list-style-type: none"> Location of Main Panel 	Required	Provided	MR
	<ul style="list-style-type: none"> Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Alternate source of power 	Required	Provided	MR
	<ul style="list-style-type: none"> Hooters' Location 	Required	At station	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement 	NA	NA	NA
	<ul style="list-style-type: none"> Ground Floor 	NA	NA	NA
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	NA	NA	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	NA	NA	NA
	<ul style="list-style-type: none"> Number of hydrants per floor 	NA	NA	NA
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Discharge of main Pump 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Head of Main pump 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Number of main pumps 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Jockey Pump out put 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Jockey pump head 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Standby Pump out put 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Standby Pump Head 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Auto Starting/Manual Stopping 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Pump House Access 	NA	NA	NA
	<ul style="list-style-type: none"> Terrace level 			
	<ul style="list-style-type: none"> ➤ Discharge of pump 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Head of the pump 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Power Supply 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Auto Starting of pump 	NA	NA	NA
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Draw-off connection 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Fire service inlet 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Access to tank 	NA	NA	NA
	<ul style="list-style-type: none"> Overhead Tank capacity 	NA	NA	NA
15.	No Smoking Signage.	Required	Provided	MR

13

ND

16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	NA	Provided (DG Set)	NA
18.	Refuge Area			
	<ul style="list-style-type: none"> > Total Area > Location 	NA	NA	NA
		NA	NA	NA
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	CO ₂ flooding system in compressor	Not Provided	NMR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the above substantial compliance of the minimum standards of fire prevention and fire safety measures as required under the rules it is recommended to grant Fire Safety Certificate under Rule 35 (3) of the Delhi Fire Service Rules 2010.

Note: Sand buckets are provided in the premises & No smoking boards adequately displayed in English and Hindi.

R.K. Yadav
24/8/2024

Signature of Inspecting Officer
Name:- R.K.Yadav
Designation:- Asstt. Div. Officer (JKP)

D.O (South West)

18/6/24

CFO (S2)

19/6/2024

Director

20/6/24

Amr...