

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/Assembly/UG/2024/SZ/401

Dated: 26/06/2024

FIRE SAFETY CERTIFICATE

Certified that the **Nehru Enclave Underground Metro Station of Line -8**, comprising of Four Levels (Undercroft, Platform, Concourse, & Ground Level) owner/occupied by Delhi Metro Rail Corporation Ltd was issued Fire Safety Certificate by this department vide letter no F6/DFS/MS/Assembly.(UG)/2021/SZ/99 dated 04/02/2021. The premise was re-inspected by the officer concerned of this department on 15/06/2024 in the presence of Mr. Bhirgu Fukan (AM/Fire) and found that the said metro station building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy "**Group D-7 Assembly Building**" as above with effect from 26/06/2024 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 26/06/2024 at New Delhi by

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. Mr. Malay Saha (CGM/E&M) Delhi Metro Rail Corporation, Metro Bhawan, Fire Brigade Lane, New Delhi-110001.

Conditions for the validity of Fire Safety Certificate: -

1. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
2. All the staff members must know the correct method of operation of fire fighting system.
3. The basement shall be used strictly as per the provision of Building Bye Laws.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

INSPECTION REPORT

1	Name & Address of the Building	Nehru Enclave Underground Metro Station of Line 8		
2	Type of Occupancy	Assembly (D-7)		
3	Building Comprised of	(Undercroft, platform, Concourse & Ground level)		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/Assembly.(UG)/2021/SZ/99 dated 04/02/2021		
6	Fire Safety Directives Letter No	F.6/DFS/MS/2013/2337 dated 27/09/2013		
7	Date of Inspection	15/06/2024		
8	Name of the Inspecting Officers	DO (South) & ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Bhirgu Fukan (AM/Fire)		
10	Year of construction	2018		
11	Applicant letter No.	DMRC/O&M/Fire/NOC/L-8/2024/05/06 Dated 13/05/2024		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old FSC Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Required NA Approachable	10 mtr. 6 m About on road	MR NA MR
2	Number, width, type & arrangements of exits			
	a. Number of Staircase	N/A	N/A	N/A
	<ul style="list-style-type: none"> Upper floors Basement floor 	Undercroft to platform -2 No Platform to CC- 6 No's + 02 Escalator CC to Ground- 06 No's + 04 Escalator	Provided	MR (50% capacity of escalators is counted for evacuation in NFPA)
	b. Width of Staircase	N/A	N/A	N/A
	<ul style="list-style-type: none"> Upper floors Basement floor 	2.8 m & 1.2 m (maintenance Staircase)	1.5 m x 2 No's 4.2 m x 2 No's 3 m x 2 No's 1.25 m x 2 No's + 1 m x 2 No's 2.6 m x 01 no's 3.1 m x 4 No's , 1.25 m x 01 No's + 1 m x 3 No's	MR
	c. Protection of exits	Required	Provided	MR
	<ul style="list-style-type: none"> Fire check door Pressurization 	Required in Fireman staircase & emergency staircase	Provided	MR
	d. No. of continuous staircase to terrace	Ancillary building	Provided (1.25m)	MR
	e. Width of corridor	0.91 m	1 mtr	MR
	f. Door size	0.91 m	1 mtr	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door. Sealing of electrical shafts. Fire rating of shaft door. Water curtain Fire dampers. 	Required Required 30 minute & 3 hours N/A Required	Provided Provided Provided N/A Provided	MR MR MR N/A MR
4	Smoke Management system.			
	<ul style="list-style-type: none"> Basement Upper floors 	Required N/A	Provided N/A	MR N/A
5	Fire Extinguishers.			
	<ul style="list-style-type: none"> Total numbers Types ISI Marking 	ISI Marked	104 Nos ABC , & W.CO ₂ , Co2 Provided	MR MR MR

6	First Aid Hose Reels				MR	
		• Total numbers on each floor.	02 No in ancillary building, 14 Nos at CC & 10 Nos at each platform	Provided		
		• Length of hose-reel hose.	Hose Reel	Provided		MR
		• Nozzle Diameter	Required	6mm		MR
7	Automatic fire detection & alarming system.					
	• Type of detectors	Required	Smoke & Heat		MR	
	• Location of Main Panel	Required	Station Control Room		MR	
	• Location of Repeater Panel	Required	Concourse level		MR	
	• Alternate source of power	Required	Provided DG Set		MR	
	• Hooter's location	Required	Provided at all levels		MR	
8	MOEFA	Required	Provided		MR	
9	Public Address System	Required	Provided		MR	
10	Automatic Sprinkler System					
	• Basement	Required in following rooms:- mess, store, Security , Locker	Provided		MR	
	• Upper floors	N/A	N/A		N/A	
	• Sprinkler above false ceiling	N/A	N/A		N/A	
11	Internal Hydrants.					
	• Size of Riser/Down-comer	150 mm	Provided		MR	
	• Number of Hydrant per floor	01 No in ancillary building, 14 Nos at CC & 10 Nos at each platform	Provided		MR	
	• Hose box.	01 No in ancillary building, 14 Nos at CC & 10 Nos at each platform	Provided		MR	
12	Yard Hydrants.					
	• Total number of hydrants.	02 No's Required	Provided		MR	
	• Hose box.	02 No in ancillary building, 01 Nos at each tunnel portal	Provided		MR	
13	Pumping arrangements.					
	a) Ground Level					
	➤ Discharge of main pump.	2839 LPM	Provided		MR	
	➤ Head of main pump.	75m for hydrant & 56m for sprinkler	Provided		MR	
	➤ Number of main pumps.	Two	Provided		MR	
	➤ Jockey Pump output.	2 x 189 LPM	Provided		MR	
	➤ Jockey Pump head.	75m for hydrant & 56m for sprinkler	Provided		MR	
	➤ Standby Pump output.	2 x 2839 LPM (electric)	Provided		MR	
	➤ Standby Pump head.	75m for hydrant & 56m for sprinkler	Provided		MR	
	➤ Auto Starting/Manual Stopping.	Required	Provided		MR	
	➤ Pump House Access	Required	Provided		MR	
	b) Terrace Level					
	➤ Discharge of pump.	N/A	N/A		N/A	
	➤ Head of pump.	N/A	N/A		N/A	
	➤ Power supply.	N/A	N/A		N/A	
	➤ Auto starting of pump.	N/A	N/A		N/A	
14	Captive water storage for Fire Fighting.					
	• Underground tank capacity.	N/A	N/A		N/A	
	➤ Draw-off connection.	Required	Provided		MR	
	➤ Fire Service Inlet.	Required	Provided		MR	
	➤ Access to tank.	Required	Provided		MR	
	• Overhead tank capacity.	2,00,000 ltr	Provided		MR	
15	Exit Signage.	Required	Provided		MR	
16	Provision of Lifts.					

	<ul style="list-style-type: none"> • Pressurization of lift shaft. • Pressurization of lift lobby. • Communication in lift car. • Fireman's switch. • Lift signage. 	N/A	N/A	N/A
		N/A	N/A	N/A
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
17	Standby Power Supply	Required	Provided (DG Set)	MR
18	Refuge Area			
	<ul style="list-style-type: none"> • Total area • Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19	Fire Control Room.			
	<ul style="list-style-type: none"> • Detector System Panel. • Flow Switch Panel. • PA system Panel. • Battery backup • Building floor plan 	Required in SCR	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
20	Special Fire Protection System for the Protection of Special Risk, if any :	Clean agent flooding system for electrical panels provided		MR

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Further, the party has complied all the observation / Shortcoming already issued & communicated by this department vide letter of even no 866 dated 03/05/2024.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/Assembly.(UG)/2021/SZ/99 dated 04/02/2021, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

[Signature]
 Signature of the Inspection Officer
 Name: Sh. Manoj Kumar Sharma
 Design: DO (South)

[Signature]
 Signature of the Inspecting Officer
 Name: Sh. Rajesh Kumar
 Design: ADO (BCP)

CFO (HO)
[Signature]
 20/06/2024

[Signature]
 Director
 21/06/24

As approved, F.T. kept
 ADO/BCP is put up for your signature
[Signature]
 Director
 21/06/24