

c34

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI - 110001**

No. F6/DFS/MS/GH/NDZ/2024/243

Dated: 20/06/2024

**FIRE SAFETY CERTIFICATE**

Certified that the M/s New Hostel Guest House situated at 368, Bazar Matia Mahal, Jama Masjid, Delhi - 06, comprised of Basement + Ground + 03 upper floors: Basement - (storage use), Ground floor - (commercial use), 1<sup>st</sup> floor - (reception + 03 guest rooms), 2<sup>nd</sup> floor - (06 guest rooms) & 3<sup>rd</sup> floor - (03 guest rooms) total 12 guest rooms was granted FSC by this department vide letter no. F6/DFS/MS/GH/NDZ/2018/2684 dated 12.12.2018. The building/premises was re-inspected by the officer concerned from this department on 07.06.2024 in presence of Mohd. Abdul Haleem (Manager) and found that the building has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010. Accordingly, the premises is fit for occupancy of "Residential (Sub-Division- A-1)" 1<sup>st</sup> floor- (03 guest rooms), 2<sup>nd</sup> floor - (06 guest rooms) & 3<sup>rd</sup> floor - (03 guest rooms) for total 12 guest room upto 3<sup>rd</sup> floor only, with effect from .....20/06/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire service Rules, 2010 printed below.

Issued on .....20/06/2024.....at New Delhi by

  
(Atul Garg)  
Director  
Delhi Fire Service  
Tel: 011-23414000  
ok  
AG

**Copy to:-**

1. The Joint Commissioner of Police (Licensing), 1st Floor, Police Station Defence Colony, New Delhi. w.r.to ID No. 2024052808262 dated 28.05.2024.
2. The Licensee, M/s New Hostel Guest House at 368, Bazar Matia Mahal, Jama Masjid, Delhi - 06.

**Condition for the validity of fire safety certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub Rule (I) of Rule 37] along with a copy of this Certificate, six month prior to its expiry".
8. Any change in the occupancy shall be intimated to this Deptt. and approval shall be obtained there to before occupancy of the same.

## INSPECTION REPORT

1	Name & address of the building	M/s New Hostel Guest House at 368, Bazar Matia Mahal, Jama Masjid Delhi -06.		
2	Building is comprised of	Basement + Ground + 03 upper floors Basement - (storage use) Ground floor - (Commercial use) 1 <sup>st</sup> floor - (reception + 03 guest rooms) 2 <sup>nd</sup> floor - (06 guest rooms) 3 <sup>rd</sup> floor - (03 guest rooms)		
3	Type of Occupancy	Residential Group A-1		
4	Type of Case	Renewal (old case)		
5	Details of Previous FSC	F6/DFS/MS/GH/NDZ/2018/2684 dated 12.12.2018		
6	Fire Safety direction letter No	Nil		
7	Date of Inspection	07.06.2024		
8	Name of the Inspecting Officers	Sumit Kumar, ADO (SPM)		
9	Name of the designation of Officer from the building side	Mohd. Abdul Haleem (Owner Son)		
10	Year of Construction	1990		
11	Applicant's letter No	Online application I.D.2024052808262 dated 28.05.2024		
S/No	Minimum Standards on fire Prevention and fire safety requirements U/R 33	Requirement/ Existing fire safety arrangements	Provided at Site	Remarks MR/NMR
1	<b>Access to building</b>			
	Road width	NA	09 m	NA
	Gate width	NA	NA	NA
	Width of internal road	NA	NA	NA
2	<b>Number, Width, Type and Arrangement of Exits</b>			
	<b>A. Number of Staircases</b>			
	Upper Floor	01 no.	01 no.	MR ✓
	Basement	NA	NA	NA
	<b>B. Width of Staircases</b>			
	Upper Floor	0.80 mtrs.	1.25 to 1.28 mtrs.	MR ✓
	Basement	NA	NA	NA
	<b>C. Protection of exits</b>			
	Fire check door	NA	NA	NA
	Pressurization	NA	NA	NA
	D. No. of continuous staircases to terrace	01 no.	01 no.	MR ✓
	E. Width of Corridor	NA	NA	NA
	G. Door size	1.0 m	1.0 m	MR
3	<b>Compartmentation</b>			
	Fire check door	NA	NA	NA
	Sealing of electrical shafts	NA	NA	NA
	Fire rating of shaft door*	NA	NA	NA
	Water curtain	NA	NA	NA
	Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	Basement	NA	NA	NA
	Upper floor	12 ACPH	Natural /Ventilation	MR ✓

6

82a

<b>5.</b>	<b>Fire Extinguisher</b>			
	Total numbers	06 no.	06 no.	MR
	types	CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC	MR
	IS marking	Required	Provided	MR
<b>6</b>	<b>First-aid-Hose Reels.</b>			
	Total numbers of each floor	01 no. at 2 <sup>nd</sup> floor	Provided ✓	MR
	Length of hose reel hose	30 m	30 m	MR
	Nozzle diameter	05 mm	05 mm	MR
<b>7</b>	<b>Automatic fire detection and alarming system.</b>			
	Type of detectors (CO type)	Required	Provided ✓	MR
	Location of main panel	Required	Provided at reception ✓	MR
	Location of repeater panel	NA	NA	NA
	Alternate source of power	Required	Provided	MR
	Hooters	Required	Provided	MR
<b>8</b>	MOEFA	NA	NA	NA
<b>9</b>	Public address System.	NA	NA	NA
<b>10</b>	<b>Automatic Sprinkler System.</b>			
	basement	NA	NA	NA
	upper floor	NA	NA	NA
	Sprinkler above false ceiling	NA	NA	NA
<b>11</b>	<b>Internal Hydrants</b>			
	size of riser/down-comer	NA	NA	NA
	Number of hydrants per floor	NA	NA	NA
	Hose Box	NA	NA	NA
<b>12</b>	<b>Yard Hydrants.</b>			
	Total number of hydrants	NA	NA	NA
	Hose Box	NA	NA	NA
<b>13</b>	<b>Pumping Arrangements.</b>			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main Pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby pump out put	NA	NA	NA
	➤ Standby pump Head	NA	NA	NA
	➤ Auto Starting /Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace Level			
	➤ Discharge of pump	225 LPM	225 LPM ✓	MR
	➤ Head of the Pump	30 m	30 m ✓	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR


P/ ↓ 84

14	<b>Captive Water Storage for Fire Fighting.</b>			
	Underground tank capacity	NA	NA	NA
	Draw-off connection	NA	NA	NA
	Fire service inlet	NA	NA	NA
	Access to tank	NA	NA	NA
15	Overhead Tank capacity	2,500 ltrs.	2,500 ltrs	MR
	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>			
	Pressurization of Lift Shaft	NA	NA	NA
	Pressurization of Lift lobby	NA	NA	NA
	Communication in lift car	NA	NA	NA
	Firemen's grounding switch	NA	NA	NA
	Lift Signage	NA	NA	NA
17	<b>Standby power supply</b>	Required	Provided	MR
18	<b>Refuge Area.</b>			
	Total area	NA	NA	NA
19	Location	NA	NA	NA
	<b>Fire Control Room</b>			
	Detector system panel	NA	NA	NA
	Flow switch panel	NA	NA	NA
	PA system panel	NA	NA	NA
	Batter backup	NA	NA	NA
20	Building Floor Plans	NA	NA	NA
	<b>Special Fire Protection systems for protection of special Risks, if any:</b>		NA	NA


The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspection.


Shortcomings communicated vide letter No.F6/DFS/MS/GH/NDZ/2021/871 dated 26.11.2021 has been rectified.

In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter No. F6/DFS/MS/GH/NDZ/2018/2684 dated 12.12.2018 is recommended to be renewed from 1<sup>st</sup> to 3<sup>rd</sup> floor only under Rule 35 of the Delhi Fire Service Rules 2010.


  
 11/01/2024  
 Signature of the Inspecting Officer  
 Name Sumit Kumar  
 Designation ADO (SPM)

DO (CD)

  
12/6/24

  
C.F.P.

  
12/06/24

  
13/01/2024  
Director  
13/06/24

  
ADY/SPM