

C77

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**

**NEW DELHI-110001.**

No. F.6/DFS/MS/EH/2024/SZ/189

Dated: 19/06/2024

**FIRE SAFETY CERTIFICATE**

Certified that the M/s Sagar Ratna Restaurant Pvt. Ltd. running at ground floor only in a building comprised of basement, ground floor plus three upper floors located at C-1, New Krishna Park, Vikas Puri, New Delhi 110018, owned/ occupied by a M/s Sagar Ratna Restaurant Pvt. Ltd. was issued Fire Safety Certificate vide Letter No. F6/DFS/MS/EH/2021/SZ/279 dated 08.10.2021. The Restaurant building was re-inspected by the officer concerned of this department on 11.06.2024 in the presence of Sh. Parshant (Restaurant Manager) and found that the M/s Sagar Ratna Restaurant Pvt. Ltd. have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the restaurant building/premises (**Ground Floor only**) is fit for occupancy class Group "D" Assembly Building" w.e.f. the date of issue of this certificate for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed below.  
Issued on 19/06/2024 at New Delhi.

  
(Atul Garg)  
Director  
Delhi Fire Service

**Online application Id 2024050206708 dated 30.05.2024**

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. Basement shall be used as per the building bye laws.
7. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

## INSPECTION REPORT

1. Name & address of the building: M/s Sagar Ratna Restaurant Pvt. Ltd., C-1, New Krishna Park, Vikas Puri, New Delhi 110018.
2. Building is comprised of : B+G+3 upper floors but restaurant is running at ground Floor only.
3. Type of Occupancy : Group D (Assembly)
4. Type of Case : Renewal
5. Details of Previous NOC : F6/DFS/MS/EH/2021/SZ/279 dated 08.10.2021
6. Fire Safety directives letter No : N.A
7. Date of inspection : 11.06.2024
8. Name of Inspecting Officers : A.D.O. R.K. Yadav
9. Name and designation of officers  
From the building side : Sh. Parshant (Restaurant Manager)
10. Year of Construction : 2006-2007
11. Applicant's letter No. : Application ID No. 2024050206708 dated 30.05.2024

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirements	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	09 m 4.5 m N/A	Provided Directly accessible N/A	M/R M/R N/A
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>	<b>(Restaurant at Ground Floor only)</b>		
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	Two N/A	Three provided N/A	M/R N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basements</li> </ul>	Old case N/A	1.14, .94 & .86 m. N/A	M/R, being old case N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	Required 1.50 m	One 2.30 m	MR MR
	e. Width of Corridor			
	f. Door Size	Two Exit	1.30 & 1.0 m	M/R, Being Old case
3.	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	<b>Smoke Management System</b>	<b>(Restaurant at Ground Floor only)</b>		
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	Required	Exhaust fans are provided	M/R
	<ul style="list-style-type: none"> <li>• Upper floors</li> </ul>	Required	Natural Ventilation	M/R
5.	<b>Fire Extinguishers</b>	<b>(Restaurant at Ground Floor only)</b>		
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	10 no's ABC/CO <sub>2</sub> ISI marked	Provided Provided ISI marked	M/R M/R M/R

N/22

16.

6.	<b>First-Aid Hose Reels</b>	<b>(Restaurant at Ground Floor only)</b>		
	<ul style="list-style-type: none"> <li>Total numbers on First Floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	One 30 mtrs 5 mm	Provided Provided Provided	MR MR MR
7.	<b>Automatic fire detection and alarming system</b>	<b>(Restaurant at Ground Floor only)</b>		
	<ul style="list-style-type: none"> <li>Type of detectors(Smoke)</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	N/A N/A N/A N/A N/A	Provided N/A N/A N/A N/A	N/A N/A N/A N/A N/A
8.	<b>MOEFA</b>	Required	Provided	M/R
9.	<b>Public Address System</b>	N/A	N/A	N/A
10.	<b>Automatic Sprinkler System</b>	<b>(Restaurant at Ground Floor only)</b>		
	<ul style="list-style-type: none"> <li>Basement</li> <li>Ground &amp; First Floor</li> <li>Sprinkler above false ceiling</li> </ul>	Required N/A N/A	Provided Provided N/A	M/R MR N/A
11.	<b>Internal Hydrants</b>	<b>(Restaurant at Ground Floor only)</b>		
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants</li> <li>Hose Box</li> </ul>	Required 100 mm One One	Provided Provided Provided	MR MR MR
12.	<b>Yard Hydrants</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	N/A N/A	N/A N/A	N/A N/A
13.	<b>Pumping Arrangements</b>			
	<ul style="list-style-type: none"> <li>Ground Level           <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/Manual Stopping</li> </ul> </li> <li>Pump House Access</li> <li>Terrace level           <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>	N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A 900 LPM 30 mtrs. Required Required	N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A Provided Provided Provided Provided	N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A MR MR MR MR
14.	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity           <ul style="list-style-type: none"> <li>Draw-off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> </ul> </li> <li>Overhead Tank capacity</li> </ul>	N/A N/A Required N/A 5000 ltrs.	N/A N/A Provided N/A 5000 ltrs. provided	N/A N/A M/R N/A M/R, being old case
15.	<b>Exit Signage.</b>	Required	Provided	M/R


1/2

1/2




Provision of Lifts.				
16.	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17.	Standby power supply	Required	Provided	MR
18. Refuge Area.				
18.	> Total Area	N/A	N/A	N/A
	> Location	N/A	N/A	N/A
19. Fire Control Room				
19.	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter number F6/DFS/MS/EH/2021/SZ/279 dated 08.10.2021, renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.

  
 Signature of Inspecting Officer  
 Name:- R.K. Yadav  
 Designation:- Asstt. Divisional Officer

D.O. (South West)

  
 12/6/24  
 CFO (S2)  
  
 13/6/2024  
 Director  
  
 15/6/24  
 Asstt. R.K.-y