

c/42

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No.F.6/DFS/MS/EH/2024/SZ/ 202

Dated: 25/06/2024

FIRE SAFETY CERTIFICATE

Certified that the M/s Hira Sweets and Confectionary Pvt. Ltd., Unit no. 3 & 4 Shop No. U-22, RCube Mall, Janakpuri East Metro Station, New Delhi-110058, comprised of ground plus first floor, owned/occupied by M/s Hira Sweets and Confectionary Pvt. Ltd., was issued FSC by this department vide letter no. F.6/DFS/MS/EH/2021/SZ/166 dated 02.08.2021. The building was re-inspected by the officer concerned of this department on 12.06.2024 in presence of Sh. Sanjay Rawat (Manager) and found that the management have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi fire service Rules 2010 and that the building/premises (Ground and first floor only) is fit for occupancy class Group-D "Assembly Building" w.e.f. 25/06/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on 25/06/2024 at New Delhi.


(Atul Garg)

Director
Delhi Fire Service

Online application Id 2024050406875 dated 30.05.2024

Following fire safety directives must be adhered to: -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per the building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

NIG

INSPECTION REPORT

1. Name & address of the building: M/s Hira Sweets and Confectionary Pvt. Ltd., Unit no. 3 & 4 Shop No. U-22, RCube Mall, Janakpuri East Metro Station, New Delhi.
2. Type of Occupancy : Group D (Assembly Building)
3. Building composition : Restaurant is running at Ground & First floor only in RCUBE Mall/DMRC Janakpuri
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/EH/2021/SZ/166 dated 02.08.2021
6. Fire Safety directives letter No : N/A
7. Date of inspection : 12.06.2024
8. Name of Inspecting Officers : A.D.O. R.K.Yadav
9. Name and designation of officers
From the building side : Sh. Sanjay Rawat (Manager)
10. Year of Construction : 2010
11. Applicant's letter No. : ID No. 2024050406875 dated 30.05.2024

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	09 mtrs 4.5 mtrs N/A	12 mtrs Directly accessible from internal road N/A	MR MR N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	2 No.	3 Nos	MR
	<ul style="list-style-type: none"> • Upper Floors • Basements 	N/A	N/A	N/A
	b. Width of staircases	02 m & 1.5 m	2M, 1.5 m & .80 M	MR
	<ul style="list-style-type: none"> • Upper Floor • Basements 	N/A	N/A	N/A
	c. Protection of exits	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	Required	Provided	MR
	e. Width of Corridor	N/A	Opening in hall	N/A
	f. Door Size	02 m & 1.5 m	2 m & 1.5 m	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	N/A Required	N/A Provided	N/A MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	04 No.'s ABC/CO ₂ ISI marked	Provided Provided ISI marked	MR MR MR

N7

6.	First-Aid Hose Reels			Provided	MR
	• Total numbers on ground floor	One		Provided	MR
	• Length of hose reel hose	30 m		Provided	MR
	• Nozzle diameter	5 mm		Provided	MR
7.	Automatic fire detection and alarming system				
	• Type of detectors	Smoke & Heat		Provided	MR
	• Location of Main Panel	Required		Provided	MR
	• Location of Repeater Panel	N/A		N/A	N/A
	• Alternate source of power	Required		Provided	MR
	• Hooters' Location	Required		At exit	MR
8.	MOEFA	Required		Provided	MR
9.	Public Address System	N/A		N/A	N/A
10.	Automatic Sprinkler System				
	• Basement	N/A		N/A	N/A
	• Ground Floor	Required		Provided	MR
	• Sprinkler above false ceiling	N/A		N/A	N/A
11.	Internal Hydrants				
	• Size of riser/down-comer	100 mm		Provided	MR
	• Number of hydrants	01 No.		Provided	MR
	• Hose Box	01 No.		Provided	MR
12.	Yard Hydrants				
	• Total number of hydrants	N/A		N/A	N/A
	• Hose Box	N/A		N/A	N/A
13.	Pumping Arrangements				
	Mall/DMRC			(Common with RCube)	
	• Ground Level				
	➤ Discharge of main Pump	1800 LPM		Provided	MR
	➤ Head of Main pump	40 m		Provided	MR
	➤ Number of main pumps	One		Provided	MR
	➤ Jockey Pump out put	180 LPM		Provided	MR
	➤ Jockey pump head	40 m		Provided	MR
	➤ Standby Pump out put	1800 LPM		Provided	MR
	➤ Standby Pump Head	40 m		Provided	MR
	➤ Auto Starting/Manual Stopping	Required		Provided	MR
	➤ Pump House Access	N/A		N/A	N/A
	• Terrace level				
	➤ Discharge of pump	N/A		N/A	N/A
	➤ Head of the pump	N/A		N/A	N/A
	➤ Power Supply	N/A		N/A	N/A
	➤ Auto Starting of pump	N/A		N/A	N/A
14.	Captive Water Storage for fire-fighting				
	Mall/DMRC			(Common with RCube)	
	• Underground tank capacity	50,000 ltrs		1,00,000 ltrs	MR
	➤ Draw-off connection	Required		Provided	MR
	➤ Fire service inlet	Required		Provided	MR
	➤ Access to tank	Required		Provided	MR
	• Overhead Tank capacity	Required		Provided	MR
15.	Exit Signage.	Required		Provided	MR
		Required		Provided	MR

N/A

6.	Provision of Lifts			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	> Total Area	N/A	N/A	N/A
	> Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The fire safety certificate of RCube mall was already issued vide letter no. F.6/DFS/MS/2024/SZ/156 dated 11.03.2024

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter number F.6/DFS/MS/EH/2021/SZ/166 dated 02.08.2021, renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Accordingly, reply letter is put up for approval & signature please.

R.K. Yadav
 13/06/2024
 Signature of the inspecting officer
 Name- R.K. Yadav
 Designation- ADO (JKP)

DO (BW)

14/6/24
CFO (S)
14/6/2024
Director (M)
14/06/24

ADO/JKP