

c-47

4

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No.F6/DFS/MS/EH/NDZ/2024/188

Dated: ...19/06/2024

FIRE SAFETY CERTIFICATE

Certified that the **Ranisha (Jain Refreshment Corner)** located at, **ground floor at shop no. P-14 - 90, Connaught Place, New Delhi** in a building comprised of Ground & inside mezzanine and 03 upper floors and but restaurant is running at ground floor, was earlier granted FSC by this department vide letter no.F6/DFS/MS/EH/NDZ/2021/195 dated 25/08/2021. Now, the premise was re-inspected by the officers concerned of this department on 07/06/24 in the presence of Manager and found that the said premises has complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010 and that the said restaurant premises is fit for occupancy class **Assembly Building (Group D) for Restaurant at ground floor only**, and valid up to 31.03.2027 from the date of issue in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued19/06/2024.....New Delhi by.

(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Chief Architect, NDMC, Palika Kendra, New Delhi.
2. The Dy. Commissioner of Police (Lic.), 1st floor, PS Defence Colony, New Delhi, ID No. 2024051807768 dated 18.05.2024.
3. The Manager, Ranisha (Jain Refreshment Corner) located at, ground floor at shop no. P-14 -90, Connaught Place, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. This FSC is valid for restaurant at ground floor only.
2. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
9. Any flammable material for interior decoration is strictly prohibited.

INSPECTION REPORT

N/8

1. Name & address of the building **Ranisha (Jain Refreshment Corner)**
located at, ground floor at shop no. P-14
-90, Connaught Place, New Delhi Gr .
+(Inside mezzanine)+3 upper floor
2. Type of occupancy:- **Assembly Building Group-D, Restaurant is running on Ground floor only.**
3. Type of case:- **Renewal**
4. Details of previous FSC:- **F6/DFS/MS/EH/NDZ/2021/195 dated 25/08/2021.**
5. Fire safety directives No.- **N/A**
6. Date of inspection: - **07/06/24**
7. Name of the inspecting officer:- **Sh. Ravinder Singh (ADO/CC)**
Sh. Rajinder Atwal (DO (CD)
8. Name & designation of officer
From the building side:- **Manager**
9. Year of construction:- **old heritage**
10. Applicant's letter No:- **Online ID no. 2024051807768 dated 18.05.2024.**

| S.No. | Minimum Standards on fire Prevention and fire safety U/R 33 | Requirement Existing | Provided at site | Remarks MR/NMR |
|-----------|---|----------------------|------------------|----------------|
| 1. | Access to Building | | | |
| | 1) Road width | 06mtr | 06 mtr. / | MR |
| | 2) Gate width | N/A | N/A | N/A |
| | 3) Width of internal road | N/A | N/A | N/A |
| 2. | Number, Width Type & Arrangement of Exits | | | |
| | A. Number of staircases | | | |
| | 1. Upper floors | 02nos | 02 nos | MR |
| | 2. Basements | N/A | N/A | N/A |
| | B. Width of staircase | | | |
| | 1. Upper floors | N/A | N/A | N/A |
| | 2. Basements | N/A | N/A | N/A |
| | C. Protection of exits | | | |
| | 1. Fire check door | N/A | N/A | N/A |
| | 2. Pressurization | N/A | N/A | N/A |
| | D. No. of continuous staircase to terrace | Required | Provided | MR |
| | E. Width of corridor | N/A | N/A | N/A |
| | F. Door size | 1.5 mtr | 1.5 m & 2.0 m / | MR |
| 3. | Compartmentation | | | |
| | 1) Fire check door | N/A | N/A | N/A |
| | 2) Sealing of electrical shafts | N/A | N/A | N/A |
| | 3) Fire rating of shaft door | N/A | N/A | N/A |
| | 4) Water curtain | N/A | N/A | N/A |
| | 5) Fire Dampers | N/A | N/A | N/A |
| 4. | Smoke Management System | | | |
| | 1) Basements | N/A | N/A | N/A |
| | 2) Upper floors | 12 a/c per hour | Natural | MR |
| 5. | Fire Extinguishers | | | |
| | 1) Total numbers | 04 Nos. | 04 Nos. / | MR |
| | 2) Types | ABC & CO2 | ABC & CO2 | MR |
| | 3) ISI marking | Required | Provided | MR |

| | | | | |
|------------|---|-------------|---------------|-----|
| 6. | First-Aid Hose Reel | | | |
| | 1) Total number | 01 | Provided / | MR |
| | 2) Length of hose reel hose | 30 mtr. | Provided | MR |
| | 3) Nozzle diameter | 05 mm | Provided | MR |
| 7. | Automatic Fire Detection & Alarming System | | | |
| | 1) Type of detectors | N/A | Provided / | N/A |
| | 2) Location of main panel | N/A | Provided / | N/A |
| | 3) Location of repeater panel | N/A | Provided | N/A |
| | 4) Alternate source of power | N/A | Provided | N/A |
| | 5) Hooter's Location | N/A | Provided | N/A |
| 8. | MOEFA | Required | Provided | MR |
| 9. | Public Address System | N/A | N/A | N/A |
| 10. | Automatic Sprinkler System | | | |
| | 1) Basement | N/A | N/A | N/A |
| | 2) Upper floors | N/A | Provided / | N/A |
| | 3) Sprinkler above false ceiling | N/A | N/A | N/A |
| 11. | Internal Hydrants | | | |
| | 1) Size of riser/down-comer | 100mm | Provided / | MR |
| | 2) Number of hydrants per floor | 01 | Provided / | MR |
| | 3) Hose box | 01 | Provided | MR |
| 12. | Yard Hydrants | | | |
| | 1) Total number of hydrants | N/A | N/A | N/A |
| | 2) Hose box | N/A | N/A | N/A |
| 13. | Pumping Arrangement | | | |
| | 1) Ground level | N/A | N/A | N/A |
| | a) Discharge of main pump | N/A | N/A | N/A |
| | b) Head of main pump | N/A | N/A | N/A |
| | c) Number of main pump | N/A | N/A | N/A |
| | d) Jockey pump out put | N/A | N/A | N/A |
| | e) Jockey pump head | N/A | N/A | N/A |
| | f) Stand by pump output | N/A | N/A | N/A |
| | g) Stand by pump head | N/A | N/A | N/A |
| | h) Auto starting/Manual stopping | N/A | N/A | N/A |
| | 2) Terrace level | | | |
| | a) Discharge of pump | 450 LPM | Provided / | MR |
| | b) Head of pump | 30 mtr. | Provided / | MR |
| | c) Power supply | Required | Provided | MR |
| | d) Auto starting of pump | Required | Provided | MR |
| 14. | Captive Water Storage for Fire Fighting | | | |
| | 1) Under ground tank capacity | N/A | N/A | N/A |
| | a) Draw-off connection | N/A | N/A | N/A |
| | b) Fire service inlet | N/A | N/A | N/A |
| | c) Access to tank | N/A | N/A | N/A |
| | d) Over head tank capacity | 20,000 lit. | 20,000 lit. / | MR |

| 15. | Exit Signage. | Required | Provided | MR |
|-----|--|----------|----------|-----|
| 16. | Provision of Lifts. | | | |
| | a) Pressurization of lift shaft | N/A | N/A | N/A |
| | b) Pressurization of lift lobby | N/A | N/A | N/A |
| | c) Communication in lift car | N/A | N/A | N/A |
| | d) Fireman's switch | N/A | N/A | N/A |
| | e) Lift signage | N/A | N/A | N/A |
| 17. | Stand by Power Supply | Required | Provided | MR |
| 18. | Refuge Area | N/A | N/A | N/A |
| | Total area location | N/A | N/A | N/A |
| 19. | Fire Control Room | N/A | N/A | N/A |
| | a) Detector system panel | N/A | N/A | N/A |
| | b) Flow switch panel | N/A | N/A | N/A |
| | c) PA system panel | N/A | N/A | N/A |
| | d) Battery backup | N/A | N/A | N/A |
| | e) Building floor plan | N/A | N/A | N/A |
| 20. | Special Fire Protection System for Protection of special Risk, if any: | | | N/A |

The fire protection systems provided in the said building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if approved, we may renew the FSC issued vide letter no. F6/DFS/MS/EH/NDZ/2021/195 dated 25/08/2021, under rule 35 of the Delhi Fire Service rules 2010. Accordingly, reply letter is prepared and put up for kind perusal and signature please.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

[Signature]
12/6/24

[Signature]
12/6/24

Name :- Sh. Rajinder Atwal
Designation :- DO (CD)

Name :- Ravinder Singh
Designation :- ADO (CC)

[Signature]
12/6/24

[Signature]
12/06/24

C.F.D.

[Signature]
13/6/2024

Director

[Signature]
17/6/24

[Signature]

As approved put up for kind perusal and signature

Director *[Signature]*
19/6/24

uploaded
19/6

[Signature]
18/6/24