

C-39

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001**

No: F6/DFS/MS/EH/NDZ/2024/209

Dated: 01/07/2024

**FIRE SAFETY CERTIFICATE**

Certified that the M/S Shri Hari Sharnam Bhojnalaya located at 1490-91, near Ritz Cinema, Kashmere Gate, Delhi - 06, comprised of Ground + 02 upper floor, but restaurant is running at 1<sup>st</sup> floor only. M/s Shri Hari Sharnam Bhojnalaya was granted FSC by this department vide letter no. F6/DFS/MS/EH/NDZ/2021/307 dated 27.10.2021. The building/ premises was re-inspected by the officer concerned of this department on 24.06.2024 in presence of Mr. Vijay Kumar (Manager) and found that the premises/building has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010. Accordingly, the premises is fit for occupancy class Group-D "Assembly Building (Restaurant)", restaurant running at 1<sup>st</sup> floor only with effect from 01/07/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire Service Rules, 2010 printed below.

Issued on 01/07/2024 at New Delhi by

  
(Atul Garg)  
Director  
Delhi Fire Service o/c  
Tel: 011-23414000  
E/G

**Copy to:-**

1. The Joint Commissioner of Police (Licensing), 1st Floor, Police Station Defence Colony, New Delhi: - Ref. MHA Portal ID. No. 2024060809056 dated 08.06.2024.
2. The Licensee, M/s Shri Hari Sharnam Bhojnalaya located at 1490-91, near Ritz Cinema, Kashmere Gate, Delhi - 06.

**Condition for the validity of fire safety certificate**

1. This FSC is valid for 1<sup>st</sup> floor only (floor occupancy by eating house).
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub Rule (I) of Rule 37] along with a copy of this Certificate, six month prior to its expiry. Any change in the occupancy shall be intimated to this Deptt. and approval shall be obtained thereto before occupancy of the same.

### INSPECTION REPORT

1	Name & address of the building	M/S Shri Hari Sharnam Bhojnalya at 1490-91, near Ritz Cinema, Kashmere Gate, Delhi - 110006.
2	Building is comprised of	(Ground + 02 upper floor) (Restaurant running at 1 <sup>st</sup> floor only)
3	Type of occupancy	Assembly Building- "Group-D" (Restaurant)
4	Type of case	renewal (old case)
5	Details of previous FSC	F6/DFS/MS/EH/NDZ/2021/307 dated 27.10.2021
6	Fire safety direction letter no.	Nil
7	Date of inspection	24.06.2024
8	Name of the inspecting officers	Mr. Sumit Kumar, ADO (SPM)
9	Name of the designation of officer from the building side	Mr. Vijay Kumar (Manager)
10	Year of construction	2017 (year of change of occupancy)
11	Applicant's letter no.	Online application no. 2024060809056 dated 08.06.2024

S.No	Minimum Standards on fire Prevention and fire safety requirements U/R 33	Requirements (as per NBC IV & UBBL 2016)	Provided at Site	Remarks MR/ NMR
<b>1</b>	<b>Access To Building:</b>			
	Road width	06 mtrs.	06 mtrs.	MR ✓
	Gate width	NA	NA	NA
	Width of internal road	NA	NA	NA
<b>2</b>	<b>Number, Width, Type and Arrangement of Exits:</b>			
<b>A</b>	<b>Number of staircases</b>			
	a Upper floor	02 nos.	02 nos.	MR ✓
	b Basement	NA	NA	NA
<b>B</b>	<b>Width of staircases</b>			
	a Upper floor	1.5 mtrs. each	1.5 mtrs each	MR ✓
	b Basement	NA	NA	NA
<b>C</b>	<b>Protection of exits</b>			
	a Fire check door	NA	NA	NA
	b Pressurization	NA	NA	NA
<b>D</b>	No. of continuous staircases to terrace	01 nos.	01 nos.	MR ✓
<b>E</b>	Width of corridor	NA	NA	NA
<b>F</b>	Door size	1.5 mtr.	1.50 mtr.	MR ✓
<b>3</b>	<b>Compartmentation:</b>			
<b>A</b>	Fire check door	NA	NA	NA
<b>B</b>	Sealing of electrical shafts	NA	NA	NA
<b>C</b>	Fire rating of shaft door	NA	NA	NA
<b>D</b>	Water curtain	NA	NA	NA
<b>E</b>	Fire dampers	NA	NA	NA
<b>4</b>	<b>Smoke Management System:</b>			
<b>A</b>	Upper floors	12 ACPH	Natural + exhaust fans	MR
<b>B</b>	Basements	NA	NA	NA

LJ 24

- N/12-

<b>5.</b>	<b>Fire Extinguisher:</b>			
A	Total numbers	04 nos.	06 nos. /	MR
B	Types	ABC & Co2	ABC & Co2	MR
C	ISI marking	Required	Provided	MR
<b>6</b>	<b>First-Aid-Hose Reels:</b>			
A	Total numbers at each floor	01 nos.	01 nos. /	MR
B	Length of hose reel hose	30 mtr.	30 mtr.	MR
C	Nozzle diameter	05 mm	05 mm	MR
<b>7</b>	<b>Automatic Fire Detection And Alarming System:</b>			
A	Type of detectors	NA	Provided	MR
B	Location of main panel	NA	Provided at 1 <sup>st</sup> floor	NA
C	Location of repeater panel	NA	NA	NA
D	Alternate source of power	NA	NA	NA
E	Hooters Location	NA	At 1 <sup>st</sup> floor	NA
<b>8</b>	<b>MOEFA:</b>	Required	Provided	MR
<b>9</b>	<b>Public Address System:</b>	NA	NA	NA
<b>10</b>	<b>Automatic Sprinkler System:</b>			
A	Basement	NA	NA	NA
B	Second floor	NA	NA	NA
C	Sprinkler above false ceiling	NA	NA	NA
<b>11</b>	<b>Internal Hydrants:</b>			
A	size of riser/down-comer	100 mm	100 mm /	MR
B	Number of hydrants per floor	01 no.	01 no. /	MR
C	Hose box	01 no.	01 no. /	MR
<b>12</b>	<b>Yard Hydrants:</b>			
A	Total number of hydrants	NA	NA	NA
B	Hose box	NA	NA	NA
<b>13</b>	<b>Pumping Arrangements:</b>			
A	Ground level			
a)	Discharge of main pump	NA	NA	NA
b)	Head of main pump	NA	NA	NA
c)	Number of main pumps	NA	NA	NA
d)	Jockey pump out put	NA	NA	NA
e)	Jockey pump head	NA	NA	NA
f)	Standby pump out put	NA	NA	NA
g)	Standby pump head	NA	NA	NA
h)	Auto starting /manual stopping	NA	NA	NA
i)	Pump House Access	NA	NA	NA
B	Terrace level			
a)	Discharge of pump	450 LPM	450 LPM /	MR
b)	Head of the pump	40 m	40 m /	MR
c)	Power supply	Required	Provided	MR
d)	Auto starting of pump	Required	Provided	MR

262

N

262

<b>14 Captive Water Storage For Fire Fighting:</b>				
A	Underground tank capacity	NA	NA	NA
B	Draw-off connection	NA	NA	NA
C	Fire service inlet	NA	NA	NA
D	Access to tank	NA	NA	NA
E	Overhead tank capacity	20,000 ltrs.	Provided /	MR
15	<b>Exit Signage:</b>	Required	Provided /	MR
<b>16 Provision of Lifts:</b>				
A	Pressurization of lift shaft	NA	NA	NA
B	Pressurization of lift lobby	NA	NA	NA
C	Communication in lift car	NA	NA	NA
D	Firemen's grounding switch	NA	NA	NA
E	Lift signage	NA	NA	NA
17	<b>Standby Power Supply:</b>	Required	Provided	MR
<b>18 Refuge Area:</b>				
A	Total area	NA	NA	NA
B	Location	NA	NA	NA
<b>19 Fire Control Room :</b>				
A	Detector system panel	NA	NA	NA
B	Flow switch panel	NA-	NA	NA
C	Pa system panel	NA	NA	NA
D	Battery backup	NA	NA	NA
E	Building floor plans	NA	NA	NA
20	<b>Special Fire Protection Systems For Protection of Special Risks, If Any:</b>		NA	NA

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspection.

In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter no. F6/DFS/MS/EH/NDZ/2021/307 dated 27.10.2021 is recommended to be renewed (restaurant running at 1<sup>st</sup> floor only), under Rule 35 of the Delhi Fire Service Rules 2010.

Accordingly, DFA is put for approval and signature please.

*Sumit Kumar*  
24.06.2024

Signature of the Inspecting Officer  
Name Sumit Kumar  
Designation ADO (SPM)

DO (CD)

*[Signature]*

24/6/24

*[Signature]*  
Dy. C.F.O. (MS-2)

*[Signature]*  
25/06/24

C.F.O.  
*[Signature]*  
25/6/2024

*[Signature]*  
Director  
25/6/24