

C 73



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001




No. F6/DFS/MS/2024/School/602

Dated: 28/06/2024

**FIRE SAFETY CERTIFICATE**

Certified that the **Geetanjali Modern School** located at **Gali No-13, A-Block, West Sant Nagar, Delhi-110084** comprised of **Ground & 03 upper floors only** owned/ occupied by **Geetanjali Modern School** was issued Fire Safety Certificated vide this office letter no. **F6/DFS/MS/School/2013/790 Dated 26.08.2013 for (Ground & first floor)**. The premise was re-inspected by the officer concerned of this department on **21.06.2024** in the presence of **Sh. Hari Kishan** and observed that the management has added two more floors and building is now ground & three upper floors and all the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premise have therefore deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and the building premise is fit for occupancy under **Educational "Group B"** with effect from **28/06/2024** for a period of **three years** in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on **28/06/2024** at New Delhi

  
(Atul Garg)  
Director  
Ph:-011-23414000  
57c Op

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Manager, Geetanjali Modern School located at Gali No-13, A-Block, West Sant Nagar, Delhi-110084.

**Conditions for the validity of Fire Safety Certificate:**

1. **This Fire Safety Certificate is valid ground & 03 upper floors for educational occupancy only. If any additional construction temporary or permanent is made in future, the Fire Safety Certificate will be treated as null & void.**
1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doi/fire/FIRE/Home/Forms>.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

**INSPECTION REPORT**

1. Name & address of the building : Geetanjali Modern School at A-Block, Gali No-13, West Sant Nagar, Delhi-110084.
2. Composition of building : Ground & 03 upper floors
3. Type of Occupancy : Educational
4. Type of Case : Add/Alt
5. Details of previous NOC : F6/DFS/MS/School/2013/790 Dated 26.08.2013 (Ground & first floor)
6. Fire Safety directives letter No : NBC Part- IV
7. Date of inspection : 21.06.2024
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers  
From the building side : Sh. Hari Kishan
10. Year of Construction : 2010 & 2016
11. Applicant's letter No. : Online E-mail I.D Dated 19.06.2024

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part-IV Requirements	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	06m	06m	MR
	• Gate width	Directly accessible	Directly accessible	MR
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	02	02	MR
	• Upper Floors	NA	NA	NA
	• Basements			
	b. Width of staircases	1.50m	1.50m	MR
	• Upper Floors	NA	NA	NA
	• Basements			
	c. Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization			
	d. No. of continuous staircases to terrace	02	02	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.20m	Provided	MR
3	<b>Compartmentation.</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural Ventilation	MR
5	<b>Fire Extinguishers</b>			
	• Total numbers	12nos	14nos	MR

		N/13	ABC/Co2	ABC-14	
	<ul style="list-style-type: none"> <li>Types</li> <li>ISI marking</li> </ul>		Yes	Yes	MR
6	<b>First-Aid Hose Reels.</b>				
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> </ul>	01	01		MR
	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> </ul>	30m	30m		MR
	<ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>	5mm	5mm		MR
7	<b>Automatic fire detection and alarming system</b>				
	<ul style="list-style-type: none"> <li>Type of detectors</li> </ul>	NA	NA		NA
	<ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>	NA	NA		NA
	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>	NA	NA		NA
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	NA	NA		NA
	<ul style="list-style-type: none"> <li>Hooters' Location</li> </ul>	NA	NA		NA
8	<b>MOEFA</b>	Required	Provided		MR
9	<b>Public Address System.</b>	NA	NA		NA
10	<b>Automatic Sprinkler System.</b>				
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	NA	NA		NA
	<ul style="list-style-type: none"> <li>Upper Floor</li> </ul>	NA	NA		NA
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	NA	NA		NA
11	<b>Internal Hydrants</b>				
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> </ul>	NA	NA		NA
	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	NA	NA		NA
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	NA	NA		NA
12	<b>Yard Hydrants.</b>				
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	NA	NA		NA
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	NA	NA		NA
13	<b>Pumping Arrangements.</b>				
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/ Manual stopping</li> <li>➤ Pump House Access</li> </ul> </li> <li>Terrace level <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul> </li> </ul>	N/A	N/A	N/A	N/A
		N/A	N/A		N/A
		N/A	N/A		N/A
		N/A	N/A		N/A
		N/A	N/A		N/A
		N/A	N/A		N/A
		N/A	N/A		N/A
		N/A	N/A		N/A
		450 LPM	450 LPM		MR
		40m	40m		MR
		Required	Provided		MR
		Required	Provided		MR
14	<b>Captive Water Storage for fire fighting.</b>				
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> </ul>	NA	NA		NA
	<ul style="list-style-type: none"> <li>➤ Draw-off connection</li> </ul>	NA	NA		NA
	<ul style="list-style-type: none"> <li>➤ Fire service inlet</li> </ul>	NA	NA		NA
	<ul style="list-style-type: none"> <li>➤ Access to tank</li> </ul>	NA	NA		NA
	<ul style="list-style-type: none"> <li>Overhead Tank capacity</li> </ul>	10,000 LTR	10,000 LTR		MR

		Required	Provided	MR
15	Exit Signage.			
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room.			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

**Note:-**

The fourth floor found demolished by the school management an undertaking with photographs has been submitted by the management of the building and if any additional construction temporary or permanent is made the FSC shall stand cancelled and shall treated null and void. The same condition has been mention in the FSC.

The fire protection systems provided in the building were tested/ checked randomly and found in good working condition, at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standard on fire prevention and fire safety requirements as stipulated in NBC Part 4, it is recommended to grant Fire Safety Certificate

DO (WZ) *[Signature]*  
24/06/2024  
Dy. Chief Fire Officer (WZ)

*[Signature]*  
24/06/2024  
Signature of the Inspecting Officer  
Name :- C.L. Meena  
Designation:- ADO/RN

*[Signature]*  
25/6

CFO - CL  
*[Signature]*  
24/06/24  
*[Signature]*

DCFO.....10.11.24  
Date.....26/6/2024

Conf ~ P.T.O.