



No. F6/DFS/MS/School/NDZ/2024/ 598

Dated: 28/06/2024

FIRE SAFETY CERTIFICATE

Certified that **Raman Modern Public School** running on ground plus first floor of the building comprised of ground plus two upper floors located at Main Road, Bhagat Vihar, Delhi - 110094, owned / occupied by **Raman Modern Public School**, was issued Fire Safety Certificate vide letter No F6/DFS/MS/School/2019/NDZ/2187 dated 21.11.2019. The school building was re-inspected by the officer concerned of this department on 21/06/2024 in presence of Mr. Rajpal Sharma (Manager) and observed that all the fire prevention and fire safety requirements in accordance with Circular No. 262 - 362 dated 17/01/2005 issued by Director of Education and observed that school building ground and first floor is fit for occupancy class "**Educational Building**" (Group - B) with effect from 28/06/2024 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 28/06/2024 at New Delhi by.


(APUL GARG)
DIRECTOR
o/c DELHI FIRE SERVICE
@

Copy to: -

1. The Dy. Director of Education, B - Block, Yamuna Vihar, Delhi - 110053.
2. The Principal, Raman Modern Public School Main Road, Bhagat Vihar, Delhi - 110094.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

419

INSPECTION REPORT

1	Name & address of the building	Raman Modern Public School located at Main Road, Bhagat Vihar, Delhi - 110094.			
2	Building is comprised of	Ground plus two upper floors (School running on ground plus first floor only)			
3	Type of occupancy	Educational Building			
4	Type of case	Renewal			
5	Details of previous FSC	F6/DFS/MS/School/2019/NDZ/2187 dated 21.11.2019			
6	Fire safety directives letter no.	Circular 262-362 dated 17.10.2005 issued by DOE			
7	Date of inspection	21/06/2024			
8	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)			
9	Name of the designation of officer from the building side	Mr. Rajpal Sharma (Manager)			
10	Year of construction	2006			
11	Applicant's letter no.	Email dated 18/06/2024			
S.No	Minimum Standards on fire Prevention and fire safety requirements U/R 33	Old Circular Requirement	Provided at Site	Remarks MR/NMR	
1	Access to building				
	a	Road width	6.0 mtrs.	4.50 mtrs. / MR (Old accepted)	
	b	Gate width	NA	NA	
	c	Width of internal road	NA	NA	
2	Number, Width, Type and Arrangement of Exits				
	A	Number of staircases			
		a	Upper floor	01 no.	02 nos. MR
		b	Basement	NA	NA
		B	Width of staircases		
		a	Upper floor	1.50 mtrs.	1.30 mtrs. & 0.78 mtrs. MR
		b	Basement	NA	NA
		C	Protection of exits		
		a	Fire check door	NA	NA
		b	Pressurization	NA	NA
		D	No. of continuous staircases to terrace	01 no.	01 no. MR
		E	Width of corridor	1.50 mtrs.	1.50 mtrs. MR
		F	Door size	1.0 mtrs.	1.0 mtrs. MR
	3	Compartmentation			
a		Fire check door	NA	NA	
b		Sealing of electrical shafts	NA	NA	
c		Fire rating of shaft door	NA	NA	
d		Water curtain	NA	NA	
e		Fire dampers	NA	NA	
4	Smoke Management System.				
	a	Basement	NA	NA	
	b	Upper floor	NA	NA	

(w)

5.	Fire Extinguisher				
	a	Total numbers	04 nos.	08 nos. ✓	MR
	b	Types	CO ₂ & ABC	CO ₂ & ABC	MR
	c	ISI marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.				
	a	Total numbers of each floor	01 no.	01 no. ✓	MR
	b	Length of hose reel hose	30 mtrs.	30 mtrs.	MR
	c	Nozzle diameter	05 mm	05 mm ✓	MR
7	Automatic fire detection and alarming system.				
	a	Type of detectors	NA	NA	NA
	b	Location of main panel	NA	NA	NA
	c	Location of repeater panel	NA	NA	NA
	d	Alternate source of power	NA	NA	NA
	e	Hooter	NA	NA	NA
8	MOEFA				
			NA	NA	NA
9	Public address System.				
			NA	NA	NA
10	Automatic Sprinkler System.				
	a	Basement	NA	NA	NA
	b	Upper floors	NA	NA	NA
	c	Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants				
	a	Size of riser	NA	NA	NA
	b	Number of hydrants per floor	NA	NA	NA
	c	Hose Box	NA	NA	NA
12	Yard Hydrants.				
	a	Total number of hydrants	NA	NA	NA
	b	Hose Box	NA	NA	NA
13	Pumping Arrangements.				
	A	Ground Level			
	a	Discharge of main Pump	NA	NA	NA
	b	Head of Main Pump	NA	NA	NA
	c	Number of main pumps	NA	NA	NA
	d	Jockey pump out put	NA	NA	NA
	e	Jockey pump head	NA	NA	NA
	f	Standby pump out put	NA	NA	NA
	g	Standby pump head	NA	NA	NA
	h	Auto starting /manual stopping	NA	NA	NA
	i	Pump House Access	NA	NA	NA
	B	Terrace Level			
	a	Discharge of pump	220 LPM	220 LPM ✓	MR
	b	Head of the Pump	40 m	40 m ✓	MR
	c	Power supply	Required	Provided	MR
	d	Auto Starting of pump	Required	Provided	MR

14	Captive Water Storage for Fire Fighting.				
	a	Underground tank capacity	NA	NA	NA
	b	Draw-off connection	NA	NA	NA
	c	Fire service inlet	NA	NA	NA
	d	Access to tank	NA	NA	NA
	e	Overhead Tank capacity	25,00 liters.	Provided	MR
15	Exit Signage.		Required	Provided	MR
16	Provision of Lifts.				
	a	Pressurization of Lift Shaft	NA	NA	NA
	b	Pressurization of Lift lobby	NA	NA	NA
	c	Communication in lift car	NA	NA	NA
	d	Firemen's grounding switch	NA	NA	NA
	e	Lift Signage	NA	NA	NA
17	Standby power supply		NA	NA	NA
18	Refuge Area.				
	a	Total area	NA	NA	NA
	b	Location	NA	NA	NA
19	Fire Control Room				
	a	Detector system panel	NA	NA	NA
	b	Flow switch panel	NA	NA	NA
	c	PA system panel	NA	NA	NA
	d	Battery backup	NA	NA	NA
	e	Building Floor Plans	NA	NA	NA
20	Special Fire Protection systems for protection of special Risks, if any:		NA	NA	NA

The fire protection system was randomly checked and tested and was found functional at the time of inspection. The earlier shortcomings issued vide letter no. F6/DFS/MS/School/NDZ/2024/85 dated 26/02/2024 by this department has been rectified by the management.

Keeping in view of the compliance of minimum standards of fire prevention and fire safety measures required as per Circular No. 262-362 dated 17/01/2005, under the rules the FSC issued vide letter no. F6/DFS/MS/School/2019/NDZ/2187 dated 21.11.2019, renewal under Rule 35 of the Delhi Fire Service Rules 2010, is recommended to be renewed.

No file is pending with me before disposal of this case



24/6/2024

Signature of the Inspecting Officer

Name: Yashwant Singh Meena

Designation: ADO (L.N)

~~DY.CFO/NDZ~~

Living
25/06/24

C.F.O.
25/6/2024

Director
27/06/24

AD/HR
P.T.O