



No. F6/DFS/MS/School/NDZ/2024/574

FIRE SAFETY CERTIFICATE

Certified that the Alok Bharti Secondary School located at Khureji Khas, Delhi-110051. Comprised of ground floor Only, owned / occupied by Alok Bharti Secondary School, was issued FSC vide letter No. F6/DFS/MS/School/2018/NDZ/1745 dated 27/07/2018. The School building have complied with the fire prevention and fire safety requirements in accordance with the Circular No.F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by the Director of Education and re-inspected by the officer concerned of this department on 14/06/2024 in presence of Mr. Sudhir Kumar (H.O.S) of the school and that the school building is fit for occupancy class "Educational Building" (Group-B) with effect from 26/06/2024 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010 & also conditions printed bellow.

Issued on 26/06/2024 at New Delhi by.


(ATUL GARG)
DIRECTOR

o/c DELHI FIRE SERVICE
@

Copy to:-

1. The Principal, Alok Bharti Secondary School, Khureji Khas, Delhi-110051.
2. The Director of Education, Govt. of NCT, Old Secretariat, Delhi-110054.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

N/08

INSPECTION REPORT

01.	Name & address of the building	Alok Bharti Secondary School located at Khureji Khas, Delhi-110051.		
02.	Building is comprised of	Ground floor only		
03.	Type of occupancy	Educational		
04.	Type of case	Renewal		
05.	Details of previous FSC	F6/DFS/MS/School/2018/NDZ/1745 dated 27/07/2018		
06.	Fire safety directives letter no.	F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011		
07.	Date of inspection	14/06/2024		
08.	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)		
09.	Name of the designation of officer from the building side	Mr. Sudhir Kumar (H.O.S)		
10.	Year of construction	1969		
11.	Applicant's letter no.	Outdoor dairy no.2665 dated 07/06/2024		
S.No	Minimum standard of fire prevention and fire safety U/R 33	Requirement Education Circular 01.03.2011	Provided at site	Remarks MR/NMR
01.	Access to Building:			
	A Road width	6.0 mtrs.	6.0 mtrs.	MR
	B Gate width	N/A	N/A	N/A
	C Width of internal road	N/A	N/A	N/A
02.	Number, Width, Type and Arrangement of Exits:			
	A Number of staircases			
	a Upper floor	N/A	N/A	N/A
	C Basement	N/A	N/A	N/A
	B Width of staircases			
	a Upper floor	N/A	N/A	N/A
	C Basement	N/A	N/A	N/A
	C Protection of exits			
	a Fire check door	N/A	N/A	N/A
	b Pressurization	N/A	N/A	N/A
	D No. of continuous staircases to terrace	N/A	N/A	N/A
	E Width of corridor	N/A	N/A	N/A
	F Door size	1.0 mtr	1.0 mtr.	MR
03.	Compartmentation:			
	A Fire check door	N/A	N/A	N/A
	B Sealing of electrical shafts	N/A	N/A	N/A
	C Fire rating of shaft door	N/A	N/A	N/A
	D Water curtain	N/A	N/A	N/A
	E Fire dampers	N/A	N/A	N/A
04.	Smoke Management System:			
	A Basement	N/A	N/A	N/A
	B Upper floor	N/A	N/A	N/A

W


05. Fire Extinguisher:				
A	Total numbers	04 nos.	04 nos.	MR
B	Types	ABC/CO ₂	ABC/CO ₂	MR
C	ISI marking	ISI Marked	ISI Marked	MR
06. First-Aid-Hose Reel:				
A	Total numbers of each floor	N/A	N/A	N/A
B	Length of hose reel hose	N/A	N/A	N/A
C	Nozzle diameter	N/A	N/A	N/A
07. Automatic Fire Detection and Alarming System:				
A	Type of detectors	N/A	N/A	N/A
B	Location of main panel	N/A	N/A	N/A
C	Location of repeater panel	N/A	N/A	N/A
D	Alternate source of power	N/A	N/A	N/A
E	Hooters	N/A	N/A	N/A
08. MOEFA:				
		N/A	N/A	N/A
09. Public Address System:				
		N/A	N/A	N/A
10. Automatic Sprinkler System:				
A	Basement	N/A	N/A	N/A
B	Upper floor	N/A	N/A	N/A
C	Sprinkler above false ceiling	N/A	N/A	N/A
11. Internal Hydrants:				
A	Size of riser/down-comer	N/A	N/A	N/A
B	Number of hydrants per floor	N/A	N/A	N/A
C	Hose box	N/A	N/A	N/A
12. Yard Hydrants:				
A	Total number of hydrants	N/A	N/A	N/A
B	Hose box	N/A	N/A	N/A
13. Pumping Arrangements:				
1. Ground level				
A	Discharge of main pump	N/A	N/A	N/A
B	Head of main pump	N/A	N/A	N/A
C	Number of main pumps	N/A	N/A	N/A
D	Jockey pump out put	N/A	N/A	N/A
E	Jockey pump head	N/A	N/A	N/A
F	Standby pump out put	N/A	N/A	N/A
G	Standby pump head	N/A	N/A	N/A
H	Auto starting /manual stopping	N/A	N/A	N/A
I	Pump house access	N/A	N/A	N/A
2. Terrace Level				
A	Discharge of pump	N/A	N/A	N/A
B	Head of the pump	N/A	N/A	N/A
C	Power supply	N/A	N/A	N/A
D	Auto starting of pump	N/A	N/A	N/A

14. Captive Water Storage for Fire Fighting:				
A	Underground tank capacity	N/A	N/A	N/A
B	Draw-off connection	N/A	N/A	N/A
C	Fire service inlet	N/A	N/A	N/A
D	Access to tank	N/A	N/A	N/A
E	Overhead tank capacity	N/A	N/A	N/A
15. Exit Signage:				
16. Provision of Lifts:				
A	Pressurization of lift shaft	N/A	N/A	N/A
B	Pressurization of lift lobby	N/A	N/A	N/A
C	Communication in lift car	N/A	N/A	N/A
D	Firemen's grounding switch	N/A	N/A	N/A
E	Lift signage	N/A	N/A	N/A
17. Standby Power Supply:				
18. Refuge Area:				
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
19. Fire Control Room:				
A	Detector system panel	N/A	N/A	N/A
B	Flow switch panel	N/A	N/A	N/A
C	PA system panel	N/A	N/A	N/A
D	Battery backup	N/A	N/A	N/A
E	Building floor plans	N/A	N/A	N/A
20. Special Fire Protection systems for protection of special Risks, if any:				
		NA	N/A	N/A

The fire protection system was randomly checked and tested and was found functional at the time of inspection. The earlier shortcomings issued vide letter no. F6/DFS/MS/School/2022/647 dated 19.10.2022 by this department have been rectified by the management.

Keeping in view of the deemed compliance of minimum standards on fire prevention and fire safety measures as required under the Rules the Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/2018/NDZ/1745 dated 27/07/2018 under the Circular no F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 is recommended to be renewed.

No file is pending with me before disposal of this case.


18/6/2024

Signature of the Inspecting Officer
Name: - Yashwant Singh Meena
Designation: - ADO (L.N)

DY. CFO /NDZ - On earned leave.

CFO 
Director 

