


C-6



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001



No F 6 / DFS / MS / 2024 / WZ / 203

Dated 28/06/2024

FIRE SAFETY CERTIFICATE

Certified that **Bhojnam Shree Pvt. Ltd.** located at **Shop No. 207-209, 211, DLF City Centre Mall, Shalimar Bagh, Delhi-110082** is running at **Second Floor** in a building comprised of (**Lower Basement, Upper Basement, Ground plus Five Upper Floors** have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on **24.06.2024** in the presence of **Sh. Abhishek Sharma** and found that the building/ premises is fit for occupancy "**Assembly**" (**Group D**) **Eating House** with effect from 28/06/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on 28/06/2024 at New Delhi by


(Anil Garg)
Director

Ph- 011-23414000

Copy to:-

1. The Owner/ Occupier, M/s Bhojnam Shree Pvt. Ltd. located at Shop No. 207-209, 211, DLF City Centre Mall, Shalimar Bagh, Delhi-110082.
2. MHA Portal ID No. 2024012400814.

Conditions for the validity of Fire Safety Certificate:

1. Fire Safety Certificate is valid for Second Floor only.
2. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
3. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate through MHA portal (<https://www.delehlhlic.gov.in>) along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in
9. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

INSPECTION REPORT

1. Name & address of the building : M/s Bhojnam Shree Private Limited located at Shop No. 207- 209, 211 2nd Floor, DLF City Centre Mall, Shalimar Bagh, Delhi- 110082.
2. Type of Occupancy : Assembly
3. Type of Case : New Case
4. Details of Previous NOC : Nil
5. Fire Safety directives letter No : NBC Part- IV/ UBBL
6. Date of inspection : 24/06/2024
7. Name of Inspecting Officer : R.K.Sinha, ADO (BW)
8. Name and designation of officers
From the building side : Sh. Abhishek Sharma
9. Year of Construction : 2007 as per MHA portal
10. Applicant's letter No. : MHA Portal ID No. 2024012400814 dated 24/05/2024

The said restaurant is running at Second Floor in Shopping Mall comprised of Lower Basement, Upper Basement, Ground plus Five Upper floors, was issued FSC by this department vide letter no. F6/DFS/MS/Mercantile/WZ/2021/549 dated 03/11/2021.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part IV/ UBBL	Provided at site	Remarks
1.	Access to building [Shopping Mall issued FSC vide letter no. F6/DFS/MS/Mercantile/WZ/2021/549 Dated 03/11/2021.]			
	• Road width	12 mts	24 mts	MR
	• Gate width	4.5 mts	05 mts	MR
	• Width of internal road	06 mts	Provided	MR
2.	Number, Width, Type & Arrangement of Exits [Provided and maintained by mall management]			
	a. Number of staircases			
	• Upper Floors	10	Provided	MR
	• Basements	16	Provided	MR
	b. Width of staircases			
	• Upper Floor	2 x 2.0 mts, 8 x 1.5 mts	Provided (Old Case)	MR, Old Case
	• Basements	2 x 2.0 mts, 14 x 1.5 mts	Provided (Old Case)	MR, Old Case
	c. Protection of exits			
	• Fire check door	N/A	Provided	N/A
	• Pressurization	N/A	Provided	N/A
	d. No. of continuous staircases to terrace	N/A	Provided	N/A
	e. Width of Corridor	1.5 mts	Provided	MR
	f. Door Size	1.5 mts	Provided	MR
3.	Compartmentation [Provided and Maintained by Mall Management]			
	• Fire check door	N/A	Provided	N/A
	• Sealing of electrical shafts	N/A	Provided	N/A
	• Fire Rating of shaft door	N/A	Provided	N/A
	• Water Curtain	N/A	Provided	N/A
	• Fire Dampers	N/A	Provided	N/A
4.	Smoke Management System [Provided and Maintained by Mall Management]			
	• Basements	N/A	Provided	N/A
	• Upper floor	Required in Basement	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	04	06	MR
	• Types	ABC/CO ₂ Type	Provided	MR
	• IS marking	Required	Provided	MR
6.	First-Aid Hose Reels [Provided & Maintained by Mall Management]			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR

h

N-2

7.	Automatic fire detection and alarming system [Provided & Maintained by Mall Management]			
	• Type of detectors	Required	Provided	MR
	• Location of Main Panel	Required	Provided at GF	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	N/A	Provided	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System [Provided & Maintained by Mall Management]			
	• Basement	N/A	Provided	N/A
	• Upper Floors	Required	Provided	MR
	• Sprinkler above false ceiling	Required	Provided	MR
11.	Internal Hydrants [Provided & Maintained by Mall Management]			
	• Size of riser/down-comer	150 mm	Provided	MR
	• Number of hydrants per floor	01	Provided (04)	MR
	• Hose Box	01	Provided (04)	MR
12.	Yard Hydrants [Provided & Maintained by Mall Management]			
	• Total number of hydrants	06	Provided	MR
	• Hose Box	06	Provided	MR
13.	Pumping Arrangements [Provided & Maintained by Mall Management]			
	• Ground Level			
	➤ Discharge of main Pump	NA	4500 LPM	NA
	➤ Head of Main pump	NA	60 mts	NA
	➤ Number of main pumps	NA	03	NA
	➤ Jockey Pump out put	NA	02 x 180 LPM	NA
	➤ Jockey pump head	NA	60 mts	NA
	➤ Standby Pump out put	NA	4500 LPM	NA
	➤ Standby Pump Head	NA	60 mts	NA
	➤ Auto Starting/Manual Stopping	NA	Provided	NA
	➤ Pump House Access	NA	Provided	NA
	• Terrace level	[Provided & Maintained by Mall Management]		
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14.	Captive Water Storage for fire fighting [Provided & Maintained by Mall Management]			
	• Underground tank capacity	NA	Provided (300000 lts)	NA
	➤ Draw-off connection	NA	Provided	NA
	➤ Fire service inlet	NA	Provided	NA
	➤ Access to tank	NA	Provided	NA
	• Overhead Tank capacity	20,000 lts	Provided (30,000 lts)	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts. [Provided & Maintained by Mall Management]			
	• Pressurization of Lift Shaft	NA	Provided	NA
	• Pressurization of Lift lobby	NA	Provided in basement floor	NA
	• Communication In lift Car	NA	Provided	NA
	• Fireman's Grounding Switch	NA	Provided	NA
	• Lift Signage	NA	Provided	NA

W

17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire Control Room	[Provided & Maintained by Mall Management]		
	• Detector System Panel	NA	Provided	NA
	• Flow Switch Panel	NA	Provided	NA
	• PA System Panel	NA	Provided	NA
	• Battery backup	NA	Provided	NA
	• Building Floor Plans	NA	Provided	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	Required	CO ₂ flooding system provided in DG Room	MR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of satisfactory compliance of the minimum standards of fire prevention and fire safety measures as required under rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules, 2010.

Rajeev Kumar Sinha
26/6/24

Signature of Inspecting Officer
Name : Rajeev Kumar Sinha
Designation : ADO/B.W.

Dy Cfo (wz)

[Signature]
26/6/2024

CFO - on leave

[Signature]
Director
27/6/24

[Signature]

uploaded
28/6/24

DCFO: 314-MHA
Dated: 26/06/24