



C-30

②

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F6/DFS/MS/2024/School/ W2/586

Dated: 27/06/2024

**FIRE SAFETY CERTIFICATE**

Certified that **Govt. Co-ed Secondary School (I.D-1309302)** located at **Bhalaswa Village, Delhi-110042** comprised of **Ground and 01 upper floor only** owned/ occupied by **Govt. Co-ed Secondary School** was granted FSC by this department vide letter No. **F6/DFS/MS/2021/317** dated **08.04.2021**. The premises was re-inspected by the officer concerned of this department on **06.06.2024** in presence of **Sh. V.K. Yadav (Vice-Principal)** and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class **Group B Educational** with effect from 27/06/2024 for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on 27/06/2024 at New Delhi by

(Anil Garg)

Director

Ph:-011-23414000

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Principal, Govt. Co-ed. Secondary School, Bhalaswa Village, Delhi-110042 .

**Conditions for the validity of Fire Safety Certificate:**

- 1 All the means of escape/entry/exit shall be kept free from any obstruction.
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
- 3 All the staff members must know the correct method of operation of firefighting system.
- 4 The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doi/fire/FIRE/Home/Forms>.
- 5 This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
- 6 "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

**INSPECTION REPORT**

1. Name & address of the building : Govt. Co-ed. Secondary School, Bhalaswa Village, Delhi-110042 . (I.D-1309302)
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Composition of building : Ground & First Floor Only
5. Details of previous NOC : F6/DFS/MS/2021/317 dated 08.04.2021
6. Fire Safety directives letter No : Director of Education Circular dated 01.03.2011
7. Date of inspection : 06.06.2024
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers from the building side : Sh. V.K. Yadav (Vice-Principal)
10. Year of Construction : 2013
11. Applicant's letter No. : Online E-Mail I.D Dated-03.06.2024

Plot Area-9847m<sup>2</sup>      Covered Area:1696.m<sup>2</sup>      No. Class Room- 16      No. Student-1245

|              | Minimum Standards on fire prevention and fire safety U/R 33 | Director of education circular dated 01.03.2011 Requirements | Provided at site | Remarks MR/NMR |
|--------------|---|--|------------------|----------------|
| 1            | <b>Access to building</b>                                   |  |                  |                |
|              | • Road width  | 06m  | 06m              | MR             |
|              | • Gate width  | 4.50m  | 4.50m            | MR             |
|              | • Width of internal road                                    | NA   | NA               | NA             |
| 2            | <b>Number, Width, Type &amp; Arrangement of Exits</b>       |  |                  |                |
|              | a. Number of staircases                                     |  |                  |                |
|              | • Upper Floors  | 02   | 02               | MR             |
|              | • Basements   | NA   | NA               | NA             |
|              | b. Width of staircases                                      |  |                  |                |
|              | • Upper Floors  | 1.5m each  | 1.5m each        | MR             |
|              | • Basements   | NA   | NA               | NA             |
|              | c. Protection of exits                                      |  |                  |                |
|              | • Fire check door   | NA   | NA               | NA             |
|              | • Pressurization  | NA   | NA               | NA             |
|              | d. No. of continuous staircases to terrace                  | NA   | NA               | NA             |
|              | e. Width of Corridor  | NA   | NA               | NA             |
| f. Door Size | 1m  | 1m double door   | MR               |                |
| 3            | <b>Compartmentation.</b>                                    |  |                  |                |
|              | • Fire check door   | NA   | NA               | NA             |
|              | • Sealing of electrical shafts                              | NA   | NA               | NA             |
|              | • Fire Rating of shaft door                                 | NA   | NA               | NA             |
|              | • Water Curtain   | NA   | NA               | NA             |
|              | • Fire Dampers  | NA   | NA               | NA             |
| 4            | <b>Smoke Management System.</b>                             |  |                  |                |
|              | • Basements   | NA   | NA               | NA             |
|              | • Upper floors  | NA   | NA               | NA             |
| 5            | <b>Fire Extinguishers.</b>                                  |  |                  |                |
|              | • Total numbers   | 10nos  | 12 nos           | MR             |



|    |   | ABC/Co2    | ABC-12 |     |
|----|---|------------|--------|-----|
|    | <ul style="list-style-type: none"> <li>Types</li> <li>ISI marking</li> </ul>  | ISI Marked | Yes    |     |
| 6  | <b>First-Aid Hose Reels.</b>  |            |        |     |
|    | <ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>  | NA         | NA     | NA  |
|    |   | NA         | NA     | NA  |
|    |   | NA         | NA     | NA  |
| 7  | <b>Automatic fire detection and alarming system.</b>  |            |        |     |
|    | <ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>   | NA         | NA     | NA  |
|    |   | NA         | NA     | NA  |
|    |   | NA         | NA     | NA  |
|    |   | NA         | NA     | NA  |
|    |   | NA         | NA     | NA  |
| 8  | <b>MOEFA</b>  | NA         | NA     | NA  |
| 9  | <b>Public Address System.</b>   | NA         | NA     | NA  |
| 10 | <b>Automatic Sprinkler System.</b>  |            |        |     |
|    | <ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>  | NA         | NA     | NA  |
|    |   | NA         | NA     | NA  |
|    |   | NA         | NA     | NA  |
| 11 | <b>Internal Hydrants</b>  |            |        |     |
|    | <ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>  | NA         | NA     | NA  |
|    |   | NA         | NA     | NA  |
|    |   | NA         | NA     | NA  |
| 12 | <b>Yard Hydrants.</b>   |            |        |     |
|    | <ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>  | NA         | NA     | NA  |
|    |   | NA         | NA     | NA  |
| 13 | <b>Pumping Arrangements.</b>  |            |        |     |
|    | <ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/ Manual stopping</li> <li>Pump House Access</li> </ul> </li> <li>Terrace level <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul> | N/A        | N/A    | N/A |
|    |   | N/A        | N/A    | N/A |
|    |   | N/A        | N/A    | N/A |
|    |   | N/A        | N/A    | N/A |
|    |   | N/A        | N/A    | N/A |
|    |   | N/A        | N/A    | N/A |
|    |   | N/A        | N/A    | N/A |
|    |   | N/A        | N/A    | N/A |
|    |   | N/A        | N/A    | N/A |
|    |   | N/A        | N/A    | N/A |
|    |   | N/A        | N/A    | N/A |
|    |   | N/A        | N/A    | N/A |
|    |   | N/A        | N/A    | N/A |
|    |   | N/A        | N/A    | N/A |
| 14 | <b>Captive Water Storage for fire fighting.</b>   |            |        |     |
|    | <ul style="list-style-type: none"> <li>Underground tank capacity</li> </ul>   | NA         | NA     | NA  |

|    |   |     |     |     |
|----|---|-----|-----|-----|
|    | ▶ Draw-off connection   | NA  | NA  | NA  |
|    | ▶ Fire service inlet  | NA  | NA  | NA  |
|    | ▶ Access to tank  | NA  | NA  | NA  |
|    | • Overhead Tank capacity  | NA  | N/A | NA  |
| 15 | <b>Exit Signage.</b>  | NA  | NA  | NA  |
| 16 | <b>Provision of Lifts.</b>  |     |     |     |
|    | • Pressurization of Lift Shaft  | N/A | N/A | N/A |
|    | • Pressurization of Lift lobby  | N/A | N/A | N/A |
|    | • Communication In lift Car   | N/A | N/A | N/A |
|    | • Fireman's Grounding Switch  | N/A | N/A | N/A |
|    | • Lift Signage  | N/A | N/A | N/A |
| 17 | <b>Standby power supply</b>   | N/A | N/A | N/A |
| 18 | <b>Refuge Area.</b>   |     |     |     |
|    | ▶ Total Area  | N/A | N/A | N/A |
|    | ▶ Location  | N/A | N/A | N/A |
| 19 | <b>Fire Control Room</b>  |     |     |     |
|    | • Detector System Panel   | N/A | N/A | N/A |
|    | • Flow Switch Panel   | N/A | N/A | N/A |
|    | • PA System Panel   | N/A | N/A | N/A |
|    | • Batter backup   | N/A | N/A | N/A |
|    | • Building Floor Plans  | N/A | N/A | N/A |
| 20 | <b>Special Fire Protection Systems for Protection of special Risks, if any:</b> | N/A | N/A | N/A |

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011, it is recommended to renewal of fire safety certificate issued vide this department letter of even no. F6/DFS/MS/2021/317 dated 08.04.2021.

*sp/dfs/wz  
26/6/2024*

*[Signature]*  
Dy. Chief Fire Officer (WZ)

*[Signature]*  
18/6/2024

*[Signature]*  
19/6/2024

*[Signature]*  
20/6/2024

*[Signature]*

*[Signature]*  
Signature of the Inspecting Officer  
Name:- C.L. Meena  
Designation:- Asst. Div. Officer (RN)