



C-5

75
आजादी का
अमृत महोत्सव

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/EH/WZ/2024/ 205

Dated: 28/06/2024

FIRE SAFETY CERTIFICATE

Certified that the **Pirates of Grill, (A unit of Holy Something Restaurant LLP)**, located at Shop No. SH- 2F - 02, Second floor, Pacific Mall, Tagore Garden, Najafgarh Road, New Delhi-110018, is running at second floor in Pacific Mall Subash Nagar comprised of 02 Basement + Ground + 04 upper floors & projection room was issued FSC by this department vide letter No. F6/DFS/MS/WZ/Mall/2023/349 dated 21/07/2023. The premises was inspected by the officer concerned of this department on 18/06/2024 in the presence of Sh. Saurabh Gupta and found that the said premises/building have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises/building is fit for occupancy class "Assembly" (Group-D) and validity upto 31/03/2027 in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010. Conditions Printed Overleaf.

Issued on 28/06/2024 at New Delhi by.


(Atul Garg)
Director

 26/6/24
 26/6/24

Copy to: -

1. The owner/occupier, Pirates of Grill, (A unit of Holy Something Restaurant LLP), located at Shop No. SH- 2F - 02, Second floor, Pacific Mall, Tagore Garden, Najafgarh Road, New Delhi-110027.
2. The Joint Commissioner of Police, Licensing Unit, 1st floor, Police Station, Defence Colony, New Delhi. (addlcp.lic-dl@nic.in)
3. The Dy. Health Officer, MCD, West Zone, Vishal Enclave, Rajouri Garden, New Delhi 110027. (dhowest_zone@gmail.com)

INSPECTION REPORT

1. Name & address of the building	Pirates of Grill, (A unit of Holy Something Restaurant LLP) located at Shop No. SH- 2F - 02, Second floor, Pacific Mall Tagore Garden, Najafgarh Road, New Delhi-110018.
2. Type of Occupancy	Assembly
3. Type of Case	New
4. Details of previous NOC	Nil
5. Fire Safety directives letter No	NBC Part - IV
6. Date of inspection	18/06/2024
7. Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8. Name and designation of officers from the building side	Sh. Saurabh Gupta
9. Year of Construction	2010 (As per MHA Portal)
10. Applicant's letter No.	Online Application ID No. 2024052408114 dated 31/05/2024

The Said Restaurant is running at second floor in Pacific Mall Comprised of 02 Basement + Ground + 04 upper floors & projection room, was issued FSC by this department vide letter No. F6/DFS/MS/WZ/Mall/2023/349 dated 21/07/2023.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL / NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 m	30m Provided	MR
	• Gate width	05m	Provided	MR
	• Width of internal road	06m	Provided	MR
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	Provided by Mall	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.5m each	Provided by Mall	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	NA	NA	NA
	f. Width of Corridor	NA	NA	NA
	g. Door Size	2m & 1.5m	2m & 1.5m Provided	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	Required	Provided	MR
5	Fire Extinguishers			
	• Total numbers	05 Nos.	Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

16			
6	First-Aid Hose Reels.	Common with Mall	
	• Total numbers on each floor	01	Provided by Mall
	• Length of hose reel hose	30m	Provided by Mall
	• Nozzle diameter	5mm	Provided by Mall
7	Automatic fire detection and alarming system.		
	• Type of detectors	Smoke & Heat	Provided & connected with the Mall
	• Location of Main Panel	Required at G.F.	Provided by Mall
	• Location of Repeater Panel	Required	Provided by Mall
	• Alternate source of power	Required	Provided by Mall
	• Hooters' Location	Required	Provided by Mall
8	MOEFA	Required	Provided & connected with the Mall
9	Public Address System.	NA	NA
10	Automatic Sprinkler System.	Common with Mall	
	• Basement	NA	Provided
	• Upper Floor	NA	Provided
	• Sprinkler above false ceiling	NA	Provided
11	Internal Hydrants	Common with Mall	
	• Size of riser/down-comer	NA	Provided
	• Number of hydrants per floor	NA	Provided
	• Hose Box	NA	Provided
12	Yard Hydrants.		
	• Total number of hydrants	NA	NA
	• Hose Box	NA	NA
13	Pumping Arrangements.	Common With Mall	
	• Ground Level		
	➤ Discharge of main Pump	NA	Common With Mall
	➤ Head of Main pump	NA	Common With Mall
	➤ Number of main pumps	NA	Common With Mall
	➤ Jockey Pump out put	NA	Common With Mall
	➤ Jockey pump head	NA	Common With Mall
	➤ Standby Pump out put	NA	Common With Mall
	➤ Standby Pump Head	NA	Common With Mall
	➤ Auto Starting/ Manual stopping	NA	Common With Mall
	➤ Pump House Access	NA	Common With Mall
	• Terrace level		
	➤ Discharge of pump	900 lpm	Common With Mall
	➤ Head of the pump	40 m	Common With Mall
	➤ Power Supply	Required	Common With Mall
	➤ Auto Starting of pump	Required	Common With Mall
14	Captive Water Storage for fire fighting.	Common With Mall	
	• Underground tank capacity	NA	2,00,000 ltrs Provided
	➤ Draw-off connection	NA	Provided
	➤ Fire service inlet	NA	Provided
	➤ Access to tank	NA	Provided
	• Overhead Tank capacity	10,000 ltrs	30,000 ltrs Provided
15	Exit Signage.	Required	Provided

2/3

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	Required	Provided by Mall	MR
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

68/ADO/MN
20/6/2024

DYC (20/w/2)

SP
20/6/2024

Signature of the Inspecting Officer
Name: Sarabjeet Singh
Designation: ADO (MN)

See the plan.

Second exit is passing through kitchen & it is not allowed. put up shortcoming.

XFOI... 304
Dated... 21/6/2024

ADO (MN)

SP
21/6

Sir, Second exit is not passing through kitchen, it is opening in fire exit of mall. resubmitted pls.

SP
26/6/2024