

C-89

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/School/2024/SW2/593

Dated: 27/06/2024

FIRE SAFETY CERTIFICATE

Certified that the Building Shree Venkateshwar International School, Located at Sector 18, Dwarka, New Delhi 110075 comprised of Basement + Ground + 3 Upper Floor was issued FSC vide Letter No. F6/DFS/MS/School/2021/437, dated 06/07/2021. The premises was re inspected by the officers concerned of this department on 20-06-2024 in the presence of Sh. Nagender Solanki and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class-B "Educational" with effect from 27/06/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010

Issued on 27/06/2024 at New Delhi by.

(Atul Garg)
Director
Delhi Fire Service
27/06/24

Copy to:

1. The Principal Shree Venkateshwar International School, Located at Sector 18, Dwarka, New Delhi 110075.
2. The, Directorate of Education Old Secretariat Delhi - 110054.

Following fire safety directives must be adhered to:-

1. **Two temporary rooms are seen at terrace. The Rooms shall not be used for school activities, as per undertaking submitted by owner.**
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. Basement shall be used strictly as per building bye laws.
9. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

N/27
INSPECTION REPORT

1. Name & address of the building: Shree Venkateshwar International School, Located at Sector 18, Dwarka, New Delhi 110075.
2. Type of Occupancy : Educational (Basement + Ground+ 3 Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2021/437, dated 06/07/2021
5. Fire Safety directives Letter No. : F6/DFS/MS /2007/1542 Dated 08/06/2007
6. Date of inspection : 20-06-2024
7. Name of the Inspecting Officer : DO/SW & ADO (DWK)
8. Name and designation of Officer
from the building side : Sh. Nagender Solanki
9. Year of Construction : 2007
10. Applicant's letter No. : Email dated 31/05/2024

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/18, N/19 & N/20	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtr	Provided	MR
	• Gate width	4.5 mtr	Provided	MR
	• Width of internal road	NA	NA	NA.
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	4 Nos.	4 Nos.	MR
	• Basements	6 Nos.	6 Nos.	MR
	b. Width of staircases			
	• Upper floors	1.5 mtr	1.5 mtr	MR
	• Basements	1.5 mtr	1.5 mtr	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	04 Nos.	04 Nos.	MR
	e. Width Of Corridor	1.5m	1.80 mtr	MR
	f. Door Size	01 mtr	1.05 mtr	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	30 a/c charge	Exhaust fans provided	MR
	• Upper floors	12 a/c charge	Natural ventilation	MR



5.	Fire Extinguishers				MR
	• Total numbers	24 nos.	Provided		MR
	• Types	ABC & CO ₂	ABC & CO ₂		MR
	• IS marking	ISI marked	ISI marked		MR
6.	First – Aid Hose Reels				MR
	• Total numbers on each floor	02	Provided		MR
	• Length of hose reel hose	30	Provided		MR
	• Nozzle diameter	05 mm	Provided		MR
7.	Automatic fire detection and alarming system				
	• Type of detectors	Required	Provided in basement		MR
	• Location of Main Panel	Ground floor	Provided in basement		MR
	• Location of Repeater Panel	NA	NA		NA
	• Alternate source of power	Required	DG Set 160 KVA		MR
	• Hooters' Location	Appropriate place	Near Staircase		MR
8.	MOEFA	Required	Provided		MR
9.	Public Address System	Required	Provided		MR
10.	Automatic Sprinkler System				
	• Basements	Required	Provided		MR
	• Upper Floor	NA	NA		NA
	• Sprinkler above false ceiling	NA	NA		NA
11.	Internal Hydrants:				
	• Size of riser/down-comer	100 mm	100 mm		MR
	• Number of hydrants per floor	02	02		MR
	• Hose Box	Required	Provided		MR
12.	Yard Hydrants				
	• Total number of hydrants	02 Nos.	02 Nos.		MR
	• Hose Box	Required	Provided		MR
13.	Pumping Arrangements:				
	• Ground Level	NA	NA		NA
	• Discharge of main pump	NA	NA		NA
	➤ Head of main pump	NA	NA		NA
	➤ Number of main pumps	NA	NA		NA
	➤ Jockey pump out put	NA	NA		NA
	➤ Jockey pump head	NA	NA		NA
	➤ Standby Pump out put	NA	NA		NA
	➤ Standby Pump Head	NA	NA		NA
	➤ Auto starting/Manual stopping	NA	NA		NA
	➤ Pump House Access	NA	NA		NA
	• Terrace level				
	➤ Discharge of pump	450 lpm & 180 lpm	Provided		MR
	➤ Head of the pump	30 mtr	Provided		MR
	➤ Power supply	Required	Provided		MR
	➤ Auto starting of pump	Required	Provided		MR



14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	50000 ltrs	50000 ltr	MR
	➤ Draw off connection	NA	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	50000 ltrs	Provided	MR
15.	Exit Signage	Required	Found removed at some places	MR
16.	Provision of Lifts (Lift Shall run from Ground to Upper Floors)			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	DG set 160 KVA	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	ABC, Fire extinguisher provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter No. F6/DFS/MS/School/2021/437, dated 06/07/2021 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended. If approved, the FSC may be issued.

Signature of the Inspecting Officer
Name: Sh. Vedpal
Designation: DO/SW

Signature of the Inspecting Officer
Name: Udai Vir Singh
Designation: ADO/DWK

Cfo (S2)
24/6/2024
Director
24/6/24

Any/any

b.