

C90



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001


No. F6/DFS/MS/2024/School/ 584

Dated: 27/06/2024

FIRE SAFETY CERTIFICATE

Certified that **Tagore International Public School** located at **Gali No-6, Sangam Vihar, Wazirabad, Delhi-110084 110042** comprised of **Ground & first floors only** owned/ occupied by the **Tagore International Public School** was issued fire safety certificate vide this office letter no. **F6/DFS/MS/2016/1190 Dated 22.07.2016**. The premises was inspected by the officer concerned of this department on **19.06,2024** in the presence of **Sh. B.P. Sharma (Manager)** and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy Group B Educational with effect from ... **27/06/2024** for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on **27/06/2024** at New Delhi by.


(Atul Garg)
Director
Ph:-011-23414000
etc

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Manager, Tagore International Public School located at Gali No-6, Sangam Vihar, Wazirabad, Delhi-110084 110042.

Conditions for the validity of Fire Safety Certificate:

- 1 All the means of escape/entry/exit shall be kept free from any obstruction.
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
- 3 All the staff members must know the correct method of operation of firefighting system.
- 4 The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [http://delhi.gov.in/wps/wcm/connect/doit fire/FIRE/Home/Forms](http://delhi.gov.in/wps/wcm/connect/doit/fire/FIRE/Home/Forms).
- 5 This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
- 6 "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

N/15
INSPECTION REPORT

1. Name & address of the building : Tagore International Public School, Gali No. 6, Sangam Vihar, Wazirabad, Delhi-110084.
2. Compositio of building : Ground & First Floor only
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/2016/1190 dated 22.07.2016
6. Fire Safety directives letter No : Director of Education Letter dated 01.03.2011.
7. Date of inspection : 19.06.2024
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers
from the building side : Sh. B.P.Sharma, Manager
10. Year of Construction : --
11. Applicant's letter No. : Online E-mial dated 11.06.2024

Plot Area-400 Sqm Covered area —400 sqm , No of student—200 nos, Total class room —11 nos

	Minimum Standards on fire prevention and fire safety U/R 33	Director of education circular dated 01.03.2011 Requirements	Provided at site	Remarks MR/NMR
1	Access to building.			
	• Road width	06m	05m	MR(bieng old case)
	• Gate width	4.5m	02m	MR(bieng old case)
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits.			
	a. Number of staircases			
	• Upper Floors	01	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50m or less and 75cm	1.20m & 75cm	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.0m	1.0m	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	Fire Extinguishers			

	<ul style="list-style-type: none"> Total numbers Types ISI marking 	N/16 04nos	04 nos	MR
		ABC/Co2	ABC-04	MR
		Yes	Yes	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor 	01	01	MR
	<ul style="list-style-type: none"> Length of hose reel hose 	30m	30m	MR
	<ul style="list-style-type: none"> Nozzle diameter 	5mm	5mm	MR
7	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors 	NA	NA	NA
	<ul style="list-style-type: none"> Location of Main Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Alternate source of power 	NA	NA	NA
	<ul style="list-style-type: none"> Hooters' Location 	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement 	NA	NA	NA
	<ul style="list-style-type: none"> Upper Floor 	NA	NA	NA
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	NA	NA	NA
	<ul style="list-style-type: none"> Number of hydrants per floor 	NA	NA	NA
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	<ul style="list-style-type: none"> Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	Required	220 LPM	MR(bieng old case)
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity 	NA	NA	NA
	<ul style="list-style-type: none"> Draw-off connection 	NA	NA	NA
	<ul style="list-style-type: none"> Fire service inlet 	NA	NA	NA

	<ul style="list-style-type: none"> ➤ Access to tank • Overhead Tank capacity 	NA	NA	NA
15	Exit Signage.	Required	2500 LTR	MR (bieng old case)
16	Provision of Lifts.	Required	Provided	MR
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection. The management has complied all the shortcomings issued and communicated by this department vide letter of even no. F6/DFS/MS/2024/School/328 dated 12.06.2024.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011, it is recommended to renewal of fire safety certificate issued vide this department letter of even no. F6/DFS/MS/2016/1190 Dated: 22.07.2016.

SECRET
1023
21/06/2024

Dy. Chief Fire Officer (WZ)

[Signature]
21/6

[Signature]
21/6/2024

Director *[Signature]*
25/6/24

[Signature]
Signature of the Inspecting Officer
Name :- C.L. Meena
Designation:- ADO/RN

[Signature] *[Signature]*