

c 80

-15

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**  
No.F6/DFS/MS/GH/NDZ/2024/269 Dated: 05/07/2024

**FIRE SAFETY CERTIFICATE**

Certified that the Millennium 2000 Dx. Guest House located at 3695, Dariba Pan, Pahar Ganj, New Delhi comprised of Basement + Ground + 04 Upper floors, Basement (Storage), Ground floor (Reception + 02 guest rooms), 1<sup>st</sup> floor to 3<sup>rd</sup> floor (10 guest rooms + 01 store room at each floor), 4<sup>th</sup> floor & above floor a not in use as per affidavit dated 16/10/19 total 32 guest rooms up to third floor only owned/occupied by Millennium 2000 Dx. Guest House was earlier granted FSC by this department vide letter No.F6/DFS/MS/GH/NDZ/2021/442 dated 29/09/21. Now, the premise was re-inspected by the officer concerned of this department on 25/06/24 in the presence of Manager and found that the said guest house building has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Residential, Sub Division-A-1 Ground floor (Reception + 02 guest rooms), 1st floor to 3rd floor (10 guest rooms + 01 store room at each floor) Total- 32 guest rooms up to third floor only and valid up to 31.03.2027 from the date of issue in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on ..05/07/2024..... at New Delhi by.

  
(Atul Karg)  
DIRECTOR  
Delhi Fire Service

**Copy to:-**

1. The Commissioner, North MCD, Civic Centre, New Delhi. : to ensure that not to use any floor above third floor for any purpose
2. The Addl. Commissioner of Police (Lic), First Floor, P.S. Defence Colony, New Delhi ref. id no.2024061209245 dated 12/06/24.
3. The Manager, Millennium 2000 Dx. Guest House at 3695, Dariba Pan, Pahar Ganj, New Delhi.

**Condition for the validity of fire safety certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.
9. Any flammable material for interior decoration is prohibited. 4<sup>th</sup> floor shall not be used for any purpose.

2/29  
**INSPECTION REPORT**

1. Name & address of the building Millennium 2000 Dx. Guest House at 3695, Dariba Pan, Pahar Ganj, New Delhi
2. Type of occupancy:- Residential, Sub Division-A-1  
B + Gr. + 04 Upper floors (total 32 Guest rooms)  
Basement (Storage), Ground floor (Reception + 02 guest rooms), 1<sup>st</sup> floor to 3<sup>rd</sup> floor (10 guest rooms + 01 store room at each floor) and 4<sup>th</sup> floor found sealed and an affidavit dated 16.10.2019 given by owner regarding not to use any floor above third floor.
3. Type of case:- Renewal
4. Details of previous FSC:- No F6/DFS/MS/GH/NDZ/2021/442 dated 29/09/21
5. Fire safety directives No.- N/A
6. Date of inspection:- 25/06/24.
7. Name of the inspecting officer:- Sh. Ravinder Singh (ADO/CC)
8. Name & designation of officer  
From the building side:- Manager
9. Year of construction:- 2002
10. Applicant's letter No:- Id no. 2024061209245 dated 12/06/24.

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ Existing fire safety arrangements	Provided at site	Remarks MR/NMR
<b>1. Access to Building</b>				
	1) Road width	N/A	06 mtr.	N/A
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
<b>2. Number, Width Type &amp; Arrangement of Exits</b>				
<b>A. Number of staircases</b>				
	1. Upper floors	01 No.	01 No.	MR
	2. Basements	01 No.	01 No.	MR
<b>B. Width of staircase</b>				
	1. Upper floors	0.80 mtr.	1.20 to 1.22 mtr.	MR
	2. Basements	0.80 mtr.	1.0 to 1.20 mtr.	MR
<b>C. Protection of exits</b>				
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	N/A	N/A	N/A
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	01 mtr.	01 mtr.	MR
<b>3. Compartmentation</b>				
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
<b>4. Smoke Management System</b>				
	1) Basements	30 ACPH	Exhaust fan	N/A
	2) Upper floors	12 ACPH	Natural / exhaust fan	MR
<b>5. Fire Extinguishers</b>				
	1) Total numbers	12 Nos.	12 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR

6

N/30

	3) ISI marking	Required	Provided	
<b>6.</b>	<b>First-Aid Hose Reel</b>			
	1) Total number of each floor	01	01	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR
<b>7.</b>	<b>Automatic Fire Detection &amp; Alarming System</b>			
	1) Type of detectors CO type	Required	Provided	MR
	2) Location of main panel	Gr. floor	Provided	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	Gr. floor	Provided	MR
<b>8.</b>	<b>MOEFA</b>	Required	Provided	MR
<b>9.</b>	<b>Public Address System</b>	Required	Provided	MR
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	1) Basement	Required	Provided	MR
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
<b>11.</b>	<b>Internal Hydrants</b>			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
<b>12.</b>	<b>Yard Hydrants</b>			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
<b>13.</b>	<b>Pumping Arrangement</b>			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump output	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	450 LPM	MR
	b) Head of pump	30 mtr.	30 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
<b>14.</b>	<b>Captive Water Storage for Fire Fighting</b>			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	5,000 ltr.	5,000 ltr.	MR

15.	Exit Signage.	Required	Provided ✓	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	Required	Provided	MR
	d) Fireman's switch	Required	Provided ✓	MR
	e) Lift signage	Required	Provided ✓	MR
17.	Stand by Power Supply	Required	Provided ✓	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any: One ABC type fire extinguisher found provided.			MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if agreed, we may renew the FSC issued vide letter No. F6/DFS/MS/GH/NDZ/2021/442 dated 29/09/21, under rule 35(6) of the Delhi Fire Service Rules 2010. Accordingly, DFA is put up for kind perusal and signature please.

Signature of the Inspecting Officer

*[Handwritten Signature]*  
26/6/24

Name: - Ravinder Singh  
Designation: - ADO (CC)

DO/CD

*[Handwritten Signature]*  
26/6/24

*[Handwritten Signature]*  
Dy. C.S. (N/31)

*[Handwritten Signature]*  
29/06/24

C.F.O.

*[Handwritten Signature]*  
17/7/2024

Director  
*[Handwritten Signature]*  
13/07/24

As approved, FSC put up for kind perusal and signature please.

*[Handwritten Signature]*  
17/7/24