

C-64

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/GH/NDZ/2024/ 267

Dated: 05/07/2024

FIRE SAFETY CERTIFICATE

Certified that the M/s Al-Shahansha Guest House situated at 5190, Ballimaran, Chandni Chowk, Delhi-06, comprised of Ground floor + 4 upper floors, Ground floor (commercial use), 1st floor - (06 guest room), 2nd floor - (06 guest room), 3rd floor - (06 guest rooms), with total of 18 guest rooms was granted FSC by this department vide letter no. F6/DFS/MS/GH/NDZ/2021/37 dated 29.01.2021. The building/premises was re-inspected by the officer concerned of this department on 27.06.2024 in presence of Mr. Afaq Khan (Manager) and found that the building is comprised of ground + 04 upper floors and now the floor wise occupancy is ground floor - (commercial use), 1st floor - (06 guest room), 2nd floor - (06 guest room), 3rd floor - (06 guest rooms) & 4th floor - (not in use as per affidavit dated 27.06.2024). The building/premises has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010. Accordingly, the premises is fit for occupancy of "Residential Group-A-1" 1st floor - (06 guest rooms), 2nd floor - (06 guest rooms), 3rd floor - (06 guest rooms) for total 18 guest rooms upto 3rd floor only with effect from05/07/2024. for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to conditions under rule 38 of Delhi Fire Service Rules, 2010 subject to condition printed below.

Issued on05/07/2024.....at New Delhi by


(Atul Garg)

Director

Delhi Fire Service

Tel: 011-23414000

Copy to:-

1. The Commissioner, MCD:- to kindly ensure the occupancy as detailed above & deviation, if any.
2. The Joint Commissioner of Police (Licensing), 1st Floor, Police Station Defence Colony, New Delhi. w.r.to ID No. 2024061109190 dated 11.06.2024.
3. The Licensee, M/s Al-Shahansha Guest House situated at 5190, Ballimaran, Chandni Chowk, Delhi-06.

Conditions for the validity of fire safety certificate:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry". Any change in the occupancy shall be intimated to this Dept. and approval shall be obtained there to before occupancy of the same.
8. The occupancy of above 3rd floor not allowed as per clause 7.31 in UBBL-2016.

INSPECTION REPORT

1	Name & address of the building	M/s Al-Shahansha Guest House located at 5190, Ballimaran, Chandni Chowk, Delhi-06.		
2	Building is comprised of	Ground + 04 upper floors Ground floor – (commercial use) 1 st floor – (06 guest rooms) 2 nd floor – (06 guest rooms) 3 rd floor – (06 guest rooms) 4 th floor – (not in use as per affidavit dated 27.06.2024)		
3	Type of occupancy	Residential Group A-1		
4	Type of case	Renewal (old case)		
5	Details of previous FSC	F6/DFS/MS/GH/NDZ/2021/37 dated 29.01.2021		
6	Fire safety direction letter no.	Nil		
7	Date of inspection	27.06.2024		
8	Name of the inspecting officers	Sh. Sumit Kumar, ADO (SPM)		
9	Name of the designation of officer from the building side	Mr. Afaq Khan (Manager)		
10	Year of construction	2010		
11	Applicant's letter no.	Online application no. 2021081718009 dated 11.06.2024		
S.No	Minimum Standards on fire Prevention and fire safety requirements U/R 33	Requirement/ Existing fire safety arrangements	Provided at Site	Remarks MR/ NMR
1	Access To Building:			
	Road width	NA	06 mtr. ✓	NA
	Gate width	NA	NA	NA
	Width of internal road	NA	NA	NA
2	Number, Width, Type and Arrangement of Exits:			
A	Number of staircases			
a	Upper floor	01 no.	01 no. ✓	MR
b	Basement	NA	NA	NA
B	Width of staircases			
a	Upper floor	125 cms	125cms ✓	MR
b	Basement	NA	NA	NA
C	Protection of exits			
a	Fire check door	NA	NA	NA
b	Pressurization	NA	NA	NA
D	No. of continuous staircases to terrace	01 nos.	01 nos. ✓	MR
E	Width of corridor	NA	NA	NA
F	Door size	1 mtr.	1 mtr. ✓	MR
3	Compartmentation:			
A	Fire check door	NA	NA ✓	NA
B	Sealing of electrical shafts	NA	NA	NA
C	Fire rating of shaft door	NA	NA	NA
D	Water curtain	NA	NA	NA
E	Fire dampers	NA	NA	NA
4	Smoke Management System:			
A	Basement	12 ACPH	NA ✓	NA
B	Upper floor	12 ACPH	Provided (E. fan)	MR

6 Su

5.	Fire Extinguisher:			
A	Total numbers	06 nos.	06 nos. /	MR
B	Types	ABC & CO ₂	ABC & CO ₂	MR
C	ISI marking	Required	Provided	MR
6	First-Aid-Hose Reels:			
A	Total numbers of each floor	01 no.	01 no. /	MR
B	Length of hose reel hose	30 mtrs.	30 mtrs. /	MR
C	Nozzle diameter	05 mm	05 mm /	MR
7	Automatic Fire Detection And Alarming System:			
A	Type of detectors (Co Type)	Required	Provided /	MR
B	Location of main panel	Required	Provided at first floor /	MR
C	Location of repeater panel	NA	NA	NA
D	Alternate source of power	Required	Provided /	MR
E	Hooters	Required	Provided /	MR
8	MOEFA:	NA	NA	NA
9	Public Address System:	Required	Provided /	MR
10	Automatic Sprinkler System:			
A	Basement	NA	NA	NA
B	Upper floor	NA	NA	NA
C	Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants:			
A	size of riser/down-comer	NA	NA	NA
B	Number of hydrants per floor	NA	NA	NA
C	Hose box	NA	NA	NA
12	Yard Hydrants:			
A	Total number of hydrants	NA	NA	NA
B	Hose box	NA	NA	NA
13	Pumping Arrangements:			
A	Ground level			
a)	Discharge of main pump	NA	NA	NA
b)	Head of main pump	NA	NA	NA
c)	Number of main pumps	NA	NA	NA
d)	Jockey pump out put	NA	NA	NA
e)	Jockey pump head	NA	NA	NA
f)	Standby pump out put	NA	NA	NA
g)	Standby pump head	NA	NA	NA
h)	Auto starting /manual stopping	NA	NA	NA
i)	Pump house access	NA	NA	NA
B	Terrace level			
a)	Discharge of pump	450 LPM	450 LPM /	MR
b)	Head of the pump	40 mtrs.	40 mtrs. /	MR
c)	Power supply	Required	Provided /	MR
d)	Auto starting of pump	Required	Provided /	MR

14	Captive Water Storage For Fire Fighting:			
	A	Underground tank capacity	NA	NA
	B	Draw-off connection	NA	NA
	C	Fire service inlet	NA	NA
	D	Access to tank	NA	NA
	E	Overhead tank capacity	5000 ltrs.	Provided ✓ MR
15	Exit Signage:		Required	Provided ✓ MR
16	Provision of Lifts:			
	A	Pressurization of lift shaft	NA	NA
	B	Pressurization of lift lobby	NA	NA
	C	Communication in lift car	NA	NA
	D	Firemen's grounding switch	NA	NA
	E	Lift signage	NA	NA
17	Standby Power Supply:		Required	Provided ✓ MR
18	Refuge Area:			
	A	Total area	NA	NA
	B	Location	NA	NA
19	Fire Control Room :			
	A	Detector system panel	NA	NA
	B	Flow switch panel	NA	NA
	C	Pa system panel	NA	NA
	D	Battery backup	NA	NA
	E	Building floor plans	NA	NA
20	Special Fire Protection Systems For Protection of Special Risks, If Any:		NA	NA

The fire protection systems provided in the building were tested, checked at randomly and found functional at the time of inspection.

Shortcomings communicated vide letter No.F6/DFS/MS/GH/NDZ/2024/265 dated 24.05.2024 has been rectified.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter No F6/DFS/MS/GH/NDZ/2021/37 dated 29.01.2021 is recommended to be renewed upto 3rd floor only, under Rule 35 of the Delhi Fire Service Rules 2010.

Sumit Kumar
27/06/2024

Signature of the Inspecting Officer
Name Sumit Kumar
Designation ADO (SPM)

DO (CD)

[Signature]
28/6/24

[Signature]
Dy. C.F.O.

[Signature]
01/07/24

C.F.O.
[Signature]
27/7/2024

Director
[Signature]
30/7/24

[Signature]
ADP/SPM