



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

656



No. F6/DFS/MS/EH/2024/ 211

Dated: 01/07/2024

FIRE SAFETY CERTIFICATE

Certified that the M/s Haldiram Product Pvt. Ltd. located at B-2, Ground & First floor, Gujrawala Town Part-I, Opp. Model Town-II, Delhi-110009 in the building comprised of Basement, Ground & 03 Floors owned/occupied by M/s Haldiram Product Pvt. Ltd. was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/EH/2021/257 dated 29.09.2021. The premises was inspected by the officers concerned of this department on 20.06.2024 in the presence of Mrs. Paramjeet Kaur (Manager) and found the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and building/ premise is fit for occupancy Class "Group D Assembly" (Restaurant) for ground & first floor only occupancy with effect from... 01/07/2024 for a period of 03 (Three) years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ... 01/07/2024 at New Delhi by

(Atul Garg)

Director

Ph. No. 011-23414000

Copy to:-

1. M/s Haldiram Product Pvt. Ltd. at B-2, Ground & First floor, Gujrawala Town Part-I, Opp. Model Town-II, Delhi-110009

Conditions for the validity of Fire Safety Certificate:

1. This Fire Safety Certificate is valid only Ground & First floor for assembly occupancy only. In case of any violation, this FSC will be treated as null & void.
2. All the means of escape/entry/exit shall be kept free from any obstruction.
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in./wps/wcm/connect/doi/fire/FIRE/Home/Forms>.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : M/s Haldi Ram Products Pvt. Ltd. , B-2, GF & FF, Gujrawala Town Delhi-110007.
2. Type of Occupancy : Assembly (Restaurant)
3. Composition of building : Basement, Ground & 03 upper floors, but restaurant, basement-Store, ground + first floor- **Haldiram Restaurant**, 2nd floor-vacant 3rd floor- barbeque nation
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/EH/2021/257 dated: 29.09.2021
6. Fire Safety directives letter No : NBC Part IV
7. Date of inspection : 20.06.2024
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers from the building side : Mrs. Paramjeet Kaur (Manager)
10. Year of Construction : 2018
11. Applicant's letter No. : Online MHA Portal ID No.2024060809017 dated: 11.06.2024

	Minimum Standards on fire prevention and fire safety U/R 33	NBC/ BBL Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06m	12m (approx)	MR
	• Gate width	4.5m	Directly accessible	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	02	02	MR
	b. Width of staircases			
	• Upper Floors	1.50m	Provided	MR
	• Basements	1.50m	Provided	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	01	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	02m	02m	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			

	<ul style="list-style-type: none"> Basements Upper floors 	Required	Exhaust Fan	MR
		Required	Natural Ventilation	MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types ISI marking 	12nos ABC/Co2 Yes	14nos ABC-10 /Co2-04 Yes	MR MR MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01each floor 30 m 5mm	01each floor 30m 5mm	MR MR MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Required Required Required Required Required	Provided Provided at ground floor Provided Provided Provided all level	MR MR MR MR MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	Required Required NA	Provided Provided NA	MR MR NA
11	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	100mm each floor 01 01	100mm each floor 01 01	MR MR MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA NA	NA NA	NA NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump 	N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A
		1620 LPM	900lpm each	MR

	➤ Head of the pump	40m	40m	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	25,000 LTR	30,000 LTR	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	Required	DG Set 62kva	MR
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room.			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested/ checked and found in working condition at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules. It is recommended to renew Fire Safety vide this department letter of even no. F6/DFS/MS/EH/2021/257 dated. 29.09.2021 Certificate under rule 37(3) of Delhi Fire Service Rules 2010.

~~DO (WZ)~~

24/06/2024

Dy. Chief Fire Officer (WZ)

Signature of the Inspecting Officer

Name :- C.L. Meena

Designation:- ADO/RN

2024-206
25/6/2024

25/6

25/6/2024

Director

24/06/24