

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/fireworks/NDZ//2024/ 428

Dated: 03/07/2024

**FIRE SAFETY CERTIFICATE**

Certified that M/s Faquir Chand Sahni Fireworks located at Shop no. 56, Sadar Bazar Chowk, Qutab Road, Delhi-06, proposed for running the trade of sale and possession of manufactured fireworks and Chinese crackers/ sparkles of same category in quantities and class as specified by licensing authority at ground floor of a building owned/occupied by Faquir Chand Sahni Fireworks, was granted FSC by this department vide letter No. F6/DFS/MS/fireworks/2020/NDZ/411 dated 09.10.2020. The premises was re-inspected by the officer concerned of this department on 25.06.2024 in the presence of Mr. Ravinder Sahni (Proprietor) and found that the said Shop has deemed complied with the guidelines issued by Joint Commissioner of Police (Lic.) and that the premises/building is fit for occupancy of Group J (Hazardous Occupancy) "Fireworks" at ground floor only, with effect from 03/07/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire Service Rules, 2010 printed below.

Issued 03/07/2024 at New Delhi by.

  
(Atul Garg)

Director  
Delhi Fire Service  
Tel: 011-23414000

**Copy to:-**

1. The Joint Commissioner of police (Licensing),  
1<sup>st</sup> Floor, P.S. Defence colony, New Delhi.
2. M/s Faquir Chand Sahni Fireworks at Shop no. 56, Sadar Bazar Chowk, Qutab Road, Delhi-06.

**Condition for the validity of fire safety certificate:-**

1. Parchatti & basement (Lower ground) should be sealed at all times.
2. All electrical wiring should be properly conduited or concealed and should be provided with and main isolation switch/MCB nears the exit. No loose wiring/connection is permitted.
3. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
4. The means of escaped shall be kept unobstructed/unlocked & remain available for speedy evacuation of occupants in case of an emergency.
5. No other trade is permitted in the same premises along with the fireworks trade. The licensing authority may kindly ensure that no other activity is allowed during the sale of fire crackers.
6. The NOC/FSC is valid for a period of three years from date of issue. The reference for inspection and subsequent NOC from fire safety point of view shall be made to this department before renewal of the license, clearly stating the period of license for which license is granted/renewed.
7. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

-N/20-

### INSPECTION REPORT

1. **Name & address of the building:-** M/s Faquir Chand Sahni Fireworks, located at Shop no. 56, Sadar Bazar Chowk, Qutab Road, Delhi-06 and has an approx area of 6 feet by 8.5 feet having basement/lower ground and parchhatti of same size)
2. **Type of occupancy:-** Group J (Hazardous Occupancy) Fireworks Shop (building is comprised of basement/lower ground & Parchatti)
3. **Type of case:-** Renewal
4. **Details of previous NOC: -** No. F6/DFS/MS/fireworks/2020/NDZ/411 dated 09.10.2020
5. **Fire safety directives No.-** N/A
6. **Date of inspection:-** 25.06.2024
7. **Name of the inspecting officer:-** Sumit Kumar, ADO (SPM)
8. **Name & designation of officer From the building side:-** Mr. Ravinder Sahni (Proprietor)  
Old Building
9. **Year of construction:-** Old Building
10. **Applicant's letter No:-** No.227-28/Joint C.P/Lic. (Expl./Fireworks), dated 11.6.2024

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Existing fire safety arrangements	Provided at site PSS	Remarks MR/NMR
1.	<b>Access to Building</b>			
	1) Road width	6 mtrs.	12 mtrs. ✓	MR
	2) Gate width	NA	NA	NA
	3) Width of internal road	NA	NA	NA
2.	<b>Number, Width Type &amp; Arrangement of Exits</b>			
	A. Number of staircases	NA	NA	NA
	1. Upper floors	NA	NA	NA
	2. Basements	NA	NA	NA
	B. Width of staircase	NA	NA	NA
	1. Upper floors	NA	NA	NA
	2. Basements	NA	NA	NA
	C. Protection of exits	NA	NA	NA
	1. Fire check door	NA	NA	NA
	2. Pressurization	NA	NA	NA
	D. No. of continuous staircase to terrace	NA	NA	NA
	E. Width of corridor	NA	NA	NA
	F. Door size	NA	NA	NA
	G. No. of exits	Independent entry and exit required	Provided ✓	MR
3.	<b>Compartmentation</b>			
	1) Fire check door	NA	NA	NA
	2) Sealing of electrical shafts	NA	NA	NA
	3) Fire rating of shaft door	NA	NA	NA
	4) Water curtain	NA	NA	NA
	5) Fire Dampers	NA	NA	NA
4.	<b>Smoke Management System</b>			
	1) Basements	12 ACPH	NA	NA
	2) Upper floors	12 ACPH	NA	NA
5.	<b>Fire Extinguishers</b>			
	1) Total numbers	05 Nos.	05 Nos. ✓	MR
	2) Types	ABC <sub>2</sub> , CO <sub>2</sub>	ABC, CO <sub>2</sub>	MR
	3) ISI marking	Required	Provided	MR

6

8



<b>6.</b>	<b>First-Aid Hose Reel</b>			
	1) Total number of each floor	NA	NA	NA
	2) Length of hose reel hose	NA	NA	NA
	3) Nozzle diameter	NA	NA	NA
<b>7.</b>	<b>Automatic Fire Detection &amp; Alarming System</b>			
	1) Type of detectors	NA	NA	NA
	2) Location of main panel	NA	NA	NA
	3) Location of repeater panel	NA	NA	NA
	4) Alternate source of power	NA	NA	NA
	5) Hooter's Location	NA	NA	NA
	6) PA system	NA	NA	NA
<b>8.</b>	<b>MOEFA</b>	NA	NA	NA
<b>9.</b>	<b>Public Address System</b>	NA	NA	NA
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	1) Basement	NA	NA	NA
	2) Upper floors	NA	NA	NA
	3) Sprinkler above false ceiling	NA	NA	NA
<b>11.</b>	<b>Internal Hydrants</b>			
	1) Size of riser/down-comer	NA	NA	NA
	2) Number of hydrants per floor	NA	NA	NA
	3) Hose box	NA	NA	NA
<b>12.</b>	<b>Yard Hydrants</b>			
	1) Total number of hydrants	NA	NA	NA
	2) Hose box	NA	NA	NA
<b>13.</b>	<b>Pumping Arrangement</b>			
	1) Ground level	NA	NA	NA
	a) Discharge of main pump	NA	NA	NA
	b) Head of main pump	NA	NA	NA
	c) Number of main pump	NA	NA	NA
	d) Jockey pump out put	NA	NA	NA
	e) Jockey pump head	NA	NA	NA
	f) Stand by pump output	NA	NA	NA
	g) Stand by pump head	NA	NA	NA
	h) Auto starting/Manual stopping	NA	NA	NA
	2) Terrace level	NA	NA	NA
	a) Discharge of pump	NA	NA	NA
	b) Head of pump	NA	NA	NA
	c) Power supply	NA	NA	NA
	d) Auto starting of pump	NA	NA	NA
<b>14.</b>	<b>Captive Water Storage for Fire Fighting</b>			
	1) Underground tank capacity	NA	NA	NA
	a) Draw-off connection	NA	NA	NA
	b) Fire service inlet	NA	NA	NA
	c) Access to tank	NA	NA	NA
	d) Over head tank capacity	NA	NA	NA
<b>15.</b>	<b>Exit Signage.</b>	Required	Provided	MR

u

9

16.	<b>Provision of Lifts.</b>			
	a) Pressurization of lift shaft	NA	NA	NA
	b) Pressurization of lift lobby	NA	NA	NA
	c) Communication in lift car	NA	NA	NA
	d) Fireman's switch	NA	NA	NA
	e) Lift signage	NA	NA	NA
17.	<b>Standby Power Supply</b>	NA	NA	NA
18.	<b>Refuge Area</b>	NA	NA	NA
	Total area location	NA	NA	NA
19.	<b>Fire Control Room</b>	NA	NA	NA
	a) Detector system panel	NA	NA	NA
	b) Flow switch panel	NA	NA	NA
	c) PA system panel	NA	NA	NA
	d) Battery backup	NA	NA	NA
	e) Building floor plan	NA	NA	NA
20.	<b>Special Fire Protection System for Protection of special Risk, if any:</b>			
	1. No Smoking signage Board, Sand Bucket & Water Buckets to be provided.	Provided ✓		MR
	2. Independent MCB for electrical isolation to be provided.	Provided ✓		MR
	3. Electrical wiring to be provided with proper casing and capping.	Provided ✓		MR

The fire protection system provided in the building were tested, checked at randomly and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/fireworks/2020/NDZ/411 dated 09.10.2020, renewal under rules 35 of the Fire Service rules 2010, is recommended.

*Sumit Kumar*  
27/06/2024

Signature of the Inspecting Officer  
Name Sumit Kumar  
Designation ADO (SPM)

~~DO (CD)~~  
*[Signature]*  
27/6/24

~~Dy. C.F.O. (NOC)~~      *[Signature]*  
28/06/24  
C.F.O. — On leave

~~Director~~  
*[Signature]*  
28/06/24

*[Signature]*  
Anand