

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/2024/School/WZ/ 643

Dated: 08/07/2024

FIRE SAFETY CERTIFICATE

Certified that the **M. R. Public School, Rajeev Nagar Extn., Barwala Road, Begum Pur, Delhi-86**, comprised of **Ground + Two upper floors** has already been issued FSC by this department vide letter No. **F.6/DFS/MS/School/WZ/2021/359** dated **04.05.2021**. The premises was re-inspected by the officer concerned of this department on **25.06.2024** in the presence of **Mr. Lokesh Kumar (Manager)** and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Group B Educational** with effect from 08/07/2024 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 08/07/2024 at New Delhi by


(Atul Garg)
DIRECTOR
Ph; 011-23414000

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sect. Delhi - 54.
2. The Principal, M. R. Public School, Rajeev Nagar Extn., Barwala Road, Begum Pur, Delhi-86.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

INSPECTION REPORT

1. Name & address of the building	M.R. Public School, Rajeev Nagar Extn., Barwala Road, Begum Pur, Delhi-86.
2. Type of Occupancy	Educational
3. Type of Case	Renewal (Ground + 02 upper floors)
4. Details of Previous NOC	F.6/DFS/MS/School/WZ/2021/359 dated 04.05.2021.
5. Fire Safety directives letter No	Director of Education Cir. dated 01.03.2011.
6. Date of inspection	25.06.2024.
7. Name of Inspecting Officer	Sh. Ajay Kumar Sharma (ADO Rohini)
8. Name and designation of officers From the building side	Mr. Lokesh Kumar (Manager)
9. Year of Construction	2005 & 2019
10. Applicant's letter No.	Online e-mail dated 21.06.2024

S. No	Minimum Standards on fire prevention and fire safety U/R 33	Cir. of Director of Education /NBC	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	4.0m	MR(Old case)
	• Width of internal road	-NA-	-NA-	-NA-
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	03nos.	02nos. & 01 ramp	MR
	• Basements	-NA-	-NA-	-NA-
	b. Width of staircases			
	• Upper Floor	1.5m	1.80m, 1.36m & 01 ramp 1.5m	MR
	• Basements	-NA-	-NA-	-NA-
	c. Protection of exits			
	• Fire check door	-NA-	-NA-	-NA-
	• Pressurization	-NA-	-NA-	-NA-
	d. No. of continuous staircases to terrace	02nos.	02nos.	MR
	e. Width of Corridor	-NA-	-NA-	-NA-
	f. Door Size	-NA-	-NA-	-NA-
3.	Compartmentation			
	a) Fire check door	-NA-	-NA-	-NA-
	b) Sealing of electrical shafts	-NA-	-NA-	-NA-
	c) Fire Rating of shaft door	-NA-	-NA-	-NA-
	d) Water Curtain	-NA-	-NA-	-NA-
	e) Fire Dampers	-NA-	-NA-	-NA-
4.	Smoke Management System			
	a) Basements	-NA-	-NA-	-NA-
	b) Upper floors	12 a/c per hour	Natural ventilated	MR
5.	Fire Extinguishers			
	a) Total numbers	07nos.	10nos.	MR
	b) Types	ABC/CO2	ABC/CO2	MR
	c) IS marking	ISI marked	Yes	MR
6.	First-Aid Hose Reels			
	a) Total numbers on each floor	01nos.	Provided	MR
	b) Length of hose reel hose	30mm	Provided	MR
	c) Nozzle diameter	5m	Provided	MR

My

7.	Automatic fire detection and alarming system			-NA-
	a) Type of detectors	-NA-	-NA-	-NA-
	b) Location of Main Panel	-NA-	-NA-	-NA-
	c) Location of Repeater Panel	-NA-	-NA-	-NA-
	d) Alternate source of power	-NA-	-NA-	-NA-
	e) Hooters' Location	-NA-	-NA-	-NA-
8.	MOEFA	-NA-	-NA-	-NA-
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			-NA-
	a) Basement	-NA-	-NA-	-NA-
	b) Ground & Upper Floors	-NA-	-NA-	-NA-
	c) Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants			-NA-
	a) Size of riser/down-comer	-NA-	-NA-	-NA-
	b) Number of hydrants per floor	-NA-	-NA-	-NA-
	c) Hose Box	-NA-	-NA-	-NA-
12.	Yard Hydrants			-NA-
	a) Total number of hydrants	-NA-	-NA-	-NA-
	b) Hose Box	-NA-	-NA-	-NA-
13.	Pumping Arrangements			-NA-
	• Ground Level	-NA-	-NA-	-NA-
	➤ Discharge of main Pump	-NA-	-NA-	-NA-
	➤ Head of Main pump	-NA-	-NA-	-NA-
	➤ Number of main pumps	-NA-	-NA-	-NA-
	➤ Jockey Pump out put	-NA-	-NA-	-NA-
	➤ Jockey pump head	-NA-	-NA-	-NA-
	➤ Standby Pump out put	-NA-	-NA-	-NA-
	➤ Standby Pump Head	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping	-NA-	-NA-	-NA-
	➤ Pump House Access	-NA-	-NA-	-NA-
	Terrace level			
	➤ Discharge of pump	450lpm	450lpm	MR
	➤ Head of the pump	40m	40m	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	-NA-	-NA-	-NA-
	➤ Draw-off connection	-NA-	-NA-	-NA-
	➤ Fire service inlet	-NA-	-NA-	-NA-
	➤ Access to tank	-NA-	-NA-	-NA-
	• Overhead Tank capacity	10,000ltr	10,000ltr	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of Lift Shaft	-NA-	-NA-	-NA-
	b) Pressurization of Lift lobby	-NA-	-NA-	-NA-
	c) Communication In lift Car	-NA-	-NA-	-NA-
	d) Fireman's Grounding Switch	-NA-	-NA-	-NA-
	e) Lift Signage	-NA-	-NA-	-NA-
17.	Standby power supply	-NA-	-NA-	-NA-

24

-NA-
-NA-

Refuge Area.

	a) Total Area	-NA-	-NA-	-NA-
	b) Location	-NA-	-NA-	-NA-
19.	Fire Control Room			
	a) Detector System Panel	-NA-	-NA-	-NA-
	b) Flow Switch Panel	-NA-	-NA-	-NA-
	c) PA System Panel	-NA-	-NA-	-NA-
	d) Battery backup	-NA-	-NA-	-NA-
	e) Building Floor Plans	-NA-	-NA-	-NA-
20.	Special Fire Protection System for Protection of special Risks, if any:	-NA-	-NA-	-NA-

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in Director of Education Circular/NBC, and removal of shortcomings issued vide letter no. 301 dated 28.05.2024, the FSC issued vide letter no. F.6/DFS/MS/School/WZ/2021/359 dated 04.05.2021, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended

Ajay K
22/6/24

Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO(Rohini)

DO (NW)

Ajay K
01/07/2024

Ajay K
24/07/2024

Ajay K
2/7

Ajay K
2/7/2024

Ajay K
15/7/24

JCFOI... 39
Dated... 02/07/2024

Fr letter is put up for kind perusal and
Signature Please.

Director *Ajay K*
15/7/24

Ajay K
11/7/24